

PAIKSED TULEKUSTUTUSSÜSTEEMID. AUTOMAATSED  
SPRINKLERSÜSTEEMID. PROJEKTEERIMINE,  
PAIGALDAMINE JA HOOLDUS

Fixed firefighting systems - Automatic sprinkler  
systems - Design, installation and maintenance

## ESTI STANDARDI EESSÖNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN 12845:2015+A1:2020 sisaldb Euroopa standardi EN 12845:2015+A1:2019 ingliskeelset teksti.	This Estonian standard EVS-EN 12845:2015+A1:2020 consists of the English text of the European standard EN 12845:2015+A1:2019.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatjas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 18.12.2019.	Date of Availability of the European standard is 18.12.2019.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 13.220.20

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:  
Koduleht [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage [www.evs.ee](http://www.evs.ee); phone +372 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

EN 12845:2015+A1

December 2019

ICS 13.220.20

Supersedes EN 12845:2015

English Version

Fixed firefighting systems - Automatic sprinkler systems -  
Design, installation and maintenance

Installations fixes de lutte contre l'incendie - Systèmes  
d'extinction automatique du type sprinkleur -  
Conception, installation et maintenance

Ortsfeste Brandbekämpfungsanlagen - Automatische  
Sprinkleranlagen - Planung, Installation und  
Instandhaltung

This European Standard was approved by CEN on 20 December 2014 and includes Amendment 1 approved by CEN on 2 October 2019.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

## Contents

	Page
<b>European foreword.....</b>	<b>12</b>
<b>Introduction .....</b>	<b>13</b>
<b>1 Scope.....</b>	<b>15</b>
<b>2 Normative references.....</b>	<b>15</b>
<b>3 Terms and definitions .....</b>	<b>16</b>
<b>4 Contract planning and documentation.....</b>	<b>24</b>
<b>4.1 General.....</b>	<b>24</b>
<b>4.2 Initial considerations.....</b>	<b>24</b>
<b>4.3 Preliminary or estimating stage.....</b>	<b>24</b>
<b>4.4 Design stage .....</b>	<b>25</b>
<b>4.4.1 General.....</b>	<b>25</b>
<b>4.4.2 Summary schedule.....</b>	<b>25</b>
<b>4.4.3 Installation layout drawings .....</b>	<b>25</b>
<b>4.4.4 Water supply.....</b>	<b>28</b>
<b>5 Extent of sprinkler protection.....</b>	<b>31</b>
<b>5.1 Buildings and areas to be protected.....</b>	<b>31</b>
<b>5.1.1 General.....</b>	<b>31</b>
<b>5.1.2 Permitted exceptions within a building.....</b>	<b>31</b>
<b>5.1.3 Necessary exceptions.....</b>	<b>31</b>
<b>5.2 Storage in the open air .....</b>	<b>31</b>
<b>5.3 Fire resistant separation .....</b>	<b>31</b>
<b>5.4 Protection of concealed spaces .....</b>	<b>32</b>
<b>5.5 Height difference between the highest and lowest sprinklers.....</b>	<b>32</b>
<b>6 Classification of occupancies and fire hazards.....</b>	<b>32</b>
<b>6.1 General.....</b>	<b>32</b>
<b>6.2 Hazard classes .....</b>	<b>32</b>
<b>6.2.1 General.....</b>	<b>32</b>
<b>6.2.2 Light Hazard - LH .....</b>	<b>32</b>
<b>6.2.3 Ordinary Hazard - OH.....</b>	<b>32</b>
<b>6.2.4 High Hazard - HH .....</b>	<b>33</b>
<b>6.3 Storage .....</b>	<b>34</b>
<b>6.3.1 General.....</b>	<b>34</b>
<b>6.3.2 Storage Configuration.....</b>	<b>34</b>
<b>7 Hydraulic design criteria.....</b>	<b>37</b>
<b>7.1 LH, OH and HHP .....</b>	<b>37</b>
<b>7.2 High Hazard Storage - HHS.....</b>	<b>38</b>
<b>7.2.1 General.....</b>	<b>38</b>
<b>7.2.2 Ceiling or roof protection only .....</b>	<b>38</b>
<b>7.2.3 Intermediate level in-rack sprinklers .....</b>	<b>39</b>
<b>7.3 Pressure and flow requirements for pre-calculated systems.....</b>	<b>41</b>
<b>7.3.1 LH and OH systems .....</b>	<b>41</b>
<b>7.3.2 HHP and HHS systems without in-rack sprinklers.....</b>	<b>42</b>
<b>8 Water supplies .....</b>	<b>44</b>

<b>8.1</b>	<b>General .....</b>	<b>44</b>
<b>8.1.1</b>	<b>Duration .....</b>	<b>44</b>
<b>8.1.2</b>	<b>Continuity .....</b>	<b>44</b>
<b>8.1.3</b>	<b>Frost protection.....</b>	<b>44</b>
<b>8.2</b>	<b>Maximum water pressure.....</b>	<b>44</b>
<b>8.3</b>	<b>Connections for other services .....</b>	<b>45</b>
<b>8.4</b>	<b>Housing of equipment for water supplies .....</b>	<b>46</b>
<b>8.5</b>	<b>Test facility devices.....</b>	<b>46</b>
<b>8.5.1</b>	<b>General .....</b>	<b>46</b>
<b>8.5.2</b>	<b>At pump house .....</b>	<b>47</b>
<b>8.5.3</b>	<b>At control valve sets.....</b>	<b>47</b>
<b>8.6</b>	<b>Water supply test.....</b>	<b>47</b>
<b>8.6.1</b>	<b>General .....</b>	<b>47</b>
<b>8.6.2</b>	<b>Storage tank and pressure tank supplies .....</b>	<b>47</b>
<b>8.6.3</b>	<b>Town main, booster pump, elevated private reservoir and gravity tank supplies .....</b>	<b>48</b>
<b>9</b>	<b>Type of water supply .....</b>	<b>48</b>
<b>9.1</b>	<b>General .....</b>	<b>48</b>
<b>9.2</b>	<b>Town mains.....</b>	<b>48</b>
<b>9.3</b>	<b>Storage tanks.....</b>	<b>48</b>
<b>9.3.1</b>	<b>General .....</b>	<b>48</b>
<b>9.3.2</b>	<b>Water volume.....</b>	<b>49</b>
<b>9.3.3</b>	<b>Refill rates for full capacity tanks .....</b>	<b>50</b>
<b>9.3.4</b>	<b>Reduced capacity tanks.....</b>	<b>50</b>
<b>9.3.5</b>	<b>Effective capacity of tanks and dimensions of suction chambers .....</b>	<b>52</b>
<b>9.3.6</b>	<b>Strainers.....</b>	<b>53</b>
<b>9.4</b>	<b>Inexhaustible sources – settling and suction chambers .....</b>	<b>53</b>
<b>9.5</b>	<b>Pressure tanks .....</b>	<b>56</b>
<b>9.5.1</b>	<b>General .....</b>	<b>56</b>
<b>9.5.2</b>	<b>Housing.....</b>	<b>56</b>
<b>9.5.3</b>	<b>Minimum capacity (water) .....</b>	<b>56</b>
<b>9.5.4</b>	<b>Air pressure and contents .....</b>	<b>56</b>
<b>9.5.5</b>	<b>Charging with air and water .....</b>	<b>57</b>
<b>9.5.6</b>	<b>Control and safety equipment.....</b>	<b>57</b>
<b>9.6</b>	<b>Choice of water supply .....</b>	<b>57</b>
<b>9.6.1</b>	<b>Single water supplies .....</b>	<b>57</b>
<b>9.6.2</b>	<b>Superior single water supplies .....</b>	<b>58</b>
<b>9.6.3</b>	<b>Duplicate water supplies .....</b>	<b>58</b>
<b>9.6.4</b>	<b>Combined water supplies .....</b>	<b>58</b>
<b>9.7</b>	<b>Isolation of water supply .....</b>	<b>59</b>
<b>10</b>	<b>Pumps .....</b>	<b>59</b>
<b>10.1</b>	<b>General .....</b>	<b>59</b>
<b>10.2</b>	<b>Multiple pump arrangements .....</b>	<b>59</b>
<b>10.3</b>	<b>Compartments for pumpsets.....</b>	<b>60</b>
<b>10.3.1</b>	<b>General .....</b>	<b>60</b>
<b>10.3.2</b>	<b>Sprinkler protection.....</b>	<b>60</b>
<b>10.3.3</b>	<b>Temperature .....</b>	<b>60</b>
<b>10.3.4</b>	<b>Ventilation.....</b>	<b>60</b>
<b>10.4</b>	<b>Maximum temperature of water supply .....</b>	<b>60</b>
<b>10.5</b>	<b>Valves and accessories.....</b>	<b>60</b>
<b>10.6</b>	<b>Suction conditions.....</b>	<b>61</b>
<b>10.6.1</b>	<b>General .....</b>	<b>61</b>
<b>10.6.2</b>	<b>Suction pipe .....</b>	<b>61</b>

<b>10.7 Performance characteristics.....</b>	<b>64</b>
<b>10.7.1 Pre-calculated systems - LH and OH .....</b>	<b>64</b>
<b>10.7.2 Pre-calculated systems - HHP and HHS with no in-rack sprinklers .....</b>	<b>65</b>
<b>10.7.3 Calculated systems .....</b>	<b>66</b>
<b>10.7.4 Pressure and water capacity of boosted town mains.....</b>	<b>67</b>
<b>10.7.5 Pressure switches .....</b>	<b>67</b>
<b>10.8 Electrically driven pumpsets .....</b>	<b>67</b>
<b>10.8.1 General.....</b>	<b>67</b>
<b>10.8.2 Electricity supply.....</b>	<b>67</b>
<b>10.8.3 Main switchboard .....</b>	<b>68</b>
<b>10.8.4 Installation between the main switchboard and the pump controller.....</b>	<b>68</b>
<b>10.8.5 Pump controller.....</b>	<b>69</b>
<b>10.8.6 Monitoring of pump operation.....</b>	<b>69</b>
<b>10.9 Diesel engine driven pumpsets.....</b>	<b>69</b>
<b>10.9.1 General.....</b>	<b>69</b>
<b>10.9.2 Engines.....</b>	<b>69</b>
<b>10.9.3 Cooling system .....</b>	<b>70</b>
<b>10.9.4 Air filtration .....</b>	<b>70</b>
<b>10.9.5 Exhaust system.....</b>	<b>70</b>
<b>10.9.6 Fuel, fuel tank and fuel feed pipes .....</b>	<b>70</b>
<b>10.9.7 Starting mechanism.....</b>	<b>71</b>
<b>10.9.8 Electric starter motor batteries .....</b>	<b>72</b>
<b>10.9.9 Battery chargers .....</b>	<b>72</b>
<b>10.9.10 Siting of batteries and chargers.....</b>	<b>72</b>
<b>10.9.11 Starter alarm indication.....</b>	<b>72</b>
<b>10.9.12 Tools and spare parts.....</b>	<b>73</b>
<b>10.9.13 Engine tests and exercising.....</b>	<b>73</b>
<b>11 Installation type and size .....</b>	<b>74</b>
<b>11.1 Wet pipe installations.....</b>	<b>74</b>
<b>11.1.1 General.....</b>	<b>74</b>
<b>11.1.2 Protection against freezing .....</b>	<b>74</b>
<b>11.1.3 Size of installations.....</b>	<b>74</b>
<b>11.2 Dry pipe installations .....</b>	<b>75</b>
<b>11.2.1 General.....</b>	<b>75</b>
<b>11.2.2 Size of installations.....</b>	<b>75</b>
<b>11.3 Alternate installations.....</b>	<b>75</b>
<b>11.3.1 General.....</b>	<b>75</b>
<b>11.3.2 Size of installations.....</b>	<b>76</b>
<b>11.4 Pre-action installations.....</b>	<b>76</b>
<b>11.4.1 General.....</b>	<b>76</b>
<b>11.4.2 Automatic detection system.....</b>	<b>76</b>
<b>11.4.3 Size of installations.....</b>	<b>77</b>
<b>11.5 Subsidiary dry pipe or alternate extension.....</b>	<b>77</b>
<b>11.5.1 General.....</b>	<b>77</b>
<b>11.5.2 Size of subsidiary extensions .....</b>	<b>77</b>
<b>11.6 Subsidiary water spray extension.....</b>	<b>77</b>
<b>12 Spacing and location of sprinklers.....</b>	<b>77</b>
<b>12.1 General.....</b>	<b>77</b>
<b>12.2 Maximum area of coverage per sprinkler .....</b>	<b>78</b>
<b>12.3 Minimum distance between sprinklers .....</b>	<b>80</b>
<b>12.4 Location of sprinklers in relation to building construction .....</b>	<b>80</b>
<b>12.5 Intermediate sprinklers in HH occupancies.....</b>	<b>86</b>

12.5.1	General .....	86
12.5.2	Maximum vertical distance between sprinklers at intermediate levels .....	86
12.5.3	Horizontal position of sprinklers at intermediate levels.....	86
12.5.4	Numbers of rows of sprinklers at each level .....	88
12.5.5	HHS intermediate sprinklers in non-shelved racks.....	88
12.5.6	HHS intermediate sprinklers below solid or slatted shelves in racks (ST5 and ST6) .....	89
13	Pipe sizing and layout .....	90
13.1	General .....	90
13.2	Calculation of pressure losses in pipework .....	90
13.2.1	Pipe friction loss .....	90
13.2.2	Static pressure difference.....	91
13.2.3	Velocity .....	91
13.2.4	Pressure loss through fittings and valves.....	91
13.2.5	Accuracy of calculations .....	92
13.3	Pre-calculated systems .....	93
13.3.1	General .....	93
13.3.2	Location of Design Points.....	93
13.3.3	Light Hazard - LH .....	94
13.3.4	Ordinary Hazard - OH.....	96
13.3.5	High hazard - HHP and HHS (except intermediate level sprinklers).....	97
13.4	Fully calculated systems .....	106
13.4.1	Design density.....	106
13.4.2	Locations of the area of operation.....	107
13.4.3	Shape of the area of operation .....	107
13.4.4	Minimum sprinkler discharge pressure .....	110
13.4.5	Minimum pipe diameters .....	110
14	Sprinkler design characteristics and uses.....	111
14.1	General .....	111
14.2	Sprinkler types and application.....	111
14.2.1	General .....	111
14.2.2	Ceiling, flush, recessed and concealed pattern .....	112
14.2.3	Sidewall pattern .....	112
14.2.4	Flat spray pattern .....	112
14.3	Flow from sprinklers.....	112
14.4	Sprinkler temperature ratings .....	113
14.5	Sprinkler thermal sensitivity .....	114
14.5.1	General .....	114
14.5.2	Interaction with other measures .....	114
14.6	Sprinkler guards .....	114
14.7	Sprinkler water shields .....	114
14.8	Sprinkler rosettes.....	115
14.9	Corrosion protection of sprinklers .....	115
15	Valves .....	115
15.1	Control valve set.....	115
15.2	Stop valves.....	115
15.3	Ring main valves .....	115
15.4	Drain valves .....	115
15.5	Test valves.....	116
15.5.1	Alarm and pump start test valves .....	116
15.5.2	Remote test valves.....	117
15.6	Flushing connections.....	117
15.7	Pressure gauges .....	117

15.7.1	General.....	117
15.7.2	Water supply connections.....	117
15.7.3	Control valve set.....	117
15.7.4	Removal.....	118
16	Alarms and alarm devices.....	118
16.1	Water flow alarms.....	118
16.1.1	General.....	118
16.1.2	Water motor and gong.....	118
16.1.3	Piping to water motor.....	118
16.2	Electrical water flow and pressure switches .....	118
16.2.1	General.....	118
16.2.2	Water flow alarm switches .....	118
16.2.3	Dry and pre-action systems.....	119
16.3	Fire brigade and remote central station alarm connection.....	119
17	Pipework.....	119
17.1	General.....	119
17.1.1	Underground piping.....	119
17.1.2	Above ground piping.....	119
17.1.3	Welding of steel pipe.....	119
17.1.4	Flexible pipes and joints.....	120
17.1.5	Concealment.....	120
17.1.6	Protection against fire and mechanical damage.....	120
17.1.7	Painting.....	120
17.1.8	Drainage .....	120
17.1.9	Copper pipe .....	121
17.2	Pipe supports.....	121
17.2.1	General.....	121
17.2.2	Spacing and location .....	121
17.2.3	Design.....	122
17.3	Pipework in concealed spaces.....	122
17.3.1	General.....	122
17.3.2	False ceilings above OH occupancies .....	122
17.3.3	All other cases .....	123
18	Signs, notices, and information .....	123
18.1	Block plan .....	123
18.2	Signs and notices .....	123
18.2.1	Location plate .....	123
18.2.2	Signs for stop valves .....	123
18.2.3	Control valve set.....	123
18.2.4	Water supply connections to other services .....	124
18.2.5	Suction and booster pumps.....	124
18.2.6	Electric switches and control panels.....	124
18.2.7	Testing and operating devices.....	125
19	Commissioning.....	125
19.1	Commissioning tests .....	125
19.1.1	Pipework.....	125
19.1.2	Equipment .....	125
19.1.3	Water supplies .....	126
19.2	Completion certificate and documents .....	126
20	Maintenance.....	126
20.1	General.....	126

<b>20.1.1</b>	<b>Introduction.....</b>	<b>126</b>
<b>20.1.2</b>	<b>Programmed work .....</b>	<b>126</b>
<b>20.1.3</b>	<b>Precautions while carrying out work.....</b>	<b>126</b>
<b>20.1.4</b>	<b>Replacement sprinklers .....</b>	<b>126</b>
<b>20.2</b>	<b>User's programme of inspection and checking.....</b>	<b>127</b>
<b>20.2.1</b>	<b>General .....</b>	<b>127</b>
<b>20.2.2</b>	<b>Weekly routine .....</b>	<b>127</b>
<b>20.2.3</b>	<b>Monthly routine .....</b>	<b>128</b>
<b>20.3</b>	<b>Service, testing and maintenance schedule .....</b>	<b>128</b>
<b>20.3.1</b>	<b>General .....</b>	<b>128</b>
<b>20.3.2</b>	<b>Quarterly routine.....</b>	<b>128</b>
<b>20.3.3</b>	<b>Half-yearly routine.....</b>	<b>129</b>
<b>20.3.4</b>	<b>Yearly routine .....</b>	<b>130</b>
<b>20.3.5</b>	<b>3 Yearly routine.....</b>	<b>130</b>
<b>20.3.6</b>	<b>10 yearly routine .....</b>	<b>131</b>
<b>21</b>	<b>[A<sub>1</sub>] Periodic system inspection.....</b>	<b>131</b>
<b>Annex A (normative) Classification of typical hazards .....</b>		<b>132</b>
<b>Annex B (normative) Methodology for categorizing stored goods.....</b>		<b>135</b>
<b>B.1</b>	<b>General .....</b>	<b>135</b>
<b>B.2</b>	<b>Material factor (M) .....</b>	<b>135</b>
<b>B.2.1</b>	<b>General .....</b>	<b>135</b>
<b>B.2.2</b>	<b>Material Factor 1.....</b>	<b>135</b>
<b>B.2.3</b>	<b>Material factor 2.....</b>	<b>136</b>
<b>B.2.4</b>	<b>Material factor 3.....</b>	<b>136</b>
<b>B.2.5</b>	<b>Material factor 4.....</b>	<b>137</b>
<b>B.3</b>	<b>Storage configuration.....</b>	<b>137</b>
<b>B.3.1</b>	<b>Effect of storage configuration.....</b>	<b>137</b>
<b>B.3.2</b>	<b>Exposed plastic container with non-combustible content .....</b>	<b>138</b>
<b>B.3.3</b>	<b>Exposed plastic surface – unexpanded .....</b>	<b>138</b>
<b>B.3.4</b>	<b>Exposed plastic surface – expanded.....</b>	<b>138</b>
<b>B.3.5</b>	<b>Open structure.....</b>	<b>138</b>
<b>B.3.6</b>	<b>Solid block materials.....</b>	<b>139</b>
<b>B.3.7</b>	<b>Granular or powdered materials .....</b>	<b>139</b>
<b>B.3.8</b>	<b>No special configuration .....</b>	<b>139</b>
<b>Annex C (normative) Alphabetical listing of stored products and categories.....</b>		<b>140</b>
<b>Annex D (normative) Zoning of sprinkler installations .....</b>		<b>144</b>
<b>D.1</b>	<b>General .....</b>	<b>144</b>
<b>D.2</b>	<b>Zoning of installations .....</b>	<b>144</b>
<b>D.3</b>	<b>Requirements for zoned installations.....</b>	<b>144</b>
<b>D.3.1</b>	<b>Extent of zones.....</b>	<b>144</b>
<b>D.3.2</b>	<b>Zone subsidiary stop valves.....</b>	<b>144</b>

<b>D.3.3</b>	<b>Flushing Valves .....</b>	<b>144</b>
<b>D.3.4</b>	<b>Monitoring.....</b>	<b>144</b>
<b>D.3.5</b>	<b>Zone test and drainage facilities.....</b>	<b>145</b>
<b>D.3.6</b>	<b>Installation control valve set .....</b>	<b>145</b>
<b>D.3.7</b>	<b>Installation monitoring and alarms .....</b>	<b>145</b>
<b>D.4</b>	<b>Block plan .....</b>	<b>145</b>
<b>Annex E (normative) Special requirements for high rise systems.....</b>		<b>147</b>
<b>E.1</b>	<b>General.....</b>	<b>147</b>
<b>E.2</b>	<b>Design criteria.....</b>	<b>147</b>
<b>E.2.1</b>	<b>Hazard group .....</b>	<b>147</b>
<b>E.2.2</b>	<b>Subdivision of high rise sprinkler systems.....</b>	<b>147</b>
<b>E.2.3</b>	<b>Standing water pressures at non-return and alarm valves .....</b>	<b>147</b>
<b>E.2.4</b>	<b>Calculation of distribution pipework for pre-calculated systems.....</b>	<b>147</b>
<b>E.2.5</b>	<b>Water pressures .....</b>	<b>147</b>
<b>E.3</b>	<b>Water supplies .....</b>	<b>148</b>
<b>E.3.1</b>	<b>Types of water supplies .....</b>	<b>148</b>
<b>E.3.2</b>	<b>Pressure and flow requirements for pre-calculated installations.....</b>	<b>148</b>
<b>E.3.3</b>	<b>Water supply characteristics for pre-calculated installations .....</b>	<b>148</b>
<b>E.3.4</b>	<b>Pump performance for pre-calculated installations.....</b>	<b>148</b>
<b>Annex F (normative) Additional measures to improve system reliability and availability .....</b>		<b>151</b>
<b>F.1</b>	<b>General.....</b>	<b>151</b>
<b>F.2</b>	<b>Subdivision into zones .....</b>	<b>151</b>
<b>F.3</b>	<b>Wet pipe installations.....</b>	<b>151</b>
<b>F.4</b>	<b>Sprinkler type and sensitivity .....</b>	<b>151</b>
<b>F.5</b>	<b>Control valve set.....</b>	<b>151</b>
<b>F.6</b>	<b>Water supplies .....</b>	<b>151</b>
<b>F.7</b>	<b>Additional measures for theatres .....</b>	<b>151</b>
<b>F.8</b>	<b>Additional precautions for maintenance .....</b>	<b>152</b>
<b>Annex G (normative) Protection of special hazards.....</b>		<b>153</b>
<b>G.1</b>	<b>General.....</b>	<b>153</b>
<b>G.2</b>	<b>Aerosols .....</b>	<b>153</b>
<b>G.3</b>	<b>Clothes in multiple garment hanging storage.....</b>	<b>153</b>
<b>G.3.1</b>	<b>General.....</b>	<b>153</b>
<b>G.3.2</b>	<b>Categorization .....</b>	<b>154</b>
<b>G.3.3</b>	<b>Sprinkler protection other than at ceiling.....</b>	<b>154</b>
<b>G.3.4</b>	<b>Sprinklers in operation.....</b>	<b>154</b>

<b>G.3.5</b>	<b>Ceiling sprinklers .....</b>	<b>154</b>
<b>G.3.6</b>	<b>Automatic shutdown .....</b>	<b>154</b>
<b>G.3.7</b>	<b>Control valve set.....</b>	<b>155</b>
<b>G.4</b>	<b>Flammable liquid storage.....</b>	<b>155</b>
<b>G.5</b>	<b>Idle pallets.....</b>	<b>157</b>
<b>G.6</b>	<b>Spirit based liquors in wooden barrels .....</b>	<b>158</b>
<b>G.7</b>	<b>Non-woven synthetic fabric .....</b>	<b>158</b>
<b>G.7.1</b>	<b>Free standing storage.....</b>	<b>158</b>
<b>G.7.2</b>	<b>Rack storage .....</b>	<b>159</b>
<b>G.8</b>	<b>Polypropylene or polyethylene storage bins.....</b>	<b>159</b>
<b>G.8.1</b>	<b>General .....</b>	<b>159</b>
<b>G.8.2</b>	<b>Classification .....</b>	<b>159</b>
<b>G.8.3</b>	<b>Palletized rack storage (ST4) .....</b>	<b>159</b>
<b>G.8.4</b>	<b>All other storage.....</b>	<b>159</b>
<b>G.8.5</b>	<b>Foam additive.....</b>	<b>160</b>
<b>Annex H (normative) Sprinkler systems monitoring.....</b>		<b>161</b>
<b>H.1</b>	<b>General .....</b>	<b>161</b>
<b>H.2</b>	<b>Functions to be monitored .....</b>	<b>161</b>
<b>H.2.1</b>	<b>General .....</b>	<b>161</b>
<b>H.2.2</b>	<b>Stop valves controlling water flow to sprinklers .....</b>	<b>161</b>
<b>H.2.3</b>	<b>Other stop valves .....</b>	<b>161</b>
<b>H.2.4</b>	<b>Liquid levels.....</b>	<b>161</b>
<b>H.2.5</b>	<b>Pressures .....</b>	<b>161</b>
<b>H.2.6</b>	<b>Electrical power .....</b>	<b>162</b>
<b>H.2.7</b>	<b>Temperature .....</b>	<b>162</b>
<b>Annex I (normative) Transmission of alarms .....</b>		<b>163</b>
<b>I.1</b>	<b>Functions to be monitored .....</b>	<b>163</b>
<b>I.2</b>	<b>Alarm levels .....</b>	<b>164</b>
<b>Annex J (informative) Precautions and procedures when a system is not fully operational.....</b>		<b>165</b>
<b>J.1</b>	<b>Minimizing the effects.....</b>	<b>165</b>
<b>J.2</b>	<b>Planned shut-down .....</b>	<b>165</b>
<b>J.3</b>	<b>Unplanned shut-down.....</b>	<b>166</b>
<b>J.4</b>	<b>Action following sprinkler operation .....</b>	<b>166</b>
<b>J.4.1</b>	<b>General .....</b>	<b>166</b>
<b>J.4.2</b>	<b>Installations protecting cold storage warehouses (air circulation refrigeration) .....</b>	<b>166</b>
<b>Annex K (informative) Twenty-five year inspection.....</b>		<b>167</b>

<b>Annex L (informative) Special technology .....</b>	<b>168</b>
<b>Annex M (informative) Independent certification body .....</b>	<b>169</b>
<b>Annex N (normative) Control Mode Specific Application Sprinklers: CMSA .....</b>	<b>170</b>
<b>N.1 Introduction.....</b>	<b>170</b>
<b>N.1.1 General.....</b>	<b>170</b>
<b>N.1.2 Definitions .....</b>	<b>170</b>
<b>N.1.3 General.....</b>	<b>170</b>
<b>N.1.4 Sprinkler type and temperature rating .....</b>	<b>170</b>
<b>N.1.5 Water demand.....</b>	<b>171</b>
<b>N.2 Sprinkler location .....</b>	<b>171</b>
<b>N.2.1 Sprinkler spacing .....</b>	<b>171</b>
<b>N.2.2 Range pipe sizes.....</b>	<b>171</b>
<b>N.2.3 Minimum clear space below sprinklers.....</b>	<b>171</b>
<b>N.2.4 Excessive clearance .....</b>	<b>171</b>
<b>N.2.5 Distance of sprinklers below ceiling .....</b>	<b>171</b>
<b>N.2.6 Location of sprinklers in beam and girder, concrete T and panel construction .....</b>	<b>172</b>
<b>N.2.7 Obstructions to sprinkler distribution.....</b>	<b>172</b>
<b>N.3 Design.....</b>	<b>176</b>
<b>Annex O (informative) Example of P&amp;ID .....</b>	<b>182</b>
<b>Annex P (normative) ESFR sprinkler protection.....</b>	<b>183</b>
<b>P.1 Introduction.....</b>	<b>183</b>
<b>P.2 Scope .....</b>	<b>183</b>
<b>P.3 Definitions .....</b>	<b>183</b>
<b>P.3.1 Sprinkler, ESFR pattern .....</b>	<b>183</b>
<b>P.3.2 Suppression mode .....</b>	<b>183</b>
<b>P.3.3 Classification of goods .....</b>	<b>183</b>
<b>P.3.4 Ceiling height .....</b>	<b>184</b>
<b>P.3.5 Laced tyre storage.....</b>	<b>184</b>
<b>P.3.6 Paper categories, based on weight .....</b>	<b>184</b>
<b>P.4 Contract arrangements .....</b>	<b>184</b>
<b>P.5 General.....</b>	<b>184</b>
<b>P.6 Occupancies and fire hazards .....</b>	<b>185</b>
<b>P.7 Racked, shelved and post pallet storage.....</b>	<b>185</b>
<b>P.7.1 Longitudinal and transverse flues .....</b>	<b>185</b>
<b>P.7.2 Shelving.....</b>	<b>186</b>
<b>P.7.3 In-rack sprinklers for ESFR systems .....</b>	<b>186</b>

<b>P.7.4 Design requirements.....</b>	<b>186</b>
<b>P.8 Building requirements .....</b>	<b>205</b>
<b>P.8.1 Roof or ceiling slope .....</b>	<b>205</b>
<b>P.8.2 Measures required to correct excessive roof or ceiling slope.....</b>	<b>205</b>
<b>P.8.3 Ceiling strength .....</b>	<b>206</b>
<b>P.8.4 Sky lights.....</b>	<b>206</b>
<b>P.8.5 Powered ventilation .....</b>	<b>206</b>
<b>P.8.6 Walkways and conveyors .....</b>	<b>208</b>
<b>P.8.7 Sprinkler protection beneath mezzanines.....</b>	<b>208</b>
<b>P.9 ESFR sprinkler installation design.....</b>	<b>208</b>
<b>P.9.1 Installation type .....</b>	<b>208</b>
<b>P.9.2 Sprinkler nominal k-factor .....</b>	<b>208</b>
<b>P.9.3 Temperature ratings thermal sensitivity and colour codings .....</b>	<b>208</b>
<b>P.9.4 ESFR sprinkler location relative to obstructions at or near the ceiling or roof.....</b>	<b>209</b>
<b>P.10 Pipe sizing .....</b>	<b>210</b>
<b>P.10.1 General .....</b>	<b>210</b>
<b>P.10.2 Minimum pipe sizes.....</b>	<b>210</b>
<b>P.10.3 Minimum ESFR sprinkler flow pressure .....</b>	<b>210</b>
<b>P.10.4 The number of sprinklers assumed to be operating .....</b>	<b>210</b>
<b>P.10.5 Shape of design sprinkler area .....</b>	<b>211</b>
<b>P.10.6 Sprinklers beneath obstructions .....</b>	<b>211</b>
<b>P.11 Sprinkler spacing and location.....</b>	<b>211</b>
<b>P.11.1 ESFR sprinkler area of coverage .....</b>	<b>211</b>
<b>P.11.2 Obstructions .....</b>	<b>211</b>
<b>P.11.3 Sprinkler positioning relative to roof and ceilings .....</b>	<b>212</b>
<b>P.11.4 Sprinkler orientation relative to the floor or pipework .....</b>	<b>212</b>
<b>P.11.5 Clear space below sprinklers .....</b>	<b>212</b>
<b>P.11.6 Sprinkler location relative to draught or smoke curtains.....</b>	<b>212</b>
<b>P.11.7 Positioning of ESFR sprinklers relative to draught or smoke curtains.....</b>	<b>212</b>
<b>P.11.8 ESFR sprinkler protection adjacent to areas protected by standard sprinklers.....</b>	<b>212</b>
<b>P.12 Water supplies.....</b>	<b>213</b>
<b>P.12.1 Pump drive and power arrangements .....</b>	<b>213</b>
<b>P.12.2 Pump selection .....</b>	<b>213</b>
<b>P.12.3 Duration.....</b>	<b>213</b>
<b>Annex Q (informative)  Periodic system inspection .....</b>	<b>214</b>
<b>Bibliography .....</b>	<b>215</b>

## European foreword

This document (EN 12845:2015+A1:2019) has been prepared by Technical Committee CEN/TC 191 "Fixed firefighting systems", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2020, and conflicting national standards shall be withdrawn at the latest by June 2020.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes ~~EN 12845:2015~~ and EN 12845:2015/AC:2016 ~~and~~.

The start and finish of text introduced or altered by amendment is indicated in the text by tags ~~AC~~ AC and ~~A<sub>1</sub>~~ A<sub>1</sub>.

It is included in a series of European Standards planned to cover:


- automatic sprinkler systems (EN 12259);
- gas extinguishing systems (EN 12094);
- powder systems (EN 12416);
- explosion protection systems (ISO 6184);
- foam systems (EN 13565);
- gas systems (EN 12094);
- hydrant and hose reel systems (EN 671);
- smoke and heat control systems (EN 12101).

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## Introduction

An automatic sprinkler system is designed to detect a fire and extinguish it with water in its early stages or hold the fire in check so that extinguishment can be completed by other means.

A sprinkler system consists of a water supply (or supplies) and one or more sprinkler installations; each installation consists of a set of installation main control valves and a pipe array fitted with sprinkler heads. The sprinkler heads are fitted at specified locations at the roof or ceiling, and where necessary between racks, below shelves, and in ovens or stoves. The main elements of a typical installation are shown in Figure 1.



### Key

1	sprinkler head	6	main distribution pipe
2	riser	7	control valve set
3	design point	8	riser
4	distribution pipe spur	9	range pipes
5	arm pipe	10	drop

**Figure 1 — Main elements of a sprinkler installation**

The sprinklers operate at predetermined temperatures to discharge water over the affected part of the area below. The flow of water through the alarm valve initiates a fire alarm. The operating temperature is generally selected to suit ambient temperature conditions.

Only sprinklers in the vicinity of the fire, i.e. those which become sufficiently heated, operate.

The sprinkler system is intended to extend throughout the premises with only limited exceptions.

It should not be assumed that the provision of a sprinkler system entirely obviates the need for other means of fighting fires and it is important to consider the fire precautions in the premises as a whole.

Structural fire resistance, escape routes, fire alarm systems, particular hazards needing other fire protection methods, provision of hose reels and fire hydrants and portable fire extinguishers, etc., safe working and goods handling methods, management supervision and good housekeeping all need consideration.

It is essential that sprinkler systems should be properly maintained to ensure operation when required. This routine is liable to be overlooked or given insufficient attention by supervisors. It is, however,

neglected at peril to the lives of occupants of the premises and at the risk of crippling financial loss. The importance of proper maintenance cannot be too highly emphasized.

When sprinkler systems are out of service extra attention should be paid to fire precautions and the appropriate authorities informed.

It is a basic assumption that this standard is for the use of companies employing personnel competent in the field of application with which it deals. Only trained and experienced personnel should undertake the design, installation and maintenance of sprinkler systems. Similarly, competent technicians should be used in the installation and testing of the equipment (see Annex M).

## 1 Scope

This European Standard specifies requirements and gives recommendations for the design, installation and maintenance of fixed fire sprinkler systems in buildings and industrial plants, and particular requirements for sprinkler systems that are integral to measures for the protection of life.

This European Standard covers only the types of sprinkler specified in EN 12259-1 (see Annex L).

The requirements and recommendations of this European Standard are also applicable to any addition, extension, repair or other modification to a sprinkler system. They are not applicable to water spray or deluge systems.

It covers the classification of hazards, provision of water supplies, components to be used, installation and testing of the system, maintenance, and the extension of existing systems, and identifies construction details of buildings which are the minimum necessary for satisfactory performance of sprinkler systems complying with this European Standard.

This European Standard does not cover water supplies to systems other than sprinklers. Its requirements can be used as guidance for other fixed firefighting extinguishing systems, provided that any specific requirements for other firefighting extinguishing supplies are taken into account.

This European Standard is intended for use by those concerned with purchasing, designing, installing, testing, inspecting, approving, operating and maintaining automatic sprinkler systems, in order that such equipment will function as intended throughout its life.

This European Standard is intended only for fixed fire sprinkler systems in buildings and other premises on land. Although the general principles might well apply to other uses (e.g. maritime use). For these other uses additional considerations should be taken into account.

The requirements are not valid for automatic sprinkler systems on ships, in aircraft, on vehicles and mobile fire appliances or for below ground systems in the mining industry.

Sprinkler system design deviations might be allowed when such deviations have been shown to provide a level of protection at least equivalent to this European Standard, for example by means of full-scale fire testing where appropriate, and where the design criteria have been fully documented.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54 (all parts), *Fire detection and fire alarm systems*

EN 1057, *Copper and copper alloys — Seamless, round copper tubes for water and gas in sanitary and heating applications*

EN 1254 (all parts), *Copper and copper alloys — Plumbing fittings*

EN 12259-1, *Fixed firefighting systems — Components for sprinkler and water spray systems — Part 1: Sprinklers*

EN 12259-2, *Fixed firefighting systems — Components for sprinkler and water spray systems — Part 2: Wet alarm valve assemblies*

EN 12259-3, *Fixed firefighting systems — Components for automatic sprinkler and water spray systems — Part 3: Dry alarm valve assemblies*

EN 12259-4, *Fixed firefighting systems — Components for sprinkler and water spray systems — Part 4: Water motor alarms*

EN 12259-5, *Fixed firefighting systems — Components for sprinkler and water spray systems — Part 5: Water flow detectors*

EN 50342-1, *Lead-acid starter batteries — Part 1: General requirements and methods of test*

EN 50342-2, *Lead-acid starter batteries — Part 2: Dimensions of batteries and marking of terminals*

EN 60332 (all parts), *Tests on electric and optical fibre cables under fire conditions (IEC 60332)*

EN 60529, *Degrees of protection provided by enclosures (IP Code) (IEC 60529)*

EN 60623, *Secondary cells and batteries containing alkaline or other non-acid electrolytes — Vented nickel-cadmium prismatic rechargeable single cells (IEC 60623)*

EN 60947-1, *Low-voltage switchgear and controlgear — Part 1: General rules (IEC 60947-1)*

EN 60947-4, *Low-voltage switchgear and control gear — Part 4: Contactors and motor-starters — Electromechanical contactors and motor-starters (IEC 60947-4)*

EN ISO 3677, *Filler metal for soft soldering, brazing and braze welding — Designation (ISO 3677)*

EN ISO 9606-1, *Qualification testing of welders — Fusion welding — Part 1: Steels (ISO 9606-1)*

ISO 65, *Carbon steel tubes suitable for screwing in accordance with ISO 7-1*

ISO 3046 (all parts), *Reciprocating internal combustion engines — Performance*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

#### 3.1

##### **'A' gauge**

pressure gauge connected to a town main connection, between the supply pipe stop valve and the non-return valve

#### 3.2

##### **accelerator**

device that reduces the delay in operation of a dry alarm valve, or composite alarm valve in dry mode, by early detection of the drop in air or inert gas pressure on sprinkler operation

#### 3.3

##### **alarm test valve**

valve through which water might be drawn to test the operation of the water motor fire alarm and/or of any associated electric fire alarm

#### 3.4

##### **alarm valve**

non-return valve, of the wet, dry or composite type that also initiates the water motor fire alarm when the sprinkler installation operates