

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Electricity metering equipment – Particular requirements –
Part 23: Static meters for reactive energy (classes 2 and 3)**

**Équipement de comptage de l'électricité – Exigences particulières –
Partie 23: Compteurs statiques d'énergie réactive (classes 2 et 3)**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2020 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Electricity metering equipment – Particular requirements –
Part 23: Static meters for reactive energy (classes 2 and 3)**

**Équipement de comptage de l'électricité – Exigences particulières –
Partie 23: Compteurs statiques d'énergie réactive (classes 2 et 3)**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 17.220.20

ISBN 978-2-8322-8440-7

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD	3
INTRODUCTION	5
1 Scope	7
2 Normative references	8
3 Terms and definitions	8
4 Standard electrical values.....	9
4.1 Voltages	9
4.2 Currents.....	9
4.2.1 General	9
4.2.2 Starting current (see Table 1)	9
4.2.3 Minimum current (see Table 2)	9
4.2.4 Maximum current.....	9
4.3 Frequencies	9
4.4 Power consumption.....	9
5 Construction requirements.....	10
6 Meter marking and documentation	10
7 Accuracy requirements	10
7.1 General test conditions	10
7.2 Methods of accuracy verification	10
7.3 Measurement uncertainty	10
7.4 Meter constant.....	10
7.5 Initial start-up of the meter	10
7.6 Test of no-load condition.....	10
7.7 Starting current test	10
7.8 Repeatability test.....	10
7.9 Limits of error due to variation of the current.....	10
7.10 Limits of error due to influence quantities.....	11
7.11 Time-keeping accuracy	13
8 Climatic requirements	13
9 The effects of external influences	14
10 Type test	14
Annex A (informative) Geometric representation of active and reactive power.....	15
Annex B (informative) Summary of changes.....	17
Figure A.1 – Recommended geometric representation	15
Figure A.2 – Alternative geometric representation.....	16
Table 1 – Starting current	9
Table 2 – Minimum current.....	9
Table 3 – Acceptable percentage error limits (single-phase meters and poly-phase meters with balanced loads or single-phase loads)	11
Table 4 – Acceptable limits of variation in percentage error due to influence quantities.....	12

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICITY METERING EQUIPMENT –
PARTICULAR REQUIREMENTS –****Part 23: Static meters for reactive energy (classes 2 and 3)****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62053-23 has been prepared by IEC technical committee 13: Electrical energy measurement and control.

This second edition cancels and replaces the first edition published in 2003 and its amendment 1:2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition: see Annex B.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
13/1807A/FDIS	13/1815/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62053 series, published under the general title *Electricity metering equipment – Particular requirements*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

NOTE The attention of National Committees is drawn to the fact that equipment manufacturers and testing organizations may need a transitional period following publication of a new, amended or revised IEC publication in which to make products in accordance with the new requirements and to equip themselves for conducting new or revised tests.

It is the recommendation of the committee that the content of this publication be adopted for implementation nationally not earlier than 2 years from the date of publication.

INTRODUCTION

This part of IEC 62053 is to be used with relevant parts of the IEC 62052, IEC 62058 and IEC 62059 series, *Electricity metering equipment*, and with the IEC 62055 series, *Electricity metering – Payment systems*:

IEC 62052-11:2020,	<i>Electricity metering equipment – General requirements, tests and test conditions – Part 11: Metering equipment</i>
IEC 62052-31:2015,	<i>Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 31: Product safety requirements and tests</i>
IEC 62053-11:2003,	<i>Electricity metering equipment (AC) – Particular requirements – Part 11: Electromechanical meters for active energy (classes 0,5, 1 and 2)</i>
IEC 62053-21:2020,	<i>Electricity metering equipment – Particular requirements – Part 21: Static meters for AC active energy (classes 0,5, 1 and 2)</i>
IEC 62053-22:2020,	<i>Electricity metering equipment – Particular requirements – Part 22: Static meters for AC active energy (classes 0,1 S, 0,2 S and 0,5 S)</i>
IEC 62053-24:2020,	<i>Electricity metering equipment – Particular requirements – Part 24: Static meters for fundamental component reactive energy (classes 0,5 S, 1 S, 1, 2 and 3)</i>
IEC 62055-31:2005,	<i>Electricity metering – Payment systems – Part 31: Particular requirements – Static payment meters for active energy (classes 1 and 2)</i>
IEC 62057-1: –	<i>Test equipment, techniques and procedures for electrical energy meters – Part 1: Stationary Meter Test Units (MTU)</i>
IEC 62058-11:2008,	<i>Electricity metering equipment (AC) – Acceptance inspection – Part 11: General acceptance inspection methods</i>
IEC 62058-21:2008,	<i>Electricity metering equipment (AC) – Acceptance inspection – Part 21: Particular requirements for electromechanical meters for active energy (classes 0,5, 1 and 2)</i>
IEC 62058-31:2008,	<i>Electricity metering equipment (AC) – Acceptance inspection – Part 31: Particular requirements for static meters for active energy (classes 0,2 S, 0,5 S, 1 and 2)</i>
IEC 62059-11:2002,	<i>Electricity metering equipment – Dependability – Part 11: General concepts</i>
IEC 62059-21:2002,	<i>Electricity metering equipment – Dependability – Part 21: Collection of meter dependability data from the field</i>
IEC 62059-32-1:2011,	<i>Electricity metering equipment – Dependability – Part 32-1: Durability – Testing of the stability of metrological characteristics by applying elevated temperature</i>

This part is a standard for type testing electricity meters. It covers the particular requirements for meters, being used indoors and outdoors in large quantities worldwide. It does not deal with special implementations (such as metering-part and/or displays in separate housings).

This document is intended to be used in conjunction with IEC 62052-11:2020 and with IEC 62052-31:2015. When any requirement in this document concerns an item already covered in IEC 62052-11:2020 or in IEC 62052-31:2015, the requirements of this document take precedence over the requirements of IEC 62052-11:2020 or of IEC 62052-31:2015.

The test levels are regarded as minimum values that provide for the proper functioning of the meter under normal working conditions. For special applications, additional test levels might be necessary and are subject to an agreement between the manufacturer and the purchaser.

This document is a preview generated by EVS

ELECTRICITY METERING EQUIPMENT – PARTICULAR REQUIREMENTS –

Part 23: Static meters for reactive energy (classes 2 and 3)

1 Scope

This part of IEC 62053 applies only to static var-hour meters of accuracy classes 2 and 3 for the measurement of alternating current electrical reactive energy in 50 Hz or 60 Hz networks and it applies to their type tests only.

For practical reasons, this document is based on a conventional definition of reactive energy for sinusoidal currents and voltages containing the fundamental frequency only.

NOTE 1 For other general requirements, such as safety, dependability, etc., see the relevant IEC 62052 or IEC 62059 standards.

This document applies to electricity metering equipment designed to:

- measure and control electrical energy on electrical networks (mains) with voltage up to 1 000 V;

NOTE 2 For AC electricity meters, the voltage mentioned above is the line-to-neutral voltage derived from nominal voltages. See IEC 62052-31:2015, Table 7.

- have all functional elements, including add-on modules, enclosed in, or forming a single meter case with exception of indicating displays;
- operate with integrated or detached indicating displays, or without an indicating display;
- be installed in a specified matching socket or rack;
- optionally, provide additional functions other than those for measurement of electrical energy.

Meters designed for operation with low power instrument transformers (LPITs as defined in the IEC 61869 series) may be considered as compliant with this document only if such meters and their LPITs are tested together and meet the requirements for directly connected meters.

NOTE 3 Modern electricity meters typically contain additional functions such as measurement of voltage magnitude, current magnitude, power, frequency, power factor, etc.; measurement of power quality parameters; load control functions; delivery, time, test, accounting, recording functions; data communication interfaces and associated data security functions. The relevant standards for these functions may apply in addition to the requirements of this document. However, the requirements for such functions are outside the scope of this document.

NOTE 4 Product requirements for power metering and monitoring devices (PMDs) and measurement functions such as voltage magnitude, current magnitude, power, frequency, etc., are covered in IEC 61557-12. However, devices compliant with IEC 61557-12 are not intended to be used as billing meters unless they are also compliant with IEC 62052-11:2020 and one or more relevant IEC 62053-xx accuracy class standards.

NOTE 5 Product requirements for power quality instruments (PQIs) are covered in IEC 62586-1. Requirements for power quality measurement techniques (functions) are covered in IEC 61000-4-30. Requirements for testing of the power quality measurement functions are covered in IEC 62586-2.

This document does not apply to:

- meters for which the voltage line-to-neutral derived from nominal voltages exceeds 1 000 V;
- meters intended for connection with low power instrument transformers (LPITs as defined in the IEC 61869 series) when tested without such transformers;
- metering systems comprising multiple devices (except LPITs) physically remote from one another;

- portable meters;

NOTE 6 Portable meters are meters that are not permanently connected.

- meters used in rolling stock, vehicles, ships and airplanes;
- laboratory and meter test equipment;
- reference standard meters;
- data interfaces to the register of the meter;
- matching sockets or racks used for installation of electricity metering equipment;
- any additional functions provided in electrical energy meters.

This document does not cover measures for the detection and prevention of fraudulent attempts to compromise a meter's performance (tampering).

NOTE 7 Nevertheless, specific tampering detection and prevention requirements, and test methods, as relevant for a particular market are subject to the agreement between the manufacturer and the purchaser.

NOTE 8 Specifying requirements and test methods for fraud detection and prevention would be counterproductive, as such specifications would provide guidance for potential fraudsters.

NOTE 9 There are many types of meter tampering reported from various markets; therefore, designing meters to detect and prevent all types of tampering could lead to unjustified increase in costs of meter design, verification and validation.

NOTE 10 Billing systems, such as, smart metering systems, are capable of detecting irregular consumption patterns and irregular network losses which enable discovery of suspected meter tampering.

NOTE 11 For transformer operated meters paired with current transformers (CTs) according to IEC 61869-2:

- the standard CT measuring range is specified from $0,05 I_n$ to I_{max} for accuracy classes 0,1, 0,2, 0,5 and 1 and these CTs are used for meters of class 2 and 3 according to this document;
- the special CT measuring range is specified from $0,01 I_n$ to I_{max} for accuracy classes 0,2S and 0,5 S and these CTs are used for meters of class 0,5 S and 1 S according to IEC 62053-24;
- combinations of standard CTs and meters of class 0,5 S and 1 S are subject to an agreement between manufacturers and purchasers.

NOTE 12 This document does not specify emission requirements, these are specified in IEC 62052-11:2020, 9.3.14.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60375:2018, *Conventions concerning electric circuits*

IEC 62052-11:2020, *Electricity metering equipment – General requirements, tests and test conditions – Part 11: Metering equipment*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62052-11:2020 apply.