
**Petroleum products and other
liquids — Guidance for flash point and
combustibility testing**

*Produits pétroliers et autres liquides — Lignes directrices pour les
essais de combustibilité et de point d'éclair*



This document is a preview generated by EKO



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	v
Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Outline of generic definitions and general statements in test methods	2
5 Brief history	2
6 Flash and fire point, and sustained combustion and burning	3
7 Why are flash point and combustibility tests required	3
8 Which test method should be used	4
8.1 First considerations.....	4
8.2 Open or closed cup.....	4
8.3 Non-equilibrium, equilibrium and rapid equilibrium tests.....	4
8.3.1 General.....	4
8.3.2 Non-equilibrium tests.....	5
8.3.3 Equilibrium tests.....	5
8.3.4 Rapid equilibrium tests.....	5
8.4 Flash point automation.....	5
8.4.1 Manual flash point test.....	5
8.4.2 Automated flash point testers.....	5
8.5 Correlation between methods.....	6
8.6 Precision.....	6
8.7 Valid temperature ranges.....	6
9 Testing environment	6
10 Safety	7
11 Calibration and verification	7
11.1 General.....	7
11.2 Calibration.....	7
11.3 Verification.....	8
12 Test samples	8
12.1 Sample handling.....	8
12.2 Samples containing volatile flammable components.....	8
12.3 Viscous and semi-solid samples.....	8
12.4 Biodiesel (B100 FAME- Fatty Acid Methyl Ester).....	9
12.5 Mixtures of materials.....	9
12.6 Samples that form a skin during testing.....	9
13 Instrumentation	9
13.1 Ignition sources.....	9
13.2 Flash detection.....	10
13.3 Stirring.....	10
13.4 Temperature measurement.....	10
13.5 Care of the instrument.....	11
13.6 Sub ambient testing.....	11
14 Flash point testing effects	11
15 Test results	12
15.1 Barometric pressure correction.....	12
15.2 Expression and reporting of results.....	13

Annex A (informative) Major test methods used in specifications and regulations	14
Bibliography	15

This document is a preview generated by EVS

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 28, *Petroleum and related products, fuels and lubricants from natural or synthetic sources*.

This second edition cancels and replaces the first edition (ISO 29662:2009). The main technical changes compared to the previous edition are as follows:

- the title has been changed;
- combustibility test details have been further added;
- a list of examples of regulations have been added;
- test samples, to include biodiesel, mixtures and samples that form a skin during testing have been added;
- the use of low hazard glass thermometers has been added;
- further details regarding the requirements for barometric corrections have been added;
- [Annex A](#) has been added to include temperature ranges for each test method.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document was written to assist laboratory managers and technicians, regulators, specification writers and industry in the use, specification and application of flash point and combustibility tests for liquids and semi-solids.

The flash point test can be summarised as a procedure where a test portion is introduced into a temperature-controlled test cup and an ignition source is applied to the vapours produced by the test portion to determine if the vapour / air mixture is flammable or at what temperature the vapour / air mixture is flammable.

Combustibility tests in this document comprise fire point, sustained combustibility and sustained burning tests. These tests can be summarised as a procedure where a test portion is introduced into a temperature-controlled test cup and an ignition source is applied to the vapours produced by the test portion to determine if the vapour / air mixture catches fire and continues to burn.

This document was developed by the Joint ISO/TC 28 - ISO/TC 35 WG9 on flash point methods.

Petroleum products and other liquids — Guidance for flash point and combustibility testing

1 Scope

This document establishes an overview of test methods in the field to determine flash point and combustibility of petroleum and related products. It presents advice on application and specification development. This document is not intended to be a comprehensive manual on flash point and combustibility tests, and the interpretation of test results, however it covers the key aspects on these subjects.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 1998-1, *Petroleum industry — Terminology — Part 1: Raw materials and products*

ISO 1998-2, *Petroleum industry — Terminology — Part 2: Properties and tests*

3 Terms and definitions

For the purposes of this document, the terms and definitions in ISO 1998-1 and ISO 1998-2 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1

repeatability

r

difference between two test results obtained by the same operator with the same apparatus under constant operating conditions, on identical test material would, in the long run and in the normal operation of the test method, exceed the given value in only one case in 20

Note 1 to entry: The general description deviates from ISO 4259-1 used in many of the standards dealt with in this document.

3.2

reproducibility

R

difference between two single and independent test results obtained by different operators in different laboratories on identical test material that would, in the long run and in the normal operation of the test method, exceed the given value in only one case in 20

Note 1 to entry: The general description deviates from ISO 4259-1 used in many of the standards dealt with in this document.