

Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full - Part 3: Nozzles and Venturi nozzles (ISO 5167-3:2019)

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

| | |
|---|--|
| See Eesti standard EVS-EN ISO 5167-3:2020 sisaldab Euroopa standardi EN ISO 5167-3:2020 ingliskeelset teksti. | This Estonian standard EVS-EN ISO 5167-3:2020 consists of the English text of the European standard EN ISO 5167-3:2020. |
| Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas | This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation. |
| Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 09.09.2020. | Date of Availability of the European standard is 09.09.2020. |
| Standard on kättesaadav Eesti Standardikeskusest. | The standard is available from the Estonian Centre for Standardisation. |

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 17.120.10

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Measurement of fluid flow by means of pressure
differential devices inserted in circular cross-section
conduits running full - Part 3: Nozzles and Venturi nozzles
(ISO 5167-3:2019)

Mesurage du débit des fluides au moyen d'appareils
déprimogènes insérés dans des conduites en charge de
section circulaire - Partie 3: Tuyères et Venturi-tuyères
(ISO 5167-3:2020)

Durchflussmessung von Fluiden mit Drosselgeräten in
voll durchströmten Leitungen mit Kreisquerschnitt -
Teil 3: Düsen und Venturidüsen (ISO 5167-3:2020)

This European Standard was approved by CEN on 24 February 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

This document (EN ISO 5167-3:2020) has been prepared by Technical Committee ISO/TC 30 "Measurement of fluid flow in closed conduits" in collaboration with Technical Committee CEN/SS F05 "Measuring Instruments" the secretariat of which is held by CCMC.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2021, and conflicting national standards shall be withdrawn at the latest by March 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 5167-3:2003.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Endorsement notice

The text of ISO 5167-3:2020 has been approved by CEN as EN ISO 5167-3:2020 without any modification.

Contents

Page

| | |
|---|-----------|
| Foreword | v |
| Introduction | vi |
| 1 Scope | 1 |
| 2 Normative references | 1 |
| 3 Terms and definitions | 2 |
| 4 Principles of the method of measurement and computation | 2 |
| 5 Nozzles and Venturi nozzles | 3 |
| 5.1 ISA 1932 nozzle | 3 |
| 5.1.1 General shape | 3 |
| 5.1.2 Nozzle profile | 3 |
| 5.1.3 Downstream face | 5 |
| 5.1.4 Material and manufacture | 5 |
| 5.1.5 Pressure tapplings | 5 |
| 5.1.6 Coefficients of ISA 1932 nozzles | 7 |
| 5.1.7 Uncertainties | 8 |
| 5.1.8 Pressure loss, Δp | 8 |
| 5.2 Long radius nozzles | 9 |
| 5.2.1 General | 9 |
| 5.2.2 Profile of high-ratio nozzle | 9 |
| 5.2.3 Profile of low-ratio nozzle | 12 |
| 5.2.4 Material and manufacture | 12 |
| 5.2.5 Pressure tapplings | 12 |
| 5.2.6 Coefficients of long radius nozzles | 13 |
| 5.2.7 Uncertainties | 13 |
| 5.2.8 Pressure loss, Δp | 14 |
| 5.3 Throat-tapped nozzles | 14 |
| 5.3.1 General | 14 |
| 5.3.2 Profile of throat-tapped nozzle | 14 |
| 5.3.3 Material and manufacturing | 15 |
| 5.3.4 Pressure Tapplings | 15 |
| 5.3.5 Coefficients | 16 |
| 5.3.6 Uncertainties | 17 |
| 5.3.7 Calibration and extrapolation | 17 |
| 5.3.8 Pressure Loss | 18 |
| 5.4 Venturi nozzles | 18 |
| 5.4.1 General shape | 18 |
| 5.4.2 Material and manufacture | 21 |
| 5.4.3 Pressure tapplings | 21 |
| 5.4.4 Coefficients | 22 |
| 5.4.5 Uncertainties | 23 |
| 5.4.6 Pressure loss | 23 |
| 6 Installation requirements | 24 |
| 6.1 General | 24 |
| 6.2 Minimum upstream and downstream straight lengths for installation between various fittings and the primary device | 24 |
| 6.3 Flow conditioners | 30 |
| 6.4 Circularity and cylindricality of the pipe | 30 |
| 6.5 Location of primary device and carrier rings | 31 |
| 6.6 Method of fixing and gaskets | 32 |
| 7 Flow calibration of nozzles | 32 |
| 7.1 General | 32 |
| 7.2 Test facility | 33 |

| | | |
|--|--|-----------|
| 7.3 | Meter installation..... | 33 |
| 7.4 | Design of the test programme..... | 33 |
| 7.5 | Reporting the calibration results | 33 |
| 7.6 | Uncertainty analysis of the calibration..... | 33 |
| 7.6.1 | General..... | 33 |
| 7.6.2 | Uncertainty of the test facility..... | 33 |
| 7.6.3 | Uncertainty of the nozzle..... | 34 |
| Annex A (informative) Tables of discharge coefficients and expansibility [expansion] factors..... | | 35 |
| Annex B (informative) Akashi type (Mitsubishi type) flow conditioner | | 42 |
| Bibliography | | 43 |

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 30, *Measurement of fluid flow in closed conduits*, Subcommittee SC 2 *Pressure differential devices*.

This second edition cancels and replaces the first edition (ISO 5167-3:2003), which has been technically revised. The main changes compared to the previous edition are as follows:

— Addition of [Subclause 5.3](#).

A list of all parts in the ISO 5167 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

ISO 5167, consisting of six parts, covers the geometry and method of use (installation and operating conditions) of orifice plates, nozzles, Venturi tubes, cone meters and wedge meters when they are inserted in a conduit running full to determine the flowrate of the fluid flowing in the conduit. It also gives necessary information for calculating the flowrate and its associated uncertainty.

ISO 5167 (all parts) is applicable only to pressure differential devices in which the flow remains subsonic throughout the measuring section and where the fluid can be considered as single-phase, but is not applicable to the measurement of pulsating flow. Furthermore, each of these devices can only be used within specified limits of pipe size and Reynolds number.

ISO 5167 (all parts) deals with devices for which direct calibration experiments have been made, sufficient in number, spread and quality to enable coherent systems of application to be based on their results and coefficients to be given with certain predictable limits of uncertainty.

The devices introduced into the pipe are called “primary devices”. The term primary device also includes the pressure tapplings. All other instruments or devices required for the measurement are known as “secondary devices”. ISO 5167 (all parts) covers primary devices; secondary devices¹⁾ will be mentioned only occasionally.

ISO 5167 consists of the following six parts.

- a) ISO 5167-1 gives general terms and definitions, symbols, principles and requirements as well as methods of measurement and uncertainty that are to be used in conjunction with ISO 5167-2, ISO 5167-3, ISO 5167-4, ISO 5167-5 and ISO 5167-6.
- b) ISO 5167-2 specifies orifice plates, which can be used with corner pressure tapplings, D and $D/2$ pressure tapplings²⁾, and flange pressure tapplings.
- c) ISO 5167-3 specifies ISA 1932 nozzles³⁾, long radius nozzles, throat-tapped nozzles and Venturi nozzles, which differ in shape and in the position of the pressure tapplings.
- d) ISO 5167-4 specifies classical Venturi tubes⁴⁾.
- e) ISO 5167-5 specifies cone meters.
- f) ISO 5167-6 specifies wedge meters.

Aspects of safety are not dealt within ISO 5167-1 to ISO 5167-6. It is the responsibility of the user to ensure that the system meets applicable safety regulations.

1) See ISO 2186:2007.

2) Orifice plates with “vena contracta” pressure tapplings are not considered in ISO 5167-2.

3) ISA is the abbreviation for the International Federation of the National Standardizing Associations, which was succeeded by ISO in 1946.

4) In the USA the classical Venturi tube is sometimes called the Herschel Venturi tube.

Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full —

Part 3: Nozzles and Venturi nozzles

1 Scope

This document specifies the geometry and method of use (installation and operating conditions) of nozzles and Venturi nozzles when they are inserted in a conduit running full to determine the flowrate of the fluid flowing in the conduit.

This document also provides background information for calculating the flowrate and is applicable in conjunction with the requirements given in ISO 5167-1.

This document is applicable to nozzles and Venturi nozzles in which the flow remains subsonic throughout the measuring section and where the fluid can be considered as single-phase. In addition, each of the devices can only be used within specified limits of pipe size and Reynolds number. It is not applicable to the measurement of pulsating flow. It does not cover the use of nozzles and Venturi nozzles in pipe sizes less than 50 mm or more than 630 mm, or where the pipe Reynolds numbers are below 10 000.

This document deals with

- a) three types of standard nozzles:
 - 1) ISA 1932⁵⁾ nozzle;
 - 2) the long radius nozzle⁶⁾;
 - 3) the throat-tapped nozzle
- b) the Venturi nozzle.

The three types of standard nozzle are fundamentally different and are described separately in this document. The Venturi nozzle has the same upstream face as the ISA 1932 nozzle, but has a divergent section and, therefore, a different location for the downstream pressure tapings, and is described separately. This design has a lower pressure loss than a similar nozzle. For all of these nozzles and for the Venturi nozzle direct calibration experiments have been made, sufficient in number, spread and quality to enable coherent systems of application to be based on their results and coefficients to be given with certain predictable limits of uncertainty.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

5) ISA is the abbreviation for the International Federation of the National Standardizing Associations, which was superseded by ISO in 1946.

6) The long radius nozzle differs from the ISA 1932 nozzle in shape and in the position of the pressure tapings.

ISO 4006, *Measurement of fluid flow in closed conduits — Vocabulary and symbols*

ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 1: General principles and requirements*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 4006 and ISO 5167-1 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

4 Principles of the method of measurement and computation

The principle of the method of measurement is based on the installation of a nozzle or a Venturi nozzle into a pipeline in which a fluid is running full. The installation of the primary device causes a static pressure difference between the upstream side and the throat. The flowrate can be determined from the measured value of this pressure difference and from the knowledge of the characteristics of the flowing fluid as well as the circumstances under which the device is being used. It is assumed that the device is geometrically similar to one on which calibration has been carried out and that the conditions of use are the same, i.e. that it is in accordance with this document.

The mass flowrate can be determined by [Formula \(1\)](#):

$$q_m = \frac{C}{\sqrt{1-\beta^4}} \varepsilon \frac{\pi}{4} d^2 \sqrt{2\Delta p \rho_1} \quad (1)$$

The uncertainty limits can be calculated using the procedure given in ISO 5167-1:2003, Clause 8.

Similarly, the value of the volume flowrate can be calculated since

$$q_V = \frac{q_m}{\rho} \quad (2)$$

where

ρ is the fluid density at the temperature and pressure for which the volume is stated;

q_V is the volume flowrate.

Computation of the flowrate, which is a purely arithmetic process, is performed by replacing the different items on the right-hand side of [Formula \(1\)](#) by their numerical values. [Tables A.1 to A.5](#) are given for convenience. [Tables A.1, A.2 and A.4](#) give the values of C as a function of β . [Table A.3](#) gives the values of C as a function of Re_d . [Table A.5](#) gives expansibility (expansion) factors ε . They are not intended for precise interpolation. Extrapolation is not permitted.

The coefficient of discharge C may be dependent on Re_D or Re_d which is itself dependent on q_m and has to be obtained by iteration. (See ISO 5167-1 for guidance regarding the choice of the iteration procedure and initial estimates.)

The diameters d and D mentioned in [Formula \(1\)](#) are the values of the diameters at working conditions. Measurements taken at any other conditions should be corrected for any possible expansion or contraction of the primary device and the pipe due to the values of the temperature and pressure of the fluid during the measurement.