
**Condition monitoring and diagnostics
of wind turbines —**

**Part 2:
Monitoring the drivetrain**

*Surveillance et diagnostic des éoliennes de production d'électricité —
Partie 2: Surveillance de la transmission*



This document is a preview generated by EKO



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	v
Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Abbreviated terms	2
5 Failure mode and symptoms analysis (FMSA)	2
5.1 General	2
5.2 The process of the FMSA analysis	2
6 Descriptors for fault detection	3
6.1 General	3
6.2 Descriptor types	4
6.3 Descriptors based on process parameters — Operational values	5
6.3.1 General	5
6.3.2 Measurement of process parameter descriptors	6
6.4 Measurement of rotational speed and descriptors based on rotational speed	6
6.4.1 General	6
6.4.2 Measurement of rotational speed	7
6.5 Descriptors based on vibration	7
6.5.1 References to other standards	7
6.5.2 General	7
6.5.3 Measurement of vibration	8
6.5.4 Transducers for vibration measurements	8
6.5.5 Vibration transducer mounting	9
6.6 Descriptors based on stress wave measurements	10
6.6.1 General	10
6.6.2 Measurement of stress waves	10
6.6.3 Transducers for stress wave measurement	11
6.6.4 Mounting of stress wave sensors	11
6.7 Descriptors based on oil debris in lubricant oil	11
6.7.1 General	11
6.7.2 Oil debris descriptors	12
6.7.3 Oil debris sensors	12
7 Descriptor monitoring interval	13
7.1 Reference to other standards	13
7.2 Factors influencing the monitoring interval	13
8 Descriptor notification criteria	14
8.1 Reference to other standards	14
8.2 General	14
8.3 Establishing descriptor alarm and alert limits for a new turbine	15
8.4 Establishing alarm and alert limits for a turbine in normal operating condition	15
8.5 Establishing alert limits upon component change	15
9 Handling changes in operating conditions — The operational state bin concept	16
9.1 General	16
9.2 Example of how to use active power as an operational state	16
10 Transducer locations	17
10.1 Reference to other standards and guidelines	17
10.2 Location of vibration transducers	17
10.3 Location of stress wave transducers	19
10.4 Location of oil debris sensors	19

10.5	Example of naming conventions and transducer locations.....	19
11	Baseline — Initial recording of data for diagnosis at commissioning time	20
11.1	General.....	20
11.2	Duration of time waveforms for baseline recording.....	20
11.3	Repeatability and stability of time waveform recordings.....	21
11.4	Sampling rate of time waveform for baseline recording.....	21
11.5	Initial check of the baseline data — Recommendations.....	21
12	Diagnosis of faults and their causes	22
12.1	Reference to other standards.....	22
12.2	General.....	22
12.3	Component data.....	22
12.4	Raw-data time waveforms for detailed diagnosis.....	22
12.5	Regular recording.....	22
12.6	Recording on request.....	23
13	Prognosis.....	23
13.1	Reference to other standards.....	23
13.2	General.....	23
13.3	Type I — Failure data-based prognostics — Statistically based.....	24
13.4	Type II — Stress based prognostics — Model based.....	25
13.5	Type III — Data-driven method — Condition based.....	25
14	Review of the condition monitoring and diagnosis system design.....	25
14.1	Reference to other standards.....	25
14.2	General.....	26
14.3	Assessment of effectiveness of the condition monitoring system.....	26
14.4	Cost benefit analysis.....	27
14.4.1	General.....	27
14.4.2	Simple model.....	27
14.4.3	Advanced model.....	28
Annex A (informative)	Details on vibration-based descriptor types.....	31
Annex B (informative)	FMSA analysis of the drivetrain.....	40
Bibliography		43

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 108, *Mechanical vibration, shock and condition monitoring*, Subcommittee SC 5, *Condition monitoring and diagnostics of machine systems*.

A list of all parts in the ISO 16079 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document is the second step of the procedure for carrying out the CM and D application design phase according to the V-model of ISO 13379-1. In this step, the monitoring strategy for the drivetrain is defined, based upon the prioritized failure modes which were the outcome of the failure modes, effect and criticality analysis (FMECA) procedure performed according to ISO 16079-1 (see [Figure 1](#)).

According to the V-Model of ISO 13379-1 and ISO 16079-1, the steps described in this document are as follows:

- a) decide under which operating conditions the different faults can be best observed and specify the conditions under which the symptom is most likely to be observed;
- b) identify the symptoms that can serve in assessing the condition of the machine, and that are used for diagnostics;
- c) list the descriptors that are used to evaluate (recognize) the different symptoms;
- d) identify the necessary measurements and transducers from which the descriptors are derived or computed.




Figure 1 — The relationship between this document and ISO 16079-1

In relation to the V-model, this document describes the two last steps of the application design phase of the condition monitoring system. This process shall ensure that data are available to support an

efficient process in the use phase of the condition monitoring system. The end goal of the “Use phase process” is minimizing wind turbine downtime through a risk assessment of a detected fault by means of remaining useful life (RUL) evaluation, and successive determination of maintenance timing. The criticality and risk assessment uses information from the FMECA analysis, but may also feed information back into an adjustment of the initial FMECA analysis (see [Figure 2](#)).




Figure 2 — Condition monitoring and diagnostics (CM and D) cycle: Design phase and use phase of the application on a machine

This document shows how to apply the results of an FMECA analysis made according to ISO 16079-1 by prescribing a methodology for making a failure mode symptoms analysis (FMSA) with the purpose of defining symptoms and related descriptors to detect a particular failure mode.

In order to implement the results of the FMSA, sections with guidelines for condition monitoring of wind turbines are provided, covering:

- 1) guidelines for descriptor measurements;
- 2) adapting to changes in operating conditions;
- 3) selection of transducers and transducer technology;
- 4) selection of transducer locations;
- 5) naming convention for identifying transducer locations and related descriptors;
- 6) evaluation criteria for descriptor measurements;
- 7) requirements to data for diagnosis;
- 8) prognosis and/or criticality assessment; and
- 9) review of the CM & D design:
 - a) assessment of effectiveness of the diagnostics system, and
 - b) cost benefit analysis.

[Figure 3](#) shows the relationship between the monitoring strategy, diagnostic strategy and maintenance strategy and how these important elements support the steps in the condition monitoring process. If the monitoring strategy, the diagnostic strategy, or both are based upon weak or missing data, it compromises the prognosis and the whole purpose of the condition monitoring process.




Figure 3 — Relationship between monitoring methods, diagnostic methods and prognosis methods

The selection of the monitoring method is to define where you measure, what you measure and how often you measure in order to provide data for:

- detecting the failure modes designated to be revealed by the condition monitoring system;
- assessing the severity of the present state of the fault;
- assessing the remaining useful lifetime of a certain component.

A weak point in the condition monitoring system setup (e.g. lack of transducers or bad transducer location, limitations in what can be measured, or too sparse data) affects the end goal of the condition monitoring process – the prognosis.

The choice of the diagnostic method is to provide enough data for:

- detailed analysis of a failure mode and identification of the root-cause;
- assessing the severity of the present state of the fault;
- assessing the remaining useful lifetime of a certain component.

The purpose of the prognosis is to make a prediction of remaining useful lifetime (RUL) of a component and assess the risk for related failure modes (secondary failure).

The maintenance action is based upon the data provided by the monitoring methods, the diagnostic methods and the prognosis methods, and on knowledge of maintenance history and alarm history. Therefore, it is very important that not only measured data are stored, but also information about earlier alarms, maintenance actions and identification of persons which have been involved with earlier alarm handling on the machine.

Condition monitoring and diagnostics of wind turbines —

Part 2: Monitoring the drivetrain

1 Scope

This document specifies the implementation of a condition monitoring system for wind turbines, with particular focus on monitoring of the drivetrain. Guidance for a practical implementation of the FMSA is provided, as well as guidance for specifying best practices and minimum recommendations regarding the condition monitoring system used for failure mode detection, diagnostics and prognostics of the direct drive and geared wind turbine drivetrain, including:

- a) main bearing(s);
- b) gearbox, if applicable; and
- c) generator (mechanical aspects).

This also includes subcomponents such as coupling and the lubrication system.

This document provides an overview of the important aspects of condition monitoring of wind turbines and makes references to other standards where in-depth information on the subjects is available.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 2041, *Mechanical vibration, shock and condition monitoring — Vocabulary*

ISO 13372, *Condition monitoring and diagnostics of machines — Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 2041 and ISO 13372 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1

time waveform

sampled vibration signal recorded from the transducer

Note 1 to entry: Time waveform recordings have a certain length in time and represent a parameter value at every instance during the recording of the time waveform.