

Acoustics - Laboratory and field measurement of the flanking transmission for airborne, impact and building service equipment sound between adjoining rooms - Part 5: Radiation efficiencies of building elements (ISO 10848-5:2020)

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN ISO 10848-5:2020 sisaldab Euroopa standardi EN ISO 10848-5:2020 ingliskeelset teksti.	This Estonian standard EVS-EN ISO 10848-5:2020 consists of the English text of the European standard EN ISO 10848-5:2020.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 07.10.2020.	Date of Availability of the European standard is 07.10.2020.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 91.120.20

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:  
Koduleht [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage [www.evs.ee](http://www.evs.ee); phone +372 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

English Version

Acoustics - Laboratory and field measurement of the  
flanking transmission for airborne, impact and building  
service equipment sound between adjoining rooms - Part  
5: Radiation efficiencies of building elements (ISO 10848-  
5:2020)

Acoustique - Mesurage en laboratoire et sur site des  
transmissions latérales du bruit aérien, des bruits de  
choc et du bruit d'équipement technique de bâtiment  
entre des pièces adjacentes - Partie 5: Efficacité de  
rayonnement des éléments de construction (ISO  
10848-5:2020)

Akustik - Messung der Flankenübertragung von  
Luftschall und Trittschall zwischen benachbarten  
Räumen im Prüfstand - Teil 5: Strahlungswirksamkeit  
von Bauelementen (ISO 10848-5:2020)

This European Standard was approved by CEN on 2 October 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

## European foreword

This document (EN ISO 10848-5:2020) has been prepared by Technical Committee ISO/TC 43 "Acoustics" in collaboration with Technical Committee CEN/TC 126 "Acoustic properties of building elements and of buildings" the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2021, and conflicting national standards shall be withdrawn at the latest by April 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## Endorsement notice

The text of ISO 10848-5:2020 has been approved by CEN as EN ISO 10848-5:2020 without any modification.

# Contents

Page

<b>Foreword</b>	<b>iv</b>
<b>Introduction</b>	<b>v</b>
<b>1 Scope</b>	<b>1</b>
<b>2 Normative references</b>	<b>1</b>
<b>3 Terms and definitions</b>	<b>1</b>
<b>4 Instrumentation</b>	<b>4</b>
<b>5 Test arrangement</b>	<b>4</b>
<b>6 Measurement methods</b>	<b>4</b>
6.1 General	4
6.2 Measurement of $L_{\sigma,a}$	5
6.2.1 Generation of sound field in the source room	5
6.2.2 Measurement of the average sound pressure level in the receiving room	5
6.2.3 Measurement of reverberation time of the room and evaluation of the equivalent sound absorption area	5
6.2.4 Measurement of the average velocity level of the element	5
6.2.5 Calculation of the radiation index	5
6.3 Measurement of $L_{\sigma,s}$	5
6.3.1 Generation of vibration on the source element	5
6.3.2 Procedure for Type A and Type B elements	5
6.3.3 Measurement using stationary excitation	6
6.3.4 Measurement using transient excitation	6
6.3.5 Measurement of reverberation time and evaluation of the equivalent sound absorption area	6
6.3.6 Radiation index calculation	6
<b>7 Precision</b>	<b>6</b>
<b>8 Expression of results</b>	<b>6</b>
<b>9 Test report</b>	<b>7</b>
<b>Annex A (informative) Measurement of radiation efficiency using sound intensity</b>	<b>8</b>
<b>Bibliography</b>	<b>10</b>

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 126, *Acoustic properties of building elements and of buildings*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

A list of all parts in the ISO 10848 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at [www.iso.org/members.html](http://www.iso.org/members.html).

## Introduction

ISO 10848 (all parts) specifies laboratory and field measurement methods to characterize the flanking transmission of one or several building components.

This document describes the measurement of the radiation efficiency of an element using structure-borne excitation and/or acoustical excitation. Both these radiation efficiencies are required to estimate the sound reduction index due to resonant transmission only, according to ISO 12354-1:2017, Annex B.

For Type B elements as defined in ISO 10848-1 and ISO 12354-1, the radiation efficiency of an element using structure-borne excitation is required to calculate flanking transmission. It is also required to estimate adaptation terms used in predicting service equipment sound according to EN 12354-5.

# Acoustics — Laboratory and field measurement of the flanking transmission for airborne, impact and building service equipment sound between adjoining rooms —

## Part 5: Radiation efficiencies of building elements

### 1 Scope

This document specifies measurement methods to characterize in the laboratory the acoustic radiation of a building element when it is directly excited by an airborne or structure-borne source. It is applicable to single-leaf and double-leaf elements (see ISO 12354-1:2017 Annex F, F2). The measured quantity can be used as input data for prediction methods, such as ISO 12354-1 and ISO 12354-2, to compare products, or to express a requirement.

### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 10140-5, *Acoustics — Laboratory measurement of sound insulation of building elements — Part 5: Requirements for test facilities and equipment*

ISO 10848-1:2017, *Acoustics — Laboratory and field measurement of flanking transmission for airborne, impact and building service equipment sound between adjoining rooms — Part 1: Frame document*

ISO 12999-1, *Acoustics — Determination and application of measurement uncertainties in building acoustics — Part 1: Sound insulation*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

#### 3.1

##### average velocity level

$L_v$

ten times the common logarithm of the ratio of the time and space averaged mean-square normal velocity of an element to the squared reference velocity, for which the time averaged velocity at position  $i$  is determined as follows:

$$v_i = \frac{1}{T_m} \int_0^{T_m} v_i^2(t) dt$$