

KÜLMUTUSSÜSTEEMID JA SOOJUSPUMBAD. OHUTUS-
JA KESKKONNANÕUDED. OSA 1: PÕHINÕUDED,
MÄÄRATLUSED, KLASSIFIKATSIOON JA
VALIKUKRITEERIUMID

Refrigerating systems and heat pumps - Safety and
environmental requirements - Part 1: Basic
requirements, definitions, classification and selection
criteria

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 378-1:2016+A1:2021 sisaldab Euroopa standardi EN 378-1:2016+A1:2020 ingliskeelset teksti.	This Estonian standard EVS-EN 378-1:2016+A1:2021 consists of the English text of the European standard EN 378-1:2016+A1:2020.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 28.10.2020.	Date of Availability of the European standard is 28.10.2020.
Standard on kättesaadav Eesti Standardimis-ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 01.040.27, 27.080, 27.200

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD

EN 378-1:2016+A1

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2020

ICS 01.040.27; 27.080; 27.200

Supersedes EN 378-1:2016

English Version

Refrigerating systems and heat pumps - Safety and environmental requirements - Part 1: Basic requirements, definitions, classification and selection criteria

Systèmes frigorifiques et pompes à chaleur - Exigences de sécurité et d'environnement - Partie 1 : Exigences de base, définitions, classification et critères de choix

Kälteanlagen und Wärmepumpen - Sicherheitstechnische und umweltrelevante Anforderungen - Teil 1: Grundlegende Anforderungen, Begriffe, Klassifikationen und Auswahlkriterien

This European Standard was approved by CEN on 3 September 2016 and includes Amendment 1 approved by CEN on 17 August 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	4
Introduction	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
3.1 Refrigerating systems	8
3.2 Occupancies, locations	10
3.3 Pressures	11
3.4 Components of refrigerating systems	12
3.5 Piping and joints	14
3.6 Safety accessories	15
3.7 Fluids	17
3.8 Miscellaneous	20
4 Symbols and abbreviated terms	20
5 Classification	22
5.1 Access categories	22
5.1.1 General	22
5.1.2 More than one access category	23
5.2 Designation and classification of refrigerants	23
5.3 Location classification of refrigerating systems	23
5.4 Refrigerating system classification	24
5.4.1 General	24
5.4.2 Direct releasable systems	24
5.4.3 Indirect systems	24
5.5 Examples of systems	24
5.5.1 Direct releasable systems	24
5.5.2 Indirect systems	26
5.6 Special requirements for ice rinks	29
6 Quantity of refrigerant	29
7 Space volume calculations	29
Annex A (informative) Equivalent terms in English, French and German	31
Annex B (informative) Total equivalent warming impact (TEWI)	36
Annex C (normative) Refrigerant charge limit requirements	39
C.1 Charge limits requirements for refrigerating systems	39
C.2 Charge limitations due to flammability for air conditioning systems or heat pumps for human comfort	48
C.2.1 Refrigerant-containing parts in a occupied space	48
C.2.2 Special requirements for non fixed factory sealed single package air conditioning systems or heat pumps with a limited charge	48
C.3 Alternative for risk management of refrigerating systems in occupied spaces	49
C.3.1 General	49
C.3.2 Allowable charge	50

Annex D (informative) Protection for people who are inside cold rooms.....	53
D.1 General	53
D.2 Operation of doors and emergency exit doors.....	53
D.3 Emergency switch or signal	53
D.4 Cold rooms with a controlled atmosphere	54
Annex E (normative) Safety classification and information about refrigerants.....	55
Annex F (normative) Special requirements for ice rinks.....	71
F.1 Indoor ice rinks.....	71
F.2 Outdoor ice rinks and installations for similar sporting activities.....	71
Annex G (informative) Potential hazards for refrigerating systems.....	72
Annex H (informative) Calculation examples related to C.2 and C.3.....	74
H.1 Example 1 for C.2.1.....	74
H.2 Example 2 for C.2.1.....	74
H.3 Example 3 for C.3	74
H.4 Example 4 for C.3	74
Bibliography	76

European foreword

This document (EN 378-1:2016+A1:2020) has been prepared by Technical Committee CEN/TC 182 “Refrigerating systems, safety and environmental requirements”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2021, and conflicting national standards shall be withdrawn at the latest by April 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1 approved by CEN on 17 August 2020.

This document supersedes A1 EN 378-1:2016 A1.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

EN 378 consists of the following parts under the general title “Refrigerating systems and heat pumps — Safety and environmental requirements”:

- *Part 1: Basic requirements, definitions, classification and selection criteria;*
- *Part 2: Design, construction, testing, marking and documentation;*
- *Part 3: Installation site and personal protection;*
- *Part 4: Operation, maintenance, repair and recovery.*

The main changes in part 1 with respect to the previous edition are listed below:

- harmonization as far as possible with ISO 5149:2014 and ISO 817:2014;
- adapt definitions for the purpose of harmonizing EN 378-2:2016 with PED.

Following detailed changes are worth noting:

- modification of the term “special machinery room” to “separate refrigeration machinery room” and adapt the definition in view of combustion equipment;
- modifications/inclusion of definitions for “part of the refrigerating system” (3.1.8), “pressure equipment” (3.1.20) and “pressure vessels” (3.4.8) in view of PED;
- movement of the location classification from Annex C to 5.3;
- rewording of the system examples in 5.3 to make the relation clear with location classification;
- replacement of Annex F (safety group) classifications by 5.2;
- modification of the approach to determine the refrigerant charge of a refrigeration system. The charge limit requirement is decided based on the most stringent refrigerant charge that results from the calculation based on toxicity and the calculation based on flammability. To this purpose,

the tables in Annex C are modified. Table C.1 contains requirements based on toxicity classes, Table C.2 contains requirements based on flammability classes;

- addition of the refrigerant classes as determined in ISO 817 to toxicity classes A, B and flammability classes 1, 2L, 2, 3;
- modification of the charge limits for refrigerants of flammability class 3, for location classification III;
- addition of C.3, alternative risk management;
- addition of refrigerants in Annex E that have been approved for publication in ASHRAE 34 in January 2015 (not those approved for public review in January 2015);
- inclusion in Annex E of GWP values for refrigerants in view of REGULATION (EU) No 517/2014 (F-gas).

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

This European Standard relates to safety and environmental requirements in the design, manufacture, construction, installation, operation, maintenance, repair and disposal of refrigerating systems and appliances regarding local and global environments. It does not related to the final destruction of the refrigerants.

It is intended to minimize possible hazards to persons, property and the environment from refrigerating systems and refrigerants. These hazards are associated with the physical and chemical characteristics of refrigerants and the pressures and temperatures occurring in refrigeration cycles.

Attention is drawn to hazards such as excessive temperature at compressor discharge, liquid slugging, erroneous operation and reduction in mechanical strength caused by corrosion, erosion, thermal stress, liquid hammer or vibration. Corrosion deserves special consideration as conditions peculiar to refrigerating systems arise due to alternate frosting and defrosting or the covering of equipment by insulation.

The extent to which hazards are covered is indicated in Annex G. In addition, machinery should comply as appropriate with EN ISO 12100 for hazards which are not covered by this European Standard.

Commonly used refrigerants except R-717 are heavier than air. Care should be taken to avoid stagnant pockets of heavy refrigerant vapours by proper location of ventilation inlet and exhaust openings. Refrigerants and their combinations with oils, water or other substances, can affect the system chemically and physically. They can, if they have detrimental properties, endanger persons, property and the environment when escaping from the refrigerating system. Refrigerants shall be selected with due regard to their potential influence on the global environment (ODP, GWP) as well as their possible effects on the local environment. Evaluation of the environmental performance requires a life cycle approach. With regard to global climate change the **Total Equivalent Warming Impact** approach is generally used as the basis (see Annex B). Reference should be made to the EN ISO 14040- series to address other environmental aspects. Many factors influence environmental impacts such as:

- location of the system;
- energy efficiency of the system;
- type of refrigerant;
- service frequency;
- refrigerant leaks;
- sensitivity of charge on efficiency;
- minimization of heat load;
- control methods.

Additional investments may be directed towards reducing leaks, increasing energy efficiency or modifying the design in order to use a different refrigerant. A life cycle approach is necessary to identify where additional investments will have the most beneficial effects.

1 Scope

This European Standard specifies the requirements for the safety of persons and property, provides guidance for the protection of the environment and establishes procedures for the operation, maintenance and repair of refrigerating systems and the recovery of refrigerants.

The term “refrigerating system” used in this European Standard includes heat pumps.

This part of EN 378 specifies the classification and selection criteria applicable to refrigerating systems. These classification and selection criteria are used in parts 2, 3 and 4.

This standard applies:

- a) to refrigerating systems, stationary or mobile, of all sizes except to vehicle air conditioning systems covered by a specific product standard e.g. ISO 13043;
- b) to secondary cooling or heating systems;
- c) to the location of the refrigerating systems;
- d) to replaced parts and added components after adoption of this standard if they are not identical in function and in the capacity;

Systems using refrigerants other than those listed in Annex E of this European Standard are not covered by this standard.

Annex C specifies how to determine the amount of refrigerant permitted in a given space, which when exceeded, requires additional protective measures to reduce the risk.

Annex E specifies criteria for safety and environmental considerations of different refrigerants used in refrigeration and air conditioning.

This standard is not applicable to refrigerating systems and heat pumps which were manufactured before the date of its publication as a European Standard except for extensions and modifications to the system which were implemented after publication.

This standard is applicable to new refrigerating systems, extensions or modifications of already existing systems, and for existing stationary systems, being transferred to and operated on another site.

This standard also applies in the case of the conversion of a system to another refrigerant type, in which case conformity to the relevant clauses of parts 1 to 4 of the standard shall be assessed.

Product family standards dealing with the safety of refrigerating systems takes precedence over horizontal and generic standards covering the same subject.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 378-2:2016, *Refrigerating systems and heat pumps — Safety and environmental requirements — Part 2: Design, construction, testing, marking and documentation*

EN 378-3:2016+A1:2020, *Refrigerating systems and heat pumps - Safety and environmental requirements - Part 3: Installation site and personal protection* A1

EN 12263, *Refrigerating systems and heat pumps — Safety switching devices for limiting the pressure — Requirements and tests*

EN 14276-2, *Pressure equipment for refrigerating systems and heat pumps — Part 2: Piping — General requirements*

ISO 817:2014, *Refrigerants — Designation and safety classification*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

NOTE See informative Annex A for equivalent terms in English, French and German.

3.1 Refrigerating systems

3.1.1

refrigerating system

heat pump

combination of interconnected refrigerant-containing parts constituting one closed circuit in which the refrigerant is circulated for the purpose of extracting and delivering heat (i.e. cooling and heating)

3.1.2

self-contained system

complete factory-made refrigerating system in a suitable frame and/or enclosure, that is fabricated and transported complete, or in two or more sections and in which no refrigerant-containing parts are connected on site other than by isolation valves, such as companion valves

3.1.3

unit system

self-contained system that has been assembled, filled ready for use and tested prior to its installation and is installed without the need for connecting any refrigerant-containing parts

Note 1 to entry: A unit system can include factory assembled companion valves.

3.1.4

limit charged system

refrigerating system in which the internal volume and total refrigerant charge are such that, with the system idle, the allowable pressure will not be exceeded when complete evaporation of the refrigerant occurs

3.1.5

sorption system

refrigerating system in which refrigeration is effected by evaporation of a refrigerant, the vapour then being absorbed or adsorbed by an absorbent or adsorbent medium respectively, from which it is subsequently expelled at a higher partial vapour pressure by heating and then liquefied by cooling

3.1.6

secondary cooling or heating system

system employing a fluid which transfers heat from the product or spaces to be cooled or heated or from another cooling or heating system to the refrigerating system without compression and expansion of the fluid