

Railway applications - Fixed Installations - Electrical protective measures for working on or near an overhead contact line system and/or its associated return circuit

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN 50488:2021 sisaldab Euroopa standardi EN 50488:2021 ingliskeelset teksti.	This Estonian standard EVS-EN 50488:2021 consists of the English text of the European standard EN 50488:2021.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 29.01.2021.	Date of Availability of the European standard is 29.01.2021.
Standard on kättesaadav Eesti Standardimis-ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 13.260, 45.020

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele. Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation:

Homepage [www.evs.ee](http://www.evs.ee); phone +372 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

English Version

## Railway applications - Fixed installations - Electrical protective measures for working on or near an overhead contact line system and/or its associated return circuit

Applications ferroviaires - Installations fixes - Mesures de protection électriques pour des activités de travail sur ou à proximité des systèmes de lignes aériennes de contact et/ou le circuit de retour associé

Bahnanwendungen - Ortsfeste Anlagen - Elektrische Schutzmaßnahmen bei Arbeiten an oder in der Nähe einer Oberleitungsanlage und/oder ihrer zugehörigen Rückleitung

This European Standard was approved by CENELEC on 2020-06-29. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

## Contents

Page

<b>European foreword</b> .....	<b>4</b>
<b>Introduction</b> .....	<b>5</b>
<b>1 Scope</b> .....	<b>6</b>
<b>2 Normative references</b> .....	<b>6</b>
<b>3 Terms, definitions, symbols and abbreviated terms</b> .....	<b>6</b>
3.1 Terms and definitions .....	6
3.2 Symbols.....	14
3.3 Abbreviated terms .....	15
<b>4 Basic principles</b> .....	<b>15</b>
4.1 Electrical safety for work activity .....	15
4.2 Personnel .....	16
4.3 Organization .....	17
4.4 Communication .....	18
4.5 Work location.....	18
4.6 Tools, equipment and devices.....	19
4.7 Documentation for safe working.....	19
4.8 Signs.....	19
4.9 Emergency arrangements during work activity .....	20
<b>5 Protective measures for work activities on or near overhead contact line system</b> .....	<b>20</b>
5.1 General.....	20
5.2 Dead working .....	20
5.3 Working near to hazardous live parts.....	23
5.4 Live working.....	26
5.5 Electromagnetic influences .....	27
5.6 Environmental conditions .....	27
<b>6 Working procedures for work activities on or near return circuit</b> .....	<b>27</b>
6.1 General.....	27
6.2 Working on or near parts of return circuit without electrical shock hazards in normal operating condition .....	27
6.3 Working on or near parts of return circuit with electrical shock hazards in normal operating condition .....	28
<b>7 Recommended distances in air for work activities</b> .....	<b>29</b>
<b>Annex A (informative) Method of calculation of the distances in air for working procedures</b> ...	<b>30</b>
<b>A.1 Calculation of the outer limit of the danger zone <math>D_R</math></b> .....	<b>30</b>
<b>A.2 Determination of approach distances <math>D_L</math> and <math>D_A</math></b> .....	<b>30</b>
<b>A.3 Determination of <math>D_V</math></b> .....	<b>31</b>
<b>A.4 Distances overview</b> .....	<b>31</b>
<b>Annex B (informative) Examples of physical measures to limit the movement of workers</b> .....	<b>33</b>
<b>B.1 General</b> .....	<b>33</b>
<b>B.2 Distances between physical measure and hazardous-live-part when working zone encroaches <math>D_V</math></b> .....	<b>34</b>

**B.3 Distances between physical measure and hazardous-live-part when working zone does not encroach  $D_v$  .....35**

**Annex C (informative) Illustration of selection process of the protective measures.....37**

**Bibliography.....38**

This document is a preview generated by EVS

## European foreword

This document (EN 50488:2021) has been prepared by CLC/SC 9XC “Electric supply and earthing systems for public transport equipment and ancillary apparatus (Fixed installations)”, of Technical Committee CLC/TC 9X, “Electrical and electronic applications for railways”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2021-07-29
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2026-01-29

This document supersedes CLC/TR 50488:2006 and all of its amendments and corrigenda (if any).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Document preview generated by EVS

## Introduction

This document provides railway specific requirements for electrical protective measures for working on or near an overhead contact line system and/or its associated return circuit.

When developing this document, EN 50110-1, *Operation of electrical installations – Part 1: General requirements*, was used as a guide. EN 50110-1 was not developed specifically to apply to the electric traction system which have different characteristics than those commonly found in other electrical installations.

Due to the numerous variations of organization, this document does not give any recommendations concerning organisational structure.

Because of numerous variations in overhead contact lines with nominal voltage lower than 1,5 kV, this document does not deal with work activities on or near these overhead contact lines and/or their associated return circuit.

The trend in Europe is that “dead working” is more common than “live working”. In the countries where live working on the overhead contact lines is allowed, the national regulation should state the necessary safety rules.

## 1 Scope

This document provides requirements for electrical safety for:

- dead working on an overhead contact line system;
- working activities near an overhead contact line system when it is live.

It applies to all work activities in relation to electrical hazards only.

This document is applicable to overhead contact line systems with the following nominal voltages and configurations:

- 1,5 kV and 3 kV DC;
- 15 kV, 2x15 kV, 25 kV and 2x25 kV AC.

It also provides requirements for work activities that can give rise to electrical hazards from the return circuit.

This document does not cover electrical risk arising from:

- live working on overhead contact line systems (live working can be carried out according to national requirements, regulations and practices);
- working on or near other electrical sources or electrical systems connected to or close to the OCL system and its return circuit.

If there are no other rules or procedures, the principles described in this document can be applied to overhead contact line systems with other nominal voltages.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50122-1:2011, *Railway applications - Fixed installations - Electrical safety, earthing and the return circuit - Part 1: Protective provisions against electric shock*

## 3 Terms, definitions, symbols and abbreviated terms

### 3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

#### 3.1.1 General

##### 3.1.1.1

##### **charged**

qualifies an entity having non-zero electric charge

[SOURCE: IEC 60050-113:2011, 113-06-26]