And Socura

AKUSTIKA. HOONETE JA EHITUSELEMENTIDE HELIISOLATSIOONI HINDAMINE. OSA 2: LÖÖGIHELI ISOLATSIOON

Acoustics - Rating of sound insulation in buildings and of building elements - Part 2: Impact sound insulation (ISO 717-2:2020)



EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN ISO 717-2:2021 sisaldab Euroopa standardi EN ISO 717-2:2020 ingliskeelset teksti.	This Estonian standard EVS-EN ISO 717-2:2021 consists of the English text of the European standard EN ISO 717-2:2020.			
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas. Euroopa standardimisorganisatsioonid on teinud	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.			
Euroopa standardi rahvuslikele liikmetele kättesaadavaks 16.12.2020.	Date of Availability of the European standard is 16.12.2020.			
Standard on kättesaadav Eesti Standardimis-ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.			
Fagasisidet standardi sisu kohta on võimalik edastad	da, kasutades EVS-i veebilehel asuvat tagasiside vo			

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 91.120.20

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis-ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis-ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD NORME EUROPÉENNE **EUROPÄISCHE NORM**

EN ISO 717-2

December 2020

ICS 91.120.20

Supersedes EN ISO 717-2:2013

English Version

Acoustics - Rating of sound insulation in buildings and of building elements - Part 2: Impact sound insulation (ISO 717-2:2020)

Acoustique - Évaluation de l'isolement acoustique des immeubles et des éléments de construction - Partie 2: Protection contre le bruit de choc (ISO 717-2:2020)

Akustik - Bewertung der Schalldämmung in Gebäuden und von Bauteilen - Teil 2: Trittschalldämmung (ISO 717-2:2020)

This European Standard was approved by CEN on 12 December 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

This document (EN ISO 717-2:2020) has been prepared by Technical Committee ISO/TC 43 "Acoustics" in collaboration with Technical Committee CEN/TC 126 "Acoustic properties of building elements and of buildings" the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2021, and conflicting national standards shall be withdrawn at the latest by June 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 717-2:2013.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Endorsement notice

The text of ISO 717-2:2020 has been approved by CEN as EN ISO 717-2:2020 without any modification.

Contents

Forew	ord		iv
Introd	uctio	n	v
1	Scop	ре	1
2	Norn	native references	1
3	Tern	ns and definitions	2
4	Proc 4.1 4.2 4.3	edure for evaluating single-number quantities for impact sound insulation rating General Reference values Method of comparison 4.3.1 Measurements in one-third-octave bands	3 4 4 4
	4.4 4.5	4.3.2 Measurements in octave bands Statement of results Impact sound insulation measured with heavy and soft impact sources	5 5 6
5	Proc floor 5.1 5.2 5.3 5.4	redure for evaluating the weighted reduction in impact sound pressure level by coverings on bare heavy floors General Reference floor Calculation Statement of results	7 7 7 8
6 Anney	Proc floor 6.1 6.2 6.3 6.4	The second pressure level by the second pres	9 9 9 9
Annex	B (in	formative) Procedure for evaluating the equivalent weighted normalized	14
Annov	impa	formative) Examples of the evaluation of a single number quantity	14
Annex	D (no	ormative) Rating method for impact sound insulation measured with a heavy	20
Rihlio	orant	w	20

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 43, *Acoustics*, Subcommittee SC 2, *Building acoustics*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 126, *Acoustic properties of building elements and of buildings*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This fourth edition cancels and replaces the third edition (ISO 717-2:2013), which has been technically revised.

The main changes compared to the previous edition are as follows:

 A new <u>Annex D</u> with a method for rating heavy/soft impact sound insulation using an A-weighted maximum impact sound pressure level.

A list of all parts in the ISO 717 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at <u>www.iso.org/members.html</u>.

62 TTZ-'S

Introduction

Methods of measurement of impact sound insulation in buildings and of building elements have sed i th are i requerely acterizing the been standardized in ISO 10140-3 and ISO 16283-2. These methods give values for the impact sound insulation which are frequency dependent. The purpose of this document is to standardize a method whereby the frequency-dependent values of impact sound insulation can be converted into a single number characterizing the acoustical performance.

© ISO 2020 – All rights reserved

Acoustics — Rating of sound insulation in buildings and of building elements —

Part 2: Impact sound insulation

1 Scope

This document

- a) defines single-number quantities for impact sound insulation in buildings and of floors,
- b) gives rules for determining these quantities from the results of measurements carried out in one-third-octave bands in accordance with ISO 10140-3 and ISO 16283-2, and in octave bands in accordance with that option in ISO 16283-2 for field measurements only,
- c) defines single-number quantities for the impact sound reduction of floor coverings and floating floors calculated from the results of measurements carried out in accordance with ISO 10140-3, and
- d) specifies a procedure for evaluating the weighted reduction in impact sound pressure level by floor coverings on lightweight floors.

The single-number quantities in accordance with this document are intended for rating impact sound insulation and for simplifying the formulation of acoustical requirements in building codes. An additional single-number evaluation in steps of 0,1 dB is indicated where it is needed for the expression of uncertainty (except for spectrum adaptation terms). Numerical values of the single-number quantities are specified where required for calculations.

The rating of measurements over an enlarged frequency range is given in <u>Annex A</u>.

A method for obtaining single-number quantities for bare heavy floors according to their performance in combination with floor coverings is given in <u>Annex B</u>.

Example calculations of single-number quantities are given in <u>Annex C</u>.

The rating of measurements with a heavy and soft impact source (rubber ball) is given in Annex D.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 10140-1, Acoustics — Laboratory measurement of sound insulation of building elements — Part 1: Application rules for specific products

ISO 10140-3:2010, Acoustics — Laboratory measurement of sound insulation of building elements — Part 3: Measurement of impact sound insulation

ISO 10140-5, Acoustics — Laboratory measurement of sound insulation of building elements — Part 5: Requirements for test facilities and equipment

ISO 12999-1, Acoustics — Determination and application of measurement uncertainties in building acoustics — Part 1: Sound insulation

ISO 16283-2:2018, Acoustics — Field measurement of sound insulation in buildings and of building elements — Part 2: Impact sound insulation

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at https://www.iso.org/obp
- IEC Electropedia: available at http://www.electropedia.org/

3.1

single-number quantity for impact sound insulation rating

value of the relevant reference curve at 500 Hz after shifting it in accordance with the method specified in 4.3.1 or the value of the relevant reference curve at 500 Hz after shifting it in accordance with the method specified in 4.3.2, reduced by 5 dB

Note 1 to entry: Terms and symbols for the single-number quantity used depend on the type of measurement. Examples are listed in <u>Table 1</u> for impact sound insulation properties of building elements and in <u>Table 2</u> for impact sound insulation in buildings. In general, new single-number quantities are derived in a similar way.

Note 2 to entry: This quantity is expressed in decibels.

3.2

spectrum adaptation term

 $\bar{C_{I}}$

value to be added to the single-number quantity (e.g. L_n) to take account of the unweighted impact sound level, thereby representing the characteristics of typical walking noise spectra

Note 1 to entry: This quantity is expressed in decibels.

3.3

weighted reduction in impact sound pressure level

difference between the weighted normalized impact sound pressure levels derived with a bare heavy reference floor or a lightweight reference floor, without and with a floor covering

Note 1 to entry: The quantity derived with a bare heavy reference floor is denoted by ΔL_w and is expressed in decibels.

Note 2 to entry: The quantity derived with a lightweight reference floor is denoted by $\Delta L_{t,w}$ and is expressed in decibels. According to the type of reference floor it is denoted as $\Delta L_{t1,w}$, $\Delta L_{t2,w}$, $\Delta L_{t3,w}$.

3.4

equivalent weighted normalized impact sound pressure level of a bare heavy floor

L_{n,eq,0,w}

sum of the weighted normalized impact sound pressure level of the bare floor under test with the reference floor covering and the weighted reduction in impact sound pressure level of the reference floor covering

Note 1 to entry: This quantity is calculated in accordance with the method specified in this document.

Note 2 to entry: This quantity is expressed in decibels.

3.5

A-weighted maximum impact sound pressure level

L'_{iA.Fmax}

A-weighted maximum impact sound pressure level determined with Fast time-weighting when measured with a heavy and soft impact source, the rubber ball

Note 1 to entry: This quantity is expressed in decibels.