

PAIKSED TULEKUSTUTUSSÜSTEEMID.
VEEUDUSÜSTEEMID. OSA 1: EHITUS, PAIGALDAMINE,
KONTROLL JA HOOLDUS

Fixed firefighting systems - Water mist systems - Part 1:
Design, installation, inspection and maintenance

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 14972-1:2021 sisaldab Euroopa standardi EN 14972-1:2020 ingliskeelset teksti.	This Estonian standard EVS-EN 14972-1:2021 consists of the English text of the European standard EN 14972-1:2020.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 23.12.2020.	Date of Availability of the European standard is 23.12.2020.
Standard on kättesaadav Eesti Standardimis-ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 13.220.20

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele. Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD

EN 14972-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

December 2020

ICS 13.220.20

Supersedes CEN/TS 14972:2011

English Version

Fixed firefighting systems - Water mist systems - Part 1: Design, installation, inspection and maintenance

Installations fixes de lutte contre l'incendie - Systèmes
à brouillard d'eau - Partie 1 : Conception, installation,
inspection et maintenance

Ortsfeste Brandbekämpfungsanlagen - Feinsprüh-
Löschanlagen - Teil 1: Planung, Einbau, Inspektion und
Wartung

This European Standard was approved by CEN on 11 October 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword.....	7
Introduction.....	9
1 Scope.....	10
2 Normative references.....	10
3 Terms, definitions and abbreviations	11
3.1 Terms and definitions	11
3.2 Abbreviations	18
4 Design.....	18
4.1 Design principal.....	18
4.1.1 General.....	18
4.1.2 General requirement	18
4.1.3 Full scale fire testing procedures.....	18
4.2 Design, installation, operation and maintenance manual	19
4.2.1 General.....	19
4.2.2 Content of the DIOM manual	19
4.3 Water mist systems using gas for their operation	21
4.4 Use of additives.....	21
4.5 Design parameters.....	21
4.6 Water and gas supply.....	21
4.6.1 Pumped systems requirements	21
4.6.2 Self-contained systems requirements	21
4.7 Compartment protection.....	21
4.7.1 General.....	21
4.7.2 Compartment.....	21
4.7.3 Fire hazard.....	22
4.7.4 Design requirements	22
4.8 Requirements for different types of water mist deluge systems.....	22
4.8.1 Local application systems	22
4.8.2 Local application systems with multiple hazards	22
4.8.3 Volume protection water mist systems	22
4.8.4 Zoned protection systems.....	22
4.8.5 Activation and control.....	22
4.9 Design of water mist automatic nozzle systems	23
4.9.1 Extent of protection.....	23
4.9.2 Permitted exceptions within a building.....	23
4.9.3 Material reaction.....	23
4.9.4 System design	23
4.9.5 Nozzle selection and positioning.....	28
4.9.6 Alarm device	28
4.9.7 Test connection.....	28
4.9.8 Air velocity and openings.....	28
4.10 Design of water mist deluge system	29
4.10.1 Nozzle selection and positioning.....	29
4.10.2 Air velocity and openings.....	29
4.10.3 Automatic shut-down	29
4.11 Fire detection and fire alarm systems activating the water mist system.....	29

4.11.1	General requirements.....	29
4.11.2	Fire detection and fire alarm systems continuity.....	29
4.11.3	Avoiding false alarms by water mist discharge.....	30
4.11.4	Manual activation.....	30
4.11.5	Electrical detection and activation.....	30
4.11.6	Non-electrical detection.....	31
4.12	Hydraulic and pneumatic calculations.....	31
4.13	Water, propellant and atomizing gas supply design.....	31
4.13.1	General.....	31
4.13.2	Connection to public or town mains.....	31
4.13.3	Flow requirement.....	32
4.13.4	Maximum and minimum water pressure.....	32
4.13.5	Discharge operating time.....	32
4.13.6	Type of water supply.....	34
4.13.7	Availability.....	35
4.13.8	Housing of equipment for water supplies.....	39
5	Installation.....	39
5.1	General.....	39
5.1.1	DIOM manual.....	39
5.1.2	Electrical safety.....	39
5.1.3	High Voltage live electrical equipment.....	40
5.1.4	Electrical clearances.....	40
5.2	Nozzle.....	40
5.2.1	General.....	40
5.2.2	Automatic nozzle.....	41
5.2.3	Open nozzle.....	41
5.3	Pipe.....	42
5.3.1	General.....	42
5.3.2	Protection against mechanical damages.....	42
5.3.3	Protection against corrosion.....	42
5.3.4	Protection in seismic areas.....	42
5.3.5	Protection against freezing for wet pipes.....	42
5.3.6	Accessibility of the pipe work.....	42
5.3.7	Pipe bending.....	42
5.3.8	Water supply pipes.....	43
5.3.9	Pipe support.....	43
5.3.10	Drainage.....	44
5.4	Gas and water containers (where provided).....	44
5.4.1	General.....	44
5.4.2	Location.....	44
5.4.3	Accessibility.....	44
5.4.4	Fixing.....	44
5.4.5	Manifolds.....	44
5.4.6	Temperature.....	45
5.5	Strainers and filters.....	45
5.5.1	Strainers.....	45
5.5.2	Nozzle filter.....	45
5.5.3	System filters.....	45
5.6	Valves.....	45
5.6.1	General.....	45
5.6.2	Identifications.....	45
5.6.3	Accessibility.....	45

5.6.4	Securing and monitoring valves	45
5.6.5	Shut-off valves	45
5.6.6	Control valves.....	46
5.6.7	Check and non-return valves	46
5.7	Pressure gauges.....	46
5.8	Test connection.....	46
5.8.1	Test connection for automatic water mist systems.....	46
5.8.2	Test connection for water mist deluge system.....	46
5.9	Electrical installation.....	46
5.9.1	Electrical power supply	46
5.9.2	Fire detection and fire alarm system	46
5.10	System monitoring and alarms	46
5.10.1	General.....	46
5.10.2	Alarms	47
5.10.3	Remote signalling.....	47
5.11	Water mist system supply, including additives	48
5.11.1	General.....	48
5.11.2	Water quality	48
5.11.3	Additives.....	48
5.11.4	Water supply.....	48
5.11.5	Test devices.....	51
6	Water mist system components.....	51
6.1	General.....	51
6.1.1	Requirements for components.....	51
6.1.2	Pressure rating	51
6.2	Nozzle	51
6.3	Piping and fittings.....	52
6.3.1	Pipework.....	52
6.3.2	Fittings	52
6.4	Flexible hoses	53
6.4.1	Hose length.....	53
6.4.2	Hoses to be used in areas exposed to fire class B fires.....	53
6.4.3	Hose rating	53
6.5	Pipe supports.....	53
6.6	Valves.....	53
6.6.1	Shut-off valves	53
6.6.2	Pressure regulating valves	54
6.6.3	Check and non-return valves	54
6.6.4	Drain/fill valves.....	54
6.6.5	Safety valves.....	54
6.7	Control valves.....	54
6.7.1	General.....	54
6.7.2	Strainers and filters.....	54
6.8	Flow switches and flow transmitters.....	55
6.9	Pressure switches and pressure transmitters.....	55
6.10	Supply components for self-contained systems.....	55
6.10.1	General.....	55
6.10.2	Excess pressure.....	55
6.10.3	Pressure container marking	55
6.10.4	Design temperature	55
6.10.5	Gas cylinders and actuation valve.....	55
6.10.6	Cylinders and storage containers for water	55

7	Main pumps for water mist systems.....	56
7.1	General	56
7.2	Pump set	56
7.2.1	Operation.....	56
7.2.2	Overpressure.....	56
7.2.3	Centrifugal pumps	56
7.2.4	Positive displacement pumps	56
7.2.5	Pump driver.....	56
7.2.6	Pump Cooling	56
7.2.7	Pump set anchoring.....	56
7.2.8	Positive displacement pump filters	57
7.2.9	Pump set coupling	57
7.2.10	Valves and accessories.....	57
7.2.11	Suction pipe	57
7.2.12	Discharge pipe	58
7.2.13	Pump set rating	58
7.2.14	Pump set operation.....	58
7.2.15	Electrically driven pump sets.....	59
7.2.16	Diesel engine driven pump sets	61
8	Testing, acceptance and commissioning.....	65
8.1	Acceptance test for water mist systems	65
8.2	Test criteria	65
8.3	Site commissioning test.....	66
8.4	Completion certificate and documents.....	66
9	Inspection and maintenance	67
9.1	Inspection.....	67
9.1.1	Inspection schedule	67
9.1.2	User's program of inspection	67
9.2	Inspection and maintenance routines	67
9.2.1	Weekly routine	67
9.2.2	Monthly routine	68
9.2.3	Quarterly routine.....	68
9.2.4	Half-yearly routine.....	69
9.2.5	Annual inspection.....	69
9.2.6	Three-yearly routine.....	70
9.2.7	Five-yearly routine.....	70
9.2.8	Ten-yearly routine	71
9.2.9	Maintenance schedule	71
9.2.10	User's program of monitoring.....	71
9.2.11	Training.....	71
10	Documentation	71
10.1	Installation documentation	71
10.2	Documentation for acceptance of design, installation and commissioning.....	72
Annex A (informative)	Guideline for developing representative fire test protocols for water mist systems	74
A.1	General	74
A.2	Evaluation of the fire hazard	74
A.3	Evaluation of the compartment conditions.....	75
A.4	Determining the performance objective.....	76
A.5	Setting up the fire test procedure.....	76
A.6	Carrying out the test.....	78

A.7	Documentation and interpretation of test results	78
A.8	Example for fire test report	78
Annex B	(informative) Area of operation for typical automatic nozzle water mist systems	80
B.1	General	80
B.2	Typical system component layouts	80
B.2.1	System components gridded layout	80
B.2.2	System components terminal layout	81
B.2.3	System components looped layout	81
B.3	AOs to be determined by full hydraulic calculation	82
B.4	Most unfavourable and most favourable AO demands and the pump supply curve	84
B.5	Calculating the number of nozzles and actual area of AO	85
B.6	Method of calculating the area per nozzle	87
B.6.1	Regular spacing	87
B.6.2	Irregular spacing	88
B.7	Shape of the AO	90
B.7.1	General	90
B.7.2	Shape of the hydraulically most unfavourable location	91
B.7.3	Shape of the hydraulically most favourable location	94
B.8	Length of the AO	96
B.9	Relocation of section valves	97
B.10	Calculating the nozzles operating in the most unfavourable AO	97
	Bibliography	99

European foreword

This document (EN 14972-1:2020) has been prepared by Technical Committee CEN/TC 191 "Fixed firefighting systems", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2021, and conflicting national standards shall be withdrawn at the latest by June 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes CEN/TS 14972:2011.

The former CEN/TS 14972:2011 was reviewed and replaced with this new European standard.

EN 14972, *Fixed firefighting systems — Water mist systems*, consists of the following parts:

- Part 1: Design, installation, inspection and maintenance;
- Part 2: Test protocol for shopping areas for automatic nozzle systems;
- Part 3: Test protocol for office, school class rooms and hotel for automatic nozzle systems;
- Part 4: Test protocol for non-storage occupancies for automatic nozzle systems;
- Part 5: Test protocol for car garages for automatic nozzle systems;
- Part 6: Test protocol for false floors and false ceilings for automatic nozzle systems;
- Part 7: Test protocol for commercial low hazard occupancies for automatic nozzle systems;
- Part 8: Test protocol for machinery in enclosures exceeding 260 m³ for open nozzle systems;
- Part 9: Test protocol for machinery in enclosures not exceeding 260 m³ for open nozzle systems;
- Part 10: Test protocol for atrium protection with sidewall nozzles for open nozzle systems;
- Part 11: Test protocol for cable tunnels for open nozzle systems;
- Part 12: Test protocol for commercial deep fat cooking fryers for open nozzle systems;
- Part 13: Test protocol for wet benches and other similar processing equipment for open nozzle systems;
- Part 14: Test protocol for combustion turbines in enclosures exceeding 260 m³ for open nozzle systems;
- Part 15: Test protocol for combustion turbines in enclosures not exceeding 260 m³ for open nozzle systems;
- Part 16: Test protocol for industrial oil cookers for open nozzle systems;

- Part 17: Test protocol for residential occupancies for automatic nozzle systems.

NOTE This list includes standards that are in preparation and other standards may be added. For current status of published standards refer to www.cen.eu.

This document converts CEN/TS 14972:2011 into a full EN standard. It is a full revision of the Technical Specification, and incorporates the following principal changes:

- guidance on areas of operation;
- guidance on effective capacity of tanks;
- extension of scope of application to cover more areas in buildings when supported by test standards produced by other organizations.

Any user claiming compliance with this document is expected to be able to justify any course of action that deviates from its recommendations.

This document is intended for use by manufacturers, designers and installers of water mist systems, and for authorities having jurisdiction.

It has been assumed in the preparation of this document that the execution of its provisions will be entrusted to appropriately qualified and experienced people, for whose use it has been produced.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

Water mist systems

Fixed water mist systems for the fire protection of industrial, commercial and residential hazards comprise specially designed nozzles mounted in pipework, and connected via control valves to a dedicated water supply.

Specific areas within buildings can be protected by water mist where relevant fire test protocols exist.

Water mist systems deliver a mist of small droplets which control, suppress or extinguish fire by:

- absorbing heat from the fire and its surroundings;
- smothering the flames by localized oxygen depletion through evaporation to steam;
- blocking some of the radiant heat transfer to adjacent combustible materials;
- wetting and cooling of the fuel surface.

Fires such as those involving flammable liquids (class B fires) can be extinguished using water mist. Fires such as those involving ordinary combustible materials (class A fires) can be controlled and suppressed using water mist and may also be extinguished. Water mist can also prevent flash-over.

With the high surface area of the droplets produced, water mist is able to absorb relatively large amounts of heat and thus provide efficient cooling.

Currently, the majority of applications for water mist relate to property and asset protection. However, under certain circumstances, water mist can improve conditions within the protected space and thus increase the chances of survival for personnel inside the protected areas. It can also enhance personnel protection in more general applications by protecting facilities thereby enhancing the safety of individuals.

Water mist is a specific application solution which needs to be proven for each individual application and/or occupancy.

1 Scope

This document specifies requirements and gives recommendations for the design, installation, inspection and maintenance of all types of fixed land based water mist systems.

This document is intended to apply to water mist automatic nozzle systems and water mist deluge systems supplied by stand alone or pumped systems.

The document covers only applications and occupancies which are covered by the fire test protocols of the EN 14972 series.

Aspects of water mist associated with explosion protection and/or use within vehicles are not covered by this document.

This document does not cover all legislative requirements. In certain countries specific national regulations apply and take precedence over this document. Users of this document are advised to inform themselves of the applicability or non-applicability for this document by their national responsible authorities.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 3-7:2004+A1:2007, *Portable fire extinguishers — Part 7: Characteristics, performance requirements and test methods*

EN 54 (all parts), *Fire detection and fire alarm systems*

CEN/TS 54-14, *Fire detection and fire alarm systems — Part 14: Guidelines for planning, design, installation, commissioning, use and maintenance*

EN 12094-1, *Fixed firefighting systems — Components for gas extinguishing systems — Part 1: Requirements and test methods for electrical automatic control and delay devices*

EN 12094-2, *Fixed firefighting systems — Components for gas extinguishing systems — Part 2: Requirements and test methods for non-electrical automatic control and delay devices*

EN 12094-4, *Fixed firefighting systems — Components for gas extinguishing systems — Part 4: Requirements and test methods for container valve assemblies and their actuators*

EN 12094-8, *Fixed firefighting systems — Components for gas extinguishing systems — Part 8: Requirements and test methods for connectors*

EN 12094-10, *Fixed firefighting systems — Components for gas extinguishing systems — Part 10: Requirements and test methods for pressure gauges and pressure switches*

EN 12259-1, *Fixed firefighting systems — Components for sprinkler and water spray systems — Part 1: Sprinklers*

EN 12259-2, *Fixed firefighting systems — Components for sprinkler and water spray systems — Part 2: Wet alarm valve assemblies*

EN 12259-3, *Fixed firefighting systems — Components for automatic sprinkler and water spray systems — Part 3: Dry alarm valve assemblies*

prEN 12259-12, *Fixed firefighting systems — Components for sprinkler and water spray systems — Part 12: Pumps*

EN 12845:2015+A1:2019, *Fixed firefighting systems — Automatic sprinkler systems — Design, installation and maintenance*

prEN 14972 (all parts),¹ *Fixed firefighting systems — Water mist systems*

EN 15004-1:2019, *Fixed firefighting systems — Gas extinguishing systems — Part 1: Design, installation and maintenance (ISO 14520-1:2015, modified)*

EN 17450-1,² *Fixed firefighting systems — Water mist components — Part 1: Product characteristics and test methods for strainer and filter components*

prEN 17451, *Fixed firefighting systems — Automatic sprinkler systems — Design, assembly, installation and commissioning of pump sets*

EN 50342 (all parts), *Lead-acid starter batteries*

EN 60529, *Degrees of protection provided by enclosures (IP Code)*

EN 60623, *Secondary cells and batteries containing alkaline or other non-acid electrolytes - Vented nickel-cadmium prismatic rechargeable single cells (IEC 60623)*

ISO 3046-1, *Reciprocating internal combustion engines — Performance — Part 1: Declarations of power, fuel and lubricating oil consumptions, and test methods — Additional requirements for engines for general use*

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <http://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1.1

additive

chemical or mixture of chemicals, intentionally injected to the water mist system or pre-mixed with the water in the water supply and/or system piping

Note 1 to entry: The additive can have one or more of the following purposes:

- compliance with fire protection requirements;
- corrosion protection;

¹ In preparation.

² Status at time of publication: prEN 17450-1:2019.