

This document is a preview generated by EVS

Information technology - Data centre facilities and infrastructures - Part 2-1: Building construction

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 50600-2-1:2021 sisaldab Euroopa standardi EN 50600-2-1:2021 ingliskeelset teksti.	This Estonian standard EVS-EN 50600-2-1:2021 consists of the English text of the European standard EN 50600-2-1:2021.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 16.04.2021.	Date of Availability of the European standard is 16.04.2021.
Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 35.020, 35.110, 91.140.50

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele. Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD

EN 50600-2-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

April 2021

ICS 35.020; 35.110; 91.140.50

Supersedes EN 50600-2-1:2014 and all of its amendments and corrigenda (if any)

English Version

Information technology - Data centre facilities and infrastructures - Part 2-1: Building construction

Technologie de l'information - Installation et infrastructures
de centres de traitement de données - Partie 2-1:
Construction des bâtiments

Informationstechnik - Einrichtungen und Infrastrukturen von
Rechenzentren - Teil 2-1: Gebäudekonstruktion

This European Standard was approved by CENELEC on 2021-03-22. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	4
Introduction	5
1 Scope	8
2 Normative references	8
3 Terms, definitions and abbreviations	9
3.1 Terms and definitions	9
3.2 Abbreviations	10
4 Conformance	10
5 Location	10
5.1 Assessment of location	10
5.2 Geographical location	11
5.3 Environmental risk analysis	11
5.4 Utility provision.....	12
6 Site configuration	13
6.1 General	13
6.2 Site selection	13
6.3 Assessment of existing premises	14
6.4 Utilities	14
7 Outside spaces	15
7.1 Access routes	15
7.2 Parking.....	15
7.3 Temporary facilities.....	15
7.4 Fuel storage facilities and infrastructure.....	16
7.5 Underground facilities	16
7.6 Perimeter design and Protection Class Boundaries	16
8 Building construction	19
8.1 Load-bearing structure.....	19
8.2 Building materials and finishes	19
8.3 Electromagnetic Interference.....	20
8.4 Protection Class Boundaries	20
8.5 Foundations	21
8.6 Exterior walls	22
8.7 Interior walls and barriers	22
8.8 Roofs.....	23
8.9 Water drainage	23
8.10 Floors	24
8.11 Raised access floors.....	25
8.12 Ceilings	25
8.13 Corridors and doors	26

8.14	Transportation lifts	26
9	Design of data centre spaces	26
9.1	Accommodation	26
9.2	Control room space	27
9.3	Computer room space	27
9.4	Electrical space	28
9.5	Mechanical space	28
9.6	Telecommunications space	28
9.7	Spaces for firefighting systems	28
9.8	Storage space	28
9.9	Testing and holding spaces	29
9.10	Docking bay	29
9.11	General office space	29
10	Construction of data centre spaces	29
10.1	Protection against flooding	29
10.2	Access to data centre spaces	30
10.3	Vapour density	30
11	Fire compartments and fire barriers	30
11.1	Fire compartments	30
11.2	Fire barriers	31
11.3	Protection Class boundaries	32
	Annex A (informative) Building materials	33
	Annex B (informative) Summary of data centre location requirements and recommendations of Clause 5	35
	Bibliography	38
Figures		
	Figure 1 — Schematic relationship between the EN 50600 series standards	6
	Figure 2 — Examples of free-standing barriers and minimum effective height	18
Tables		
	Table 1 — Heights and topping requirements for free-standing barriers	17
	Table 2 — Load capacity guidance for building structures	24
	Table B.1 — Summary of EN 50600-2-1:2021, Clause 5 location requirements and recommendations	35

European foreword

This document (EN 50600-2-1:2021) has been prepared by CLC/TC 215 “Electrotechnical aspects of telecommunication equipment”.

The following dates are fixed:

- latest date by which this document has to be (dop) 2022-03-22
implemented at national level by publication of an
identical national standard or by endorsement
- latest date by which the national standards (dow) 2024-03-22
conflicting with this document have to be withdrawn

This document supersedes EN 50600-2-1:2014 and all of its amendments and corrigenda (if any).

This document includes the following significant technical changes with respect to EN 50600-2-1:2014:

- a) the document has been completely revised and restructured;
- b) the interrelationship between this document and EN 50600-2-5 concerning constructional prerequisites for the implementation of security concepts and desired security systems has been more clearly presented;
- c) Clause 6 “Site configuration” has been split and relevant subclauses have been moved into a new Clause 7 “Outside spaces”;
- d) Clause 7 “Building construction” has been completely reworked to present all requirements and recommendations in a single Clause 8;
- e) Clause 8 “Data centre spaces and access routes” has been revised to focus on the design of data centre spaces (now Clause 9);
- f) a new Clause 10 “Construction of data centre spaces” has been added;
- g) Clause 9 “Fire compartments, fire barriers and fire suppression systems” has been revised (now Clause 11);
- h) Annex A on additional requirements and recommendations has been removed;
- i) Annex B on physical protection against external hazards has been revised as Annex A “Building materials”;
- j) a new Annex B summarizing the requirements and recommendations of Clause 5 has been added;
- k) Clauses 1 to 4 have been amended accordingly.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Introduction

The unrestricted access to internet-based information demanded by the information society has led to an exponential growth of both internet traffic and the volume of stored/retrieved data. Data centres are housing and supporting the information technology and network telecommunications equipment for data processing, data storage and data transport. They are required both by network operators (delivering those services to customer premises) and by enterprises within those customer premises.

Data centres usually provide modular, scalable and flexible facilities and infrastructures to easily accommodate the rapidly changing requirements of the market. In addition, energy consumption of data centres has become critical both from an environmental point of view (reduction of environmental footprint) and with respect to economical considerations (cost of energy) for the data centre operator.

The implementation of data centres varies in terms of:

- a) purpose (enterprise, co-location, co-hosting or network operator facilities);
- b) security level;
- c) physical size;
- d) accommodation (mobile, temporary and permanent constructions).

The needs of data centres also vary in terms of availability of service, the provision of security and the objectives for energy efficiency. These needs and objectives influence the design of data centres in terms of building construction, power distribution, environmental control, telecommunications cabling and physical security as well as the operation of the data centre. Effective management and operational information is important in order to monitor achievement of the defined needs and objectives.

Recognizing the substantial resource consumption, particularly of energy, of larger data centres, it is also important to provide tools for the assessment of that consumption both in terms of overall value and of source mix and to provide Key Performance Indicators (KPIs) to evaluate trends and drive performance improvements.

At the time of publication of this document, the EN 50600 series is designed as a framework of standards, technical specifications and technical reports covering the design, the operation and management, the key performance indicators for energy efficient operation of the data centre as well as a data centre maturity model.

The EN 50600-2 series defines the requirements for the data centre design.

The EN 50600-3 series defines the requirements for the operation and the management of the data centre.

The EN 50600-4 series defines the key performance indicators for the data centre.

The CLC/TS 50600-5 series defines the data centre maturity model requirements and recommendations.

The CLC/TR 50600-99-X Technical Reports cover recommended practices and guidance for specific topics around data centre operation and design.

This series of documents specifies requirements and recommendations to support the various parties involved in the design, planning, procurement, integration, installation, operation and maintenance of facilities and infrastructures within data centres. These parties include:

- 1) owners, operators, facility managers, ICT managers, project managers, main contractors;
- 2) consulting engineers, architects, building designers and builders, system and installation designers, auditors, test and commissioning agents;
- 3) facility and infrastructure integrators, suppliers of equipment;
- 4) installers, maintainers.

At the time of publication of this document, the EN 50600-2 series comprises the following documents:

EN 50600-2-1, *Information technology — Data centre facilities and infrastructures — Part 2-1: Building construction*;

EN 50600-2-2, *Information technology — Data centre facilities and infrastructures — Part 2-2: Power supply and distribution*;

EN 50600-2-3, *Information technology — Data centre facilities and infrastructures — Part 2-3: Environmental control*;

EN 50600-2-4, *Information technology — Data centre facilities and infrastructures — Part 2-4: Telecommunications cabling infrastructure*;

EN 50600-2-5, *Information technology — Data centre facilities and infrastructures — Part 2-5: Security systems*.

CLC/TR 50600-2-10, *Information technology — Data centre facilities and infrastructures — Part 2-10: Earthquake risk and impact analysis*

The inter-relationship of the documents within the EN 50600 series is shown in Figure 1.




Figure 1 — Schematic relationship between the EN 50600 series standards

EN 50600-2-X documents specify requirements and recommendations for particular facilities and infrastructures to support the relevant classification for “availability”, “physical security” and “energy efficiency enablement” selected from EN 50600-1.

EN 50600-3-X documents specify requirements and recommendations for data centre operations, processes and management.

EN 50600-4-X documents specify requirements and recommendations for key performance indicators (KPIs) used to assess and improve the resource usage efficiency and effectiveness, respectively, of a data centre.

This document addresses the site selection and the building design of data centres; it addresses security issues from a constructional point of view, whereas EN 50600-2-5 specifies the security system requirements of those facilities and infrastructures (in accordance with the requirements of EN 50600-1).

This document is intended for use by and collaboration between architects, building designers and builders, system and installation designers.

This series of documents does not address the selection of information technology and network telecommunications equipment, software and associated configuration issues.

This document is a preview generated by EVS

1 Scope

This document gives guidelines for the construction of buildings and other structures which provide accommodation for data centres based upon the criteria and classification for “physical security” within EN 50600-1 in support of availability.

This document specifies requirements and recommendations for the following:

- a) location and site selection (taking in to account natural environment and adjacencies);
- b) protection from environmental risks;
- c) site configuration;
- d) building construction;
- e) building configuration;
- f) provision of access;
- g) intrusion protection;
- h) physical fire protection;
- i) protection against damage from water;
- j) quality construction measures.

Safety and electromagnetic compatibility (EMC) requirements are outside the scope of this document and are covered by other standards and regulations. However, information given in this document can be of assistance in meeting these standards and regulations.

Conformance of data centres to the present document is covered in Clause 4.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 81 (all parts), *Safety rules for the construction and installation of lifts - Special lifts for the transport of persons and goods*

EN 1366-3, *Fire resistance tests for service installations - Part 3: Penetration seals*

EN 1627:2011, *Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglar resistance - Requirements and classification*

EN 1634 (all parts), *Fire resistance and smoke control tests for door and shutter assemblies, openable windows and elements of building hardware*

EN 1991-1-1, *Eurocode 1: Actions on structures - Part 1-1: General actions - Densities, self-weight, imposed loads for buildings*

EN 12825:2001, *Raised access floors*

EN 50310, *Telecommunications bonding networks for buildings and other structures*

EN 50600-1:2019, *Information technology - Data centre facilities and infrastructures - Part 1: General concepts*

EN 50600-2-2, *Information technology - Data centre facilities and infrastructures - Part 2-2: Power supply and distribution*

EN 50600-2-3, *Information technology - Data centre facilities and infrastructures - Part 2-3: Environmental control*

EN 50600-2-4, *Information technology - Data centre facilities and infrastructures - Part 2-4: Telecommunications cabling infrastructure*

EN 50600-2-5, *Information technology - Data centre facilities and infrastructures - Part 2-5: Security systems*

CLC/TS 50600-2-10, *Information technology - Data centre facilities and infrastructures - Part 2-10: Earthquake risk and impact analysis*

EN 50600-3-1, *Information technology - Data centre facilities and infrastructures - Part 3-1: Management and operational information*

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 50600-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1.1

effective height of free-standing barrier

h_e

shortest distance between any point on the top of the permanent part of the free-standing barrier (excluding any toppings) and the surface of the supporting ground when measured in the plane of the barrier

3.1.2

free-standing barrier

wall, fence, gate, turnstile or other similar self-supporting barrier, and their associated foundations, designed to prevent entry to a space of a given Protection Class

3.1.3

topping

construction, added to the top of a free-standing barrier, and designed to be an effective intruder deterrent or for a decorative display of security

3.1.4

modular construction

construction method which uses a system of prefabricated elements and assemblies

3.1.5

pathway

defined route of different media between identified points

Note 1 to entry: Examples of media are bus bars, cables, conduits, ducts, pipes.