
**Plastics piping systems for the supply
of gaseous fuels — Unplasticized
polyamide (PA-U) piping systems
with fusion jointing and mechanical
jointing —**

**Part 5:
Fitness for purpose of the system**

*Systèmes de canalisations en matières plastiques pour la distribution
de combustibles gazeux — Systèmes de canalisations en polyamide
non plastifié (PA-U) avec assemblages par soudage et assemblages
mécaniques —*

Partie 5: Aptitude à l'emploi du système



This document is a preview generated by ELS



COPYRIGHT PROTECTED DOCUMENT

© ISO 2021

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword.....	iv
Introduction.....	vi
1 Scope.....	1
2 Normative references.....	1
3 Terms and definitions.....	2
4 Symbols.....	3
5 Fitness for purpose.....	3
5.1 Method of preparation of assemblies for testing.....	3
5.1.1 General.....	3
5.1.2 Butt fusion joints.....	3
5.1.3 Electrofusion jointing.....	3
5.1.4 Transition fittings.....	4
5.2 Requirements for fitness for purpose.....	4
5.2.1 Fitness for purpose for butt fusion joints.....	4
5.2.2 Fitness for purpose for electrofusion joints.....	5
5.2.3 Fitness for purpose for transition fittings.....	7
6 Design coefficient.....	7
Annex A (normative) Preparation of test assemblies by butt fusion.....	8
Annex B (normative) Preparation of test assemblies by electrofusion.....	11
Annex C (informative) Derating coefficients for operating temperatures.....	12
Annex D (normative) Rapid crack propagation (RCP) resistance of pipe at temperature less than 0 °C.....	13
Bibliography.....	14

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fittings and valves for the transport of fluids*, Subcommittee SC 4, *Plastics pipes and fittings for the supply of gaseous fuels*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 155, *Plastics piping systems and ducting systems*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 16486-5:2012), which has been technically revised.

The main changes compared to the previous edition are as follows:

- for transition fittings, reference is made to ISO 17885;
- new [Clause 5](#), Design Coefficient, has been added;
- [Annex A](#) refers to ISO 11414 for test piece assemblies by butt fusion and has been brought in line with ISO 12176-1 for butt fusion equipment.
- [Annex A](#) has been brought in line with ISO 21307, with a definition of PA fusion parameters for the single low-pressure and the single high-pressure butt fusion jointing procedures (the dual low-pressure procedure is not investigated for PA-U so far);
- in [Table A.2](#) for the single low-pressure butt fusion procedure, the pressure, p_1 , has been changed from $(0,3 \pm 0,1)$ MPa to $(0,3 \pm 0,05)$ MPa to raise the minimum pressure from 0,2 MPa to 0,25 MPa;
- [Annex B](#) refers to ISO 11413 for test piece assemblies by electro fusion and to ISO 12176-2 for electro fusion equipment;
- Annex C of ISO 16486-5:2012, Assessment of fitness for purpose of transition fittings, has been deleted;
- new [Annex C](#), Derating coefficients for operating temperatures, has been transferred from ISO 16486-6;

- new [Annex D](#), Rapid crack propagation (RCP) resistance of pipe at temperature less than 0 °C, has been added.

A list of all parts in the ISO 16486 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document specifies the requirements for a piping system and its components made from unplasticized polyamide (PA-U), which is intended to be used for the supply of gaseous fuels.

Requirements and test methods for material and components of the piping system are specified in ISO 16486-1, ISO 16486-2, ISO 16486-3, and ISO 16486-4.

This document covers the characteristics for fitness for purpose of the system.

Recommended practice for installation is given in ISO 16486-6, which will not be implemented as European Standard under the Vienna Agreement.

NOTE Recommended practice for installation is also given in CEN/TS 12007-6, which has been prepared by Technical Committee CEN/TC 234, *Gas infrastructure*.

Assessment of conformity of the system is to form the subject the future ISO/TS 16486-7¹⁾.

1) Under preparation. Stage at the time of publication: ISO/AWI TS 16486-7:2021.

Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing —

Part 5: Fitness for purpose of the system

1 Scope

This document specifies the requirements of fitness for purpose of unplasticized polyamide (PA-U) piping system, intended to be buried and used for the supply of gaseous fuels. It also specifies the definitions of electrofusion and butt fusion joints.

This document specifies the method of preparation of test piece joints and the tests to be carried out on these joints for assessing the fitness for purpose of the system under normal and extreme conditions. It also specifies the test parameters for the test methods to which it refers.

The ISO 16486 series is applicable to PA-U piping systems, the components of which are connected by fusion jointing and/or mechanical jointing.

In conjunction with the other parts of ISO 16486, it is applicable to PA-U fittings, their joints and to joints with components of PA-U.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 1167-1, *Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 1: General method*

ISO 1167-4, *Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 4: Preparation of assemblies*

ISO 11413:2019, *Plastics pipes and fittings — Preparation of test piece assemblies between a polyethylene (PE) pipe and an electrofusion fitting*

ISO 11414:2009, *Plastics pipes and fittings — Preparation of polyethylene (PE) pipe/pipe or pipe/fitting test piece assemblies by butt fusion*

ISO 13953, *Polyethylene (PE) pipes and fittings — Determination of the tensile strength and failure mode of test pieces from a butt-fused joint*

ISO 13954, *Plastics pipes and fittings — Peel decohesion test for polyethylene (PE) electrofusion assemblies of nominal outside diameter greater than or equal to 90 mm*

ISO 13955, *Plastics pipes and fittings — Crushing decohesion test for polyethylene (PE) electrofusion assemblies*

ISO 13956, *Plastics pipes and fittings — Decohesion test of polyethylene (PE) saddle fusion joints — Evaluation of ductility of fusion joint interface by tear test*

ISO 16486-1, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 1: General*

ISO 16486-2, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 2: Pipes*

ISO 16486-3, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 3: Fittings*

ISO 16486-6, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 6: Code of practice for design, handling and installation*

ISO 17885, *Plastics piping systems — Mechanical fittings for pressure piping systems — Specifications*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 16486-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1 electrofusion joint

joint between a PA-U electrofusion socket or saddle fitting and a pipe or a spigot end fitting

Note 1 to entry: The electrofusion fittings are heated by the Joule effect of the heating element incorporated at their jointing surfaces, causing the material adjacent to them to melt and the pipe and fitting surfaces to fuse.

3.2 butt fusion joint

joint made by heating the planed ends of matching surfaces by holding them against a flat heating plate until the PA-U material reaches fusion temperature, quickly removing the heating plate and pushing the two softened ends against one another

Note 1 to entry: This definition refers to a butt fusion joint using a heating tool.

3.3 fusion compatibility

ability of two unplasticized polyamide materials of the same type to be fused together to form a joint which conforms to the performance requirements of this part of ISO 16486

3.4 transition fitting

factory-made fitting that makes a *transition joint* (3.5) between a unplasticized polyamide (PA-U) piping and a metallic pipe as described in ISO 16486-3

Note 1 to entry: The metallic parts of the fitting may be assembled to metallic pipes by screw threads, compression joints, welded or flanged connections. The fitting can allow for either a dismountable or permanently assembled joint. In some cases, the supporting ring may also act as a grip ring.

3.5 transition joint

joint at which two different piping materials (the PA-U and metal piping) are connected