

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**High-voltage switchgear and controlgear –
Part 103: Alternating current switches for rated voltages above 1 kV up to and
including 52 kV**

**Appareillage à haute tension –
Partie 103: Interrupteurs à courant alternatif pour tensions assignées
supérieures à 1 kV et inférieures ou égales à 52 kV**





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC online collection - oc.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.



IEC 62271-103

Edition 2.0 2021-05

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**High-voltage switchgear and controlgear –
Part 103: Alternating current switches for rated voltages above 1 kV up to and
including 52 kV**

**Appareillage à haute tension –
Partie 103: Interrupteurs à courant alternatif pour tensions assignées
supérieures à 1 kV et inférieures ou égales à 52 kV**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.130.10

ISBN 978-2-8322-9770-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD	8
1 Scope	10
2 Normative references	10
3 Terms and definitions	11
3.1 General terms and definitions	11
3.2 Assemblies of switchgear and controlgear	11
3.3 Parts of assemblies	11
3.4 Switching devices	12
3.5 Parts of switchgear and controlgear	12
3.6 Operational characteristics of switchgear and controlgear	13
3.7 Characteristic quantities	13
3.8 Index of definitions	17
4 Normal and special service conditions	18
5 Ratings	18
5.1 General	18
5.2 Rated voltage (U_r)	18
5.3 Rated insulation level (U_d , U_p , U_s)	18
5.4 Rated frequency (f_r)	18
5.5 Rated continuous current (I_r)	18
5.6 Rated short-time withstand current (I_k)	19
5.7 Rated peak withstand current (I_p)	19
5.8 Rated duration of short-circuit (t_k)	19
5.9 Rated supply voltage of auxiliary circuits and control circuits (U_a)	19
5.10 Rated supply frequency of auxiliary and control circuits	19
5.11 Rated pressure of compressed gas supply for controlled pressure systems	19
5.101 Rated mainly active load-breaking current (I_{load})	19
5.102 Rated closed-loop breaking current (I_{loop})	19
5.103 Rated parallel power transformer breaking current for special purpose switches (I_{pptr})	19
5.104 Rated cable-charging breaking current (I_{cc})	19
5.105 Rated line-charging breaking current (I_{lc})	19
5.106 Rated single capacitor bank breaking current for special purpose switches (I_{sb})	20
5.107 Rated back-to-back capacitor bank breaking current for special purpose switches (I_{bb})	20
5.108 Rated back-to-back capacitor bank inrush making current for special purpose switches (I_{in})	20
5.109 Rated earth fault breaking current (I_{ef1})	20
5.110 Rated cable- and line-charging breaking current under earth fault conditions (I_{ef2})	20
5.111 Rated motor breaking current for special purpose switches (I_{mot})	20
5.112 Rated short-circuit making current (I_{ma})	21
5.113 Types of switches and their associated ratings	21

5.113.1	Types of switches	21
5.113.2	Rated making and breaking currents for general purpose switches	21
5.113.3	Rated making and breaking currents for limited purpose switches	22
5.113.4	Rated making and breaking currents for special purpose switches	22
5.113.5	Ratings for switches backed by fuses	22
5.114	Mechanical endurance class of switches	23
5.114.1	Class M1 switch.....	23
5.114.2	Class M2 switch.....	23
5.115	Electrical endurance class of general purpose switches	23
5.115.1	Class E1 general purpose switch	23
5.115.2	Class E2 general purpose switch	23
5.115.3	Class E3 general purpose switch	23
5.116	Capacitive breaking capability class of switches	23
5.116.1	General	23
5.116.2	Class C1 switch	23
5.116.3	Class C2 switch.....	24
6	Design and construction	24
6.1	Requirements for liquids in switchgear and controlgear.....	24
6.2	Requirements for gases in switchgear and controlgear	24
6.3	Earthing of switchgear and controlgear	24
6.4	Auxiliary and control equipment and circuits	24
6.5	Dependent power operation	24
6.6	Stored energy operation.....	24
6.7	Independent unlatched operation (independent manual or power operation)	24
6.8	Manually operated actuators	24
6.9	Operation of releases.....	24
6.10	Pressure/level indication	24
6.11	Nameplates.....	25
6.11.1	General	25
6.11.2	Application.....	25
6.12	Locking devices	27
6.13	Position indication	27
6.14	Degrees of protection provided by enclosures	27
6.15	Creepage distances for outdoor insulators	27
6.16	Gas and vacuum tightness	27
6.17	Tightness for liquid systems	27
6.18	Fire hazard (flammability)	27
6.19	Electromagnetic compatibility (EMC)	28
6.20	X-ray emission	28
6.21	Corrosion	28
6.22	Filling levels for insulation, switching and/or operation	28
6.101	Making and breaking operations	28
6.102	Requirements for switch-disconnectors	28
6.103	Mechanical strength	28
6.104	Securing the position	28
6.105	Indication and signalling of position	28
6.105.1	General requirements	28
6.105.2	Indication of position.....	29
6.105.3	Signalling of position by auxiliary contacts	30

6.106	No-load transformer breaking.....	30
7	Type tests	30
7.1	General.....	30
7.1.1	Basics	30
7.1.2	Information for identification of test objects.....	31
7.1.3	Information to be included in the type-test reports	31
7.2	Dielectric tests	31
7.2.9	Artificial pollution tests for outdoor insulators.....	31
7.2.10	Partial discharge tests	31
7.3	Radio interference voltage (RIV) test	31
7.4	Resistance measurement.....	32
7.5	Continuous current tests	32
7.6	Short-time withstand current and peak withstand current tests	32
7.6.1	General	32
7.6.2	Arrangement of the equipment and of the test circuit	32
7.6.3	Test current and duration.....	32
7.6.4	Conditions of the test object after test.....	32
7.7	Verification of the protection	32
7.8	Tightness tests	32
7.9	Electromagnetic compatibility (EMC) tests	32
7.10	Additional tests on auxiliary and control circuits	32
7.10.1	General	32
7.10.2	Functional tests	32
7.10.3	Verification of the operational characteristics of auxiliary contacts	33
7.10.4	Environmental tests	33
7.10.5	Dielectric test	33
7.11	X-radiation test for vacuum interrupters	33
7.101	Making and breaking tests	33
7.101.1	Test duties for general purpose switches	33
7.101.2	Test duties for limited purpose switches	36
7.101.3	Test duties for special purpose switches.....	36
7.101.4	Arrangement of the switch for tests.....	37
7.101.5	Earthing of test circuit and switch	38
7.101.6	Test parameters	38
7.101.7	Test circuits	41
7.101.8	Behaviour of switch during breaking tests	56
7.101.9	Condition of switch after breaking tests and short-circuit making tests	57
7.101.10	Type-test reports	57
7.102	Mechanical and environmental tests	59
7.102.1	Miscellaneous provisions for mechanical and environmental tests	59
7.102.2	Mechanical operation test at ambient air temperature	60
7.102.3	Low and high temperature tests	61
7.102.4	Humidity test on auxiliary and control circuits	65
7.102.5	Operation under severe ice conditions	67
7.102.6	Tests to verify the proper functioning of the position-indicating device	67
7.103	Common checks after tests.....	68
7.103.1	Checking the capability of the switch to carry its rated continuous current.....	68

7.103.2	Checking the integrity of vacuum in case of a switch using a vacuum interrupter.....	69
8	Routine tests	70
8.101	General.....	70
8.102	Mechanical operating tests	70
9	Guide to the selection of switchgear and controlgear (informative)	70
9.101	General.....	70
9.102	Conditions affecting application	70
9.103	Insulation coordination.....	71
9.104	Selection of class of switch.....	71
9.104.1	General purpose switch	71
9.104.2	Limited purpose switch	71
9.104.3	Special purpose switch	71
9.105	Tests for special applications	71
10	Information to be given with inquiries, tenders and orders (informative)	71
10.1	General.....	71
10.2	Information with inquiries and orders.....	72
10.3	Information with tenders.....	72
11	Transport, storage, installation, operating instructions and maintenance.....	73
12	Safety.....	73
13	Influence of the product on the environment	73
Annex A (normative)	Tolerances on test quantities for type tests	74
Annex B (informative)	Explanation of the determination for the value of I_{ef1} and I_{ef2}	76
B.1	Usage of rating I_{ef1} and I_{ef2}	76
B.1.1	General	76
B.1.2	Isolated neutral system.....	76
B.1.3	High impedance earthed neutral systems	78
B.1.4	Resonant earthed neutral systems (Petersen coil)	79
B.1.5	Synthesis.....	80
B.2	Calculation of I_{ef1} and I_{ef2}	81
B.2.1	General	81
B.2.2	Calculation of I_{ef1}	84
B.2.3	Calculation of I_{ef2}	84
Annex C (informative)	List of notes concerning certain countries	86
Bibliography.....	87	
Figure 1 – Position-indicating/signalling device(s)	29	
Figure 2 – Three-phase test circuit for mainly active load current switching for test duty TD_{load}	42	
Figure 3 – Single-phase test circuit for mainly active load current switching for test duty TD_{load}	43	
Figure 4 – Three-phase test circuit for distribution line closed-loop and parallel transformer current switching test for test duties TD_{loop} and TD_{pptr}	45	

Figure 5 – Single-phase test circuit for distribution line closed-loop and parallel transformer current switching test, for test duties TD _{loop} and TD _{pptr}	45
Figure 6 – General test circuit for three- and single-phase capacitive switching tests.....	51
Figure 7 – Prospective recovery voltage and related specified parameter values for capacitive current breaking tests.....	53
Figure 8 – Three-phase test circuit for earth fault breaking current tests, for test duty TD _{ef1}	54
Figure 9 – Three-phase test circuit for cable-charging breaking current tests under earth fault conditions, for test duty TD _{ef2}	55
Figure 10 – Three-phase test circuit for short-circuit making current test for test duty TD _{ma}	55
Figure 11 – Single-phase test circuit for short-circuit making current test for test duty TD _{ma}	56
Figure 12 – Test sequences for low and high temperature tests	62
Figure 13 – Humidity test	66
Figure B.1 – Earth fault in isolated neutral system	76
Figure B.2 – Capacitive current in non-faulty phases of isolated neutral system.....	78
Figure B.3 – Earth fault in high impedance earthed neutral system	79
Figure B.4 – Earth fault in resonant or compensate earthed neutral system	80
Figure B.5 – Example of sequence to find and isolate a faulty branch in an overhead network	82
Figure B.6 – Example of sequence to find and isolate a faulty branch in a cable network.....	83
 Table 1 – Preferred values of rated line- and cable-charging breaking currents for general purpose switches	22
Table 2 – Nameplate information	25
Table 3 – Test duties for general purpose switches – Test duties for three-phase tests on three-pole operated, general purpose switches	34
Table 4 – Test duties for general purpose switches – Single-phase tests on three-pole general purpose switches operated pole-after-pole and single-pole general purpose switches applied on three-phase systems	34
Table 5 – Test duties for special purpose switches – Three-phase tests on three-pole operated switches	36
Table 6 – Test duties for special purpose switches – Single-phase tests on three-pole switches operated pole-after-pole and single-pole switches applied on three-phase systems	37
Table 7 – Summary of the conditions for combining tests and alternative procedures	39
Table 8 – Supply circuit TRV parameters for mainly active load current breaking tests ^a	43
Table 9 – TRV parameters for distribution line closed loop breaking tests.....	46
Table 10 – TRV parameters for parallel power transformer breaking current tests	47
Table 11 – Prospective recovery voltage parameter limits for capacitive current breaking tests	53
Table A.1 – Tolerances on test quantities for type tests	74
Table B.1 – Need of ratings I_{ef1} and I_{ef2} in non-effectively earthed neutral systems	80
Table B.2 – Values relating to the examples in Figure B.5 and Figure B.6 for capacitance and capacitive current for cables and overhead lines [6], [10], [11].....	85

Table B.3 – Values for $I_{\text{ef}2}$	85
---	----

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –**Part 103: Alternating current switches for rated voltages
above 1 kV up to and including 52 kV****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62271-103 has been prepared by subcommittee 17A: Switching devices, of IEC technical committee 17: High-voltage switchgear and controlgear. It is an International Standard.

This second edition cancels and replaces the first edition published in 2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) this document has been aligned with IEC 62271-1:2017 and IEC 62271-102:2018;
- b) clarifications regarding the behaviour of the switch during breaking tests regarding current interruption and restrikes have been added;
- c) conditions of the switch after making and breaking tests have been clarified;
- d) a new informative Annex B intended to provide guidance for the calculation of I_{ef1} and I_{ef2} has been added;

- e) new rules for the combination of 50 Hz and 60 Hz switching tests have been defined and a new table (Table 7) has been added;
- f) tests with specified TRV have been modified to be in accordance with the practice described in IEC 62271-100;
- g) the behaviour of the switch during breaking tests has been clarified and boundaries for restrike allowance have been defined;
- h) explanations for short-circuit making tests have been added;
- i) vacuum integrity check after mechanical operations has been defined;
- j) all test voltages for single-phase capacitive testing have been grouped under 7.101.7.3.2 and have been confirmed by simulation and calculation.

The text of this International Standard is based on the following documents:

Draft	Report on voting
17A/1297/FDIS	17A/1303/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

This document is to be read in conjunction with IEC 62271-1:2017, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC 62271-1:2017. Amendments to these clauses and subclauses are given under the same numbering whilst additional subclauses are numbered from 101.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The reader's attention is drawn to the fact that Annex C lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 103: Alternating current switches for rated voltages above 1 kV up to and including 52 kV

1 Scope

This part of IEC 62271 is applicable to three-phase, alternating current switches and switch-disconnectors for their switching function, having making and breaking current ratings, for indoor and outdoor installations, for rated voltages above 1 kV up to and including 52 kV and for rated frequencies from 16 2/3 Hz up to and including 60 Hz. This document is also applicable to single-pole switches used on three-phase systems.

This document is also applicable to the operating devices of these switches and to their auxiliary equipment.

For switch-disconnectors, refer also to IEC 62271-102 for their disconnecting function.

Devices not covered by this document are:

- devices that require a dependent manual operation;
- earthing switches. Earthing switches forming an integral part of a switch are covered by IEC 62271-102;
- switching devices attached as an element of a high-voltage fuse assembly or its mounting and operated by opening and closing the fuse assembly.

General principles and provisions of this document can also be applicable to single pole switches intended for application in single-phase systems, the requirements for dielectric tests and making and breaking tests being in accordance with the requirements of the specific application.

This document establishes requirements for general, limited and special purpose switches used in distribution systems.

NOTE Except where special clarification is required, the term "switch" is used to refer to all kinds of switches and switch-disconnectors within the scope of this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-441, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses* (available at <http://www.electropedia.org>)

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*
IEC 60529:1989/AMD1:1999
IEC 60529:1989/AMD1:2013

IEC 62262:2002, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-102:2018, *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

IEC 62271-110:2017, *High-voltage switchgear and controlgear – Part 110: Inductive load switching*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-441 and IEC 62271-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

NOTE Terms and definitions are classified in accordance with IEC 62271-1:2017.

3.1 General terms and definitions

Subclause 3.1 of IEC 62271-1:2017 is applicable with the following additions:

3.1.101

effectively earthed neutral system

system earthed through a sufficiently low impedance such that for all system conditions the ratio of the zero-sequence reactance to the positive-sequence reactance (X_0/X_1) is positive and less than 3, and the ratio of the zero-sequence resistance to the positive-sequence reactance (R_0/X_1) is positive and less than 1

Note 1 to entry: Normally such systems are solidly earthed (neutral) systems or low impedance earthed (neutral) systems.

Note 2 to entry: The earthing conditions depend not only on the physical earthing conditions around the relevant location but also on the total system.

3.1.102

non-effectively earthed neutral system

system other than effectively earthed neutral system, not meeting the conditions given in 3.1.101

Note 1 to entry: Normally such systems are isolated neutral systems, high impedance earthed (neutral) systems or resonant earthed (neutral) systems

Note 2 to entry: The earthing conditions depend not only on the physical earthing conditions around the relevant location but also on the total system.

3.2 Assemblies of switchgear and controlgear

Subclause 3.2 of IEC 62271-1:2017 applies.

3.3 Parts of assemblies

Subclause 3.3 of IEC 62271-1:2017 applies.