



IEC 61557-12

Edition 2.1 2021-05
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electrical safety in low voltage distribution systems up to 1 000 V AC and
1 500 V DC – Equipment for testing, measuring or monitoring of protective
measures –**

Part 12: Power metering and monitoring devices (PMD)

**Sécurité électrique dans les réseaux de distribution basse tension jusqu'à
1 000 V en courant alternatif et 1 500 V en courant continu – Dispositifs de
contrôle, de mesure ou de surveillance de mesures de protection –**

Partie 12: Dispositifs de comptage et de surveillance du réseau électrique (PMD)



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC online collection - oc.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.



IEC 61557-12

Edition 2.1 2021-05
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures –

Part 12: Power metering and monitoring devices (PMD)

**Sécurité électrique dans les réseaux de distribution basse tension jusqu'à 1 000 V en courant alternatif et 1 500 V en courant continu – Dispositifs de contrôle, de mesure ou de surveillance de mesures de protection –
Partie 12: Dispositifs de comptage et de surveillance du réseau électrique (PMD)**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 17.220.20; 29.080.01; 29.240.01

ISBN 978-2-8322-9845-9

Warning! Make sure that you obtained this publication from an authorized distributor.

Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.



IEC 61557-12

Edition 2.1 2021-05
CONSOLIDATED VERSION

REDLINE VERSION

VERSION REDLINE



Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures –

Part 12: Power metering and monitoring devices (PMD)

Sécurité électrique dans les réseaux de distribution basse tension jusqu'à 1 000 V en courant alternatif et 1 500 V en courant continu – Dispositifs de contrôle, de mesure ou de surveillance de mesures de protection –

Partie 12: Dispositifs de comptage et de surveillance du réseau électrique (PMD)

CONTENTS

FOREWORD	9
INTRODUCTION	11
1 Scope	12
2 Normative references	13
3 Terms, definitions and notations	13
3.1 General definitions	14
3.2 Definitions related to uncertainty and performance	16
3.3 Definitions related to electric phenomena	19
3.4 Definitions related to measurement techniques	22
3.5 Notations	23
3.5.1 Functions	23
3.5.2 Symbols and abbreviations	23
3.5.3 Indices	24
4 Requirements	24
4.1 General requirements	24
4.2 PMD general architecture	24
4.3 Classification of PMD	25
4.4 Structure of PMD	26
4.4.1 Structure of PMD related to sensors	26
4.4.2 Requirements for self-powered PMD	26
4.5 List of applicable performance classes	27
4.6 Operating and reference conditions for PMD	27
4.6.1 Reference conditions	27
4.6.2 Rated operating conditions	28
4.7 Start-up conditions	30
4.8 Requirements for PMD functions	30
4.8.1 General requirements	30
4.8.2 Active power (P) and active energy (E_A) measurements	31
4.8.3 Reactive power (Q_A , Q_V) and reactive energy (E_{rA} , E_{rV}) measurements	37
4.8.4 Apparent power (S_A , S_V) and apparent energy (E_{apA} , E_{apV}) measurements	40
4.8.5 Frequency (f) measurements	42
4.8.6 RMS phase current (I) and neutral current (I_N , I_{Nc}) measurements	43
4.8.7 RMS voltage (U) measurements	47
4.8.8 Power factor (PF_A , PF_V) measurements	49
4.8.9 Short term flicker (P_{st}) and long term flicker (P_{lt}) measurements	49
4.8.10 Voltage dip (U_{dip}) and voltage swell (U_{swl}) measurements	50
4.8.11 Voltage interruption (U_{int}) measurements	55
4.8.12 Transient overvoltage (U_{tr}) measurements	56
4.8.13 Voltage unbalance (U_{nb} , U_{nba}) measurements	56
4.8.14 Voltage harmonics (U_h) and voltage THD (THD_U and $THD-R_U$) measurements	57
4.8.15 Current unbalance (I_{nb} , I_{nba}) measurements	58
4.8.16 Current harmonics (I_h) and current THD (THD_i and $THD-R_i$) measurements	59

4.8.17	Minimum, maximum, peak, three-phases average and demand measurements	60
4.9	General mechanical requirements	60
4.9.1	Vibration requirements.....	60
4.9.2	IP requirements	60
4.10	Safety requirements	61
4.10.1	Protection against electrical hazards	61
4.10.2	Protection against mechanical hazards.....	62
4.10.3	Protection against other hazards	62
4.11	EMC requirements	62
4.11.1	Immunity.....	62
4.11.2	Emission.....	62
4.12	Inputs and/or outputs	62
4.12.1	General	62
4.12.2	Analog outputs	62
4.12.3	Pulse outputs.....	63
4.12.4	Control outputs	63
4.12.5	Analog inputs.....	63
4.12.6	Pulse and control inputs	63
5	Marking and operating instructions	63
5.1	General.....	63
5.2	Marking.....	63
5.3	Operating, installation and maintenance instructions.....	64
5.3.1	General	64
5.3.2	General characteristics	64
5.3.3	Essential characteristics	64
6	Tests	66
6.1	General.....	66
6.2	Type tests of PMD	67
6.2.1	General	67
6.2.2	Tests of intrinsic uncertainty	67
6.2.3	Tests of variation of uncertainty with influence quantities.....	67
6.2.4	Test of temperature influence	67
6.2.5	Active power.....	68
6.2.6	Apparent power	70
6.2.7	Power factor	71
6.2.8	Common mode voltage rejection test	71
6.2.9	Frequency	71
6.2.10	Measurement of voltage harmonics and THD_u	72
6.2.11	Measurement of current harmonics and THD_i	72
6.2.12	Dips and swells	73
6.2.13	Voltage interruptions.....	73
6.2.14	Outputs tests	73
6.2.15	Climatic tests.....	74
6.2.16	EMC tests.....	75
6.2.17	Start-up tests.....	75
6.2.18	Gapless measurement test	75
6.2.19	Safety tests	75
6.3	Routine tests.....	75

6.3.1	Protective bonding test	75
6.3.2	Dielectric strength test.....	76
6.3.3	Uncertainty test	76
Annex A (informative)	Metering, measuring and monitoring applications	77
A.1	Applications on demand side and supply side	77
A.2	Link between applications, devices and standards	77
Annex B (informative)	Definitions of electrical parameters	79
B.1	General.....	79
B.2	Definitions in the presence of a neutral	79
B.3	Power measurement in three-phase three-wire systems using the two-wattmeter method	83
B.3.1	General	83
B.3.2	Total active power	84
B.3.3	Total vector reactive power using quadrature phase shift definition	84
B.3.4	Total vector reactive power using Budeanu's definition	85
B.4	Additional relationships in case of sinusoidal voltage	85
Annex C (informative)	Convention about the sign of the power factor.....	86
C.1	General.....	86
C.2	Convention for power factor (consumer perspective).....	86
C.3	Convention for power factor (producer reference frame)	87
Annex D (normative)	Definitions of minimum, maximum, peak and demand values	89
D.1	Demand quantities	89
D.1.1	General	89
D.1.2	Power demand.....	89
D.1.3	Current demand.....	89
D.1.4	Thermal current demand (or bi-metal current demand).....	89
D.1.5	Specified intervals for demand calculation	89
D.2	Peak demand quantities.....	90
D.3	Three-phase average quantities	90
D.4	Maximum and minimum quantities	90
Annex E (informative)	Intrinsic uncertainty and operating uncertainty.....	91
E.1	General.....	91
E.2	Operating uncertainty calculation	91
Annex F (informative)	Recommended sensor classes for the different kinds of PMD	93
F.1	General considerations	93
F.2	Specific case of an active power and energy measurement, achieved by a PMD associated with an external current sensor or/and a voltage sensor	93
F.3	List of functions affected by uncertainty of external sensors.....	93
Annex G (informative)	Notion of measurement uncertainty	95
G.1	General considerations	95
G.2	Computing the expanded uncertainty	95
G.2.1	General	95
G.2.2	Estimated standard deviation.....	95
G.2.3	Expanded uncertainty	96
G.3	Determining the measurement uncertainty	97
G.3.1	Systematic error	97
G.3.2	Measurement uncertainty.....	97
G.4	Using the measurement uncertainty as a pass/fail criterion	98

G.4.1	Intrinsic uncertainty tests	98
G.4.2	Tests with influence quantities	98
G.4.3	Overall pass/fail criterion	98
Annex H (normative) Requirements for power metering and monitoring function (PMF) and additional requirements for equipment embedding power metering and monitoring function (EPMF)	100	
H.1	Scope	100
H.2	Normative references	100
H.3	Terms, definitions and notations	101
H.4	Requirements for PMF and additional requirements for EPMF	101
H.4.1	General requirements	101
H.4.2	EPMF general architecture	102
H.4.3	Classification of PMF	102
H.4.4	Structure of EPMF	103
H.4.5	List of applicable performance classes for PMF	103
H.4.6	Operating and reference conditions	103
H.4.7	Start-up conditions for EPMF	104
H.4.8	Requirements for PMF	104
H.4.9	General mechanical requirements	104
H.4.10	Safety requirements	104
H.4.11	EMC requirements	104
H.4.12	Inputs and/or outputs	104
H.5	Marking and operating instructions	105
H.5.1	General	105
H.5.2	Marking	105
H.5.3	Operating, installation and maintenance instructions	105
H.6	Tests	106
H.6.1	General	106
H.6.2	Type tests of EPMF	106
H.6.3	Routine tests of EPMF	108
Annex I (informative) Potential new requirements derived from IEC 62053-2x series of standards	109	
I.1	Scope	109
I.2	Future requirements for active power (P) and active energy (E_a) measurements	110
I.2.1	Future intrinsic uncertainty tables	110
I.2.2	Future limits of variations due to influence quantities	111
I.3	Future requirements for reactive power (Q) and reactive energy (E_r) measurements	116
I.3.1	Future intrinsic uncertainty tables	116
I.3.2	Limits of variation in percentage error due to influence quantities	116
Bibliography	119	
Figure 1 – PMD generic measurement chain	25	
Figure 2 – Description of different types of PMD	26	
Figure 3 – Relationship between ambient air temperature and relative humidity	30	
Figure 4 – Waveform for odd harmonics influence test on active power measurement	68	
Figure 5 – Spectral content for odd harmonics influence test on active power measurement	69	

Figure 6 – Waveform for sub-harmonics influence test on active power measurement.....	70
Figure 7 – Spectral content for sub-harmonics influence test on active power measurement.....	70
Figure 8 – Common mode voltage influence testing	71
Figure 9 – Waveform for harmonics influence test on frequency measurement.....	72
Figure A.1 – Simplified overview of measurement applications on supply side and demand side	77
Figure B.1 – Arithmetic and vector apparent powers in sinusoidal situation	83
Figure B.2 – Three-phase circuit without neutral	84
Figure C.1 – Formatting of power factor with a consumer perspective.....	86
Figure C.2 – Convention for power factor with a producer perspective	87
Figure D.1 – Thermal current demand.....	89
Figure D.2 – Fixed block interval.....	90
Figure D.3 – Sliding block interval.....	90
Figure E.1 – Different kinds of uncertainties.....	91
Figure E.2 – Flowchart for the determination of the operating uncertainty	92
Figure G.1 – Illustration of the notion of measurement uncertainty	97
Figure G.2 – Overview of the uncertainty test procedure	99
Figure H.1 – Example of architecture of EPMF	102

Table 1 – Functional classification of PMD with minimal required functions	25
Table 2 – Structure of PMD.....	26
Table 3 – List of applicable performance classes	27
Table 4 – Reference conditions for testing	28
Table 5 – Rated operating temperatures for portable equipment	28
Table 6 – Rated operating temperatures for fixed installed equipment	29
Table 7 – Humidity and altitude operating conditions	29
Table 8 – Intrinsic uncertainty table for active power and active energy measurement	32
Table 9 – Influence quantities for active power and active energy measurement (1 of 3).....	33
Table 10 – Minimum test period	36
Table 11 – Starting current for active power and active energy measurement	37
Table 12 – Intrinsic uncertainty table for reactive power and reactive energy measurement.....	37
Table 13 – Influence quantities for reactive power and reactive energy measurement.....	38
Table 14 – Minimum test period	39
Table 15 – Starting current for reactive energy measurement	40
Table 16 – Intrinsic uncertainty table for apparent power and apparent energy measurement.....	40
Table 17 – Influence quantities for apparent power and apparent energy measurement	41
Table 18 – Intrinsic uncertainty table for frequency measurement	42
Table 19 – Influence quantities for frequency measurement.....	43
Table 20 – Rated range of operation for phase current measurement	43
Table 21 – Rated range of operation for neutral current (calculated or measured).....	44
Table 22 – Intrinsic uncertainty table for phase current	44

Table 23 – Intrinsic uncertainty table for neutral current measurement.....	44
Table 24 – Intrinsic uncertainty table for neutral current calculation	45
Table 25 – Influence quantities for phase current and neutral current measurement	46
Table 26 – Rated range of operation for RMS voltage measurement	47
Table 27 – Intrinsic uncertainty table for RMS voltage measurement.....	47
Table 28 – Influence quantities for RMS voltage measurement	48
Table 29 – Intrinsic uncertainty table for power factor measurement	49
Table 30 – Intrinsic uncertainty table for flicker measurement	50
Table 31 – Rated range of operation for voltage dips and swells measurement.....	52
Table 32 – Intrinsic uncertainty table for voltage dips and swells measurement	53
Table 33 – Influence quantities for dips and swells measurement	54
Table 34 – Intrinsic uncertainty table for voltage interruption measurement	56
Table 35 – Intrinsic uncertainty table for transient overvoltage measurement.....	56
Table 36 – Intrinsic uncertainty table for voltage unbalance measurement	57
Table 37 – Rated range of operation for voltage harmonics measurement	57
Table 38 – Intrinsic uncertainty table for voltage harmonics measurement	57
Table 39 – Intrinsic uncertainty table for voltage THD_U or $THD-R_U$ measurement	58
Table 40 – Intrinsic uncertainty table for current unbalance measurement	58
Table 41 – Rated range of operation for current harmonics measurement.....	59
Table 42 – Intrinsic uncertainty table for current harmonics measurement	59
Table 43 – Intrinsic uncertainty table for current THD_I and $THD-R_I$ measurement	59
Table 44 – Minimum IP requirements for PMD	60
Table 45 – PMD specification form.....	65
Table 46 – Characteristics specification template.....	66
Table A.1 – Main measurement applications	78
Table B.1 – Definition of symbols.....	79
Table B.2 – Calculation definitions for electrical parameters	80
Table C.1 – Conventions for the sign of Power factor with a Consumer perspective	87
Table C.2 – Conventions for the sign of power factor with a producer perspective	88
Table F.1 – PMD SD associated with current sensor or PMD DS associated with voltage sensor or PMD SS associated with voltage and current sensors	93
Table F.2 – List of functions affected by uncertainty of external sensors	94
Table G.1 – Correction factor $C(N)$ for sample size N	96
Table H.1 – List of equipment that may embed EPMF	101
Table H.2 – Functional classification of PMF with minimal required functions.....	102
Table H.3 – Structure of EPMF	103
Table H.4 – Value of current according to the type of EPMF	104
Table H.5 – EPMF specification form	105
Table I.1 – Future intrinsic uncertainty table for active power and active energy measurement for classes $> 0,5$	110
Table I.2 – Future intrinsic uncertainty table for active power and active energy measurement for classes $\leq 0,5$	110
Table I.3 – Limits of variation in percentage error due to influence quantities for classes $> 0,5$	111

Table I.4 – Limits of variation in percentage error due to influence quantities for classes $\leq 0,5$	113
Table I.5 – Future intrinsic uncertainty table for reactive power and reactive energy measurement.....	116
Table I.6 – Limits of variation in percentage error due to influence quantities.....	116

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION
SYSTEMS UP TO 1 000 V AC AND 1 500 V DC. –
EQUIPMENT FOR TESTING, MEASURING OR
MONITORING OF PROTECTIVE MEASURES –**

Part 12: Power metering and monitoring devices (PMD)

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61557-12 edition 2.1 contains the second edition (2018-10) [documents 85/644/FDIS and 85/649/RVD] and its amendment 1 (2021-05) [documents 85/755/FDIS and 85/764/RVD].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 61557-12 has been prepared by IEC technical committee 85: Measuring equipment for electrical and electromagnetic quantities.

This second edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) PMD-A has been withdrawn due the fact these devices are now mainly covered by the IEC 62586 series of standards.
- b) Three categories of PMD have been created with a list of minimum required functions for each category.
- c) Added a new Annex A explaining the different applications linked to the relevant standards and devices, and another new Annex C about the power factor conventions.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61557 series, published under the general title *Electrical safety in low voltage distribution systems up to 1 000 V AC and 1 500 V DC – Equipment for testing, measuring or monitoring of protective measures*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Energy distribution systems need to guarantee energy efficiency, availability and network performances in order to address the following challenges:

- sustainable development requirements where energy measurement, for instance, is recognised as an essential element of energy management, part of the overall drive to reduce carbon emissions and to improve the commercial efficiency of manufacturing, commercial organizations and public services;
- technological evolutions (electronic loads, electronic measuring methods, etc.);
- end-users needs (cost saving, compliance with aspects of building regulations, etc.) regarding electrical energy management as well as other energies, or fluids. Other functionalities involving several non electrical parameters are often needed in parallel;
- safety and continuity of service;
- evolution of installation standards, for instance over-current detection is now a new requirement for the neutral conductor due to harmonic content.

Monitoring electrical quantities in internal networks allows to address these challenges.

The devices on the current market have different characteristics, which need a common system of references. Therefore there is a need for this document in order to facilitate the choices of the end-users in terms of performance, safety, interpretation of the indications, etc. This document provides a basis by which such devices can be specified and described, and their performance evaluated.

In order to fulfil the requirements of the energy efficiency project, many PMD measuring electrical parameters can also collect data (water, air, gas, temperature...) coming from other sensors or meters inside building or plant areas. In order to be able to transmit all these data to a supervision software it will be relevant to equip the PMD with a communication bus. The supervision software will then manage all the collected data in order to monitor them and produce useful reports for energy usage and consumption analysis.

**ELECTRICAL SAFETY IN LOW VOLTAGE DISTRIBUTION
SYSTEMS UP TO 1 000 V AC AND 1 500 V DC. –
EQUIPMENT FOR TESTING, MEASURING OR
MONITORING OF PROTECTIVE MEASURES –**

Part 12: Power metering and monitoring devices (PMD)

1 Scope

This part of IEC 61557 specifies requirements for power metering and monitoring devices (PMD) that measure and monitor the electrical quantities within electrical distribution systems, and optionally other external signals. These requirements also define the performance of PMD in single- and three-phase AC or DC systems having rated voltages up to 1 000 V AC or up to 1 500 V DC.

These devices are fixed or portable. They are intended to be used indoors and/or outdoors.

Power metering and monitoring devices (PMD), as defined in this document, give additional safety information, which aids the verification of the installation and enhances the performance of the distribution systems.

Additionally, this document specifies requirements for measurement functions dedicated to metering and monitoring of electrical parameters called power metering and monitoring function (PMF) which can be embedded in equipment (EPMF) that is not classified as PMD and for which the main function is not power metering and monitoring.

Requirements for power metering and monitoring function (PMF) and additional requirements for equipment embedding power metering and monitoring function (EPMF) are described in Annex H.

The power metering and monitoring devices (PMD) for electrical parameters described in this document are used for general industrial and commercial applications.

The power metering and monitoring devices (PMD) can be associated with sensing devices such as but not limited to instruments transformers compliant to IEC 61869 series of standards or with transducers compliant to IEC 60688.

This document does not address functional safety and cyber security aspects.

This document is not applicable ~~for~~ to:

- electricity metering equipment that complies with IEC 62053-21, IEC 62053-22, IEC 62053-23 and IEC 62053-24. Nevertheless, uncertainties defined in this document for active and reactive energy measurement are derived from those defined in IEC 62053 (all parts);
- the measurement and monitoring of electrical parameters defined in IEC 61557-2 to IEC 61557-9 and IEC 61557-13 or in IEC 62020;
- power quality instrument (PQI) according IEC 62586 (all parts);
- devices covered by IEC 60051 (all parts) (direct acting analogue electrical measuring instrument).

NOTE 1 Generally such types of devices are used in the following applications or for the following general needs:

- energy management inside the installation, such as facilitating the implementation of documents such as ISO 50001 and IEC 60364-8-1;
- monitoring and/or measurement of electrical parameters;
- measurement and/or monitoring of the quality of energy inside commercial/industrial installations.

NOTE 2 A measuring and monitoring device of electrical parameters usually consists of several functional modules. All or some of the functional modules are combined in one device. Examples of functional modules are:

- measurement and monitoring of several electrical parameters simultaneously;
- energy measurement and/or monitoring, as well as sometimes compliance with aspects of building regulations;
- alarms functions;
- demand side quality (current and voltage harmonics, over/under voltages, voltage dips and swells, etc.).

NOTE 3 PMD are historically called power meter, power monitor, power monitor device, power energy monitoring device, power analyser, multifunction meter, measuring multifunction equipment, energy meters.

NOTE 4 Metering, measuring and monitoring applications are explained in Annex A.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-1, *Environmental testing – Part 2-1: Tests – Test A: Cold*

IEC 60068-2-2, *Environmental testing – Part 2: Tests – Tests B: Dry heat*

IEC 60068-2-30, *Environmental testing – Part 2-30 – Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 61000-4-30:2015, *Electromagnetic compatibility (EMC) – Part 4-30: Testing and measurement techniques – Power quality measurement methods*

IEC 61010-1:2010, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*
IEC 61010-1:2010/AMD1:2016

IEC 61010-2-030:2017, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 2-030: Particular requirements for testing and measuring circuits*

IEC 61326-1:2012, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements*

IEC 62053-31:1998, *Electricity metering equipment (a.c.) – Particular requirements – Part 31: Pulse output devices for electromechanical and electronic meters (two wires only)*

3 Terms, definitions and notations

For the purposes of this document, the following terms, definitions and notations apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>