

Plastics piping systems for the supply of gaseous fuels -
Unplasticized polyamide (PA-U) piping systems with
fusion jointing and mechanical jointing - Part 5: Fitness
for purpose of the system (ISO 16486-5:2021)

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN ISO 16486-5:2021 sisaldab Euroopa standardi EN ISO 16486-5:2021 ingliskeelset teksti.	This Estonian standard EVS-EN ISO 16486-5:2021 consists of the English text of the European standard EN ISO 16486-5:2021.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 26.05.2021.	Date of Availability of the European standard is 26.05.2021.
Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 75.200, 83.140.30

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele. Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation: Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

Plastics piping systems for the supply of gaseous fuels -
Unplasticized polyamide (PA-U) piping systems with
fusion jointing and mechanical jointing - Part 5: Fitness for
purpose of the system (ISO 16486-5:2021)

Systèmes de canalisations en matières plastiques pour
la distribution de combustibles gazeux - Systèmes de
canalisations en polyamide non plastifié (PA-U) avec
assemblages par soudage et assemblages mécaniques -
Partie 5: Aptitude à l'emploi du système (ISO 16486-
5:2021)

Kunststoff-Rohrleitungssysteme für die Gasversorgung
- Rohrleitungssysteme aus weichmacherfreiem
Polyamid (PA-U) mit Schweißverbindungen und
mechanischen Verbindungen - Teil 5:
Gebrauchstauglichkeit des Systems (ISO 16486-
5:2021)

This European Standard was approved by CEN on 14 May 2021.

This European Standard was corrected and reissued by the CEN-CENELEC Management Centre on 21 July 2021.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

This document (EN ISO 16486-5:2021) has been prepared by Technical Committee ISO/TC 138 "Plastics pipes, fittings and valves for the transport of fluids" in collaboration with Technical Committee CEN/TC 155 "Plastics piping systems and ducting systems" the secretariat of which is held by NEN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2021, and conflicting national standards shall be withdrawn at the latest by November 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Endorsement notice

The text of ISO 16486-5:2021 has been approved by CEN as EN ISO 16486-5:2021 without any modification.

Annex (informative)

A-deviation

A-deviation: National deviation due to regulations, the alteration of which is for the time being outside the competence of the CEN-CENELEC national member.

This European Standard does not fall under any Directive of the EU.

In the relevant CEN-CENELEC countries these A-deviations are valid instead of the provisions of the European Standard until they have been removed.

Country	Clause	Deviation
ITALY	§1 Scope	<p>According to Italian legislation concerning the safety of gas installation</p> <ul style="list-style-type: none"> - DM 16 April 2008 (DSO) prescribes that piping and components used in distribution system shall be in accordance with national standard UNI 9034 (pipes with MOP below 5 bar). In case of MOP greater than 5 bar DM 17 April 2008 shall be followed. (Official Journal Italian Republic GU n. 107 of 8th May 2008 https://www.gazzettaufficiale.it/eli/id/2008/05/08/08A02871/sg) - DM 17 April 2008 (TSO) prescribes that piping and components used in transmission system shall be made of steel (art. 3.1 of Technical Annex A to Decree). (Official Journal Italian Republic GU n. 107 of 8th May 2008 https://www.gazzettaufficiale.it/atto/serie_generale/caricaDettaglioAtto/originario?atto.dataPubblicazioneGazzetta=2008-05-08&atto.codiceRedazionale=08A02872&elenco30giorni=false)

Contents

	Page
Foreword	iv
Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Symbols	3
5 Fitness for purpose	3
5.1 Method of preparation of assemblies for testing.....	3
5.1.1 General.....	3
5.1.2 Butt fusion joints.....	3
5.1.3 Electrofusion jointing.....	3
5.1.4 Transition fittings.....	4
5.2 Requirements for fitness for purpose.....	4
5.2.1 Fitness for purpose for butt fusion joints.....	4
5.2.2 Fitness for purpose for electrofusion joints.....	5
5.2.3 Fitness for purpose for transition fittings.....	7
6 Design coefficient	7
Annex A (normative) Preparation of test assemblies by butt fusion	8
Annex B (normative) Preparation of test assemblies by electrofusion	11
Annex C (informative) Derating coefficients for operating temperatures	12
Annex D (normative) Rapid crack propagation (RCP) resistance of pipe at temperature less than 0 °C	13
Bibliography	14

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fittings and valves for the transport of fluids*, Subcommittee SC 4, *Plastics pipes and fittings for the supply of gaseous fuels*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 155, *Plastics piping systems and ducting systems*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 16486-5:2012), which has been technically revised.

The main changes compared to the previous edition are as follows:

- for transition fittings, reference is made to ISO 17885;
- new [Clause 5](#), Design Coefficient, has been added;
- [Annex A](#) refers to ISO 11414 for test piece assemblies by butt fusion and has been brought in line with ISO 12176-1 for butt fusion equipment.
- [Annex A](#) has been brought in line with ISO 21307, with a definition of PA fusion parameters for the single low-pressure and the single high-pressure butt fusion jointing procedures (the dual low-pressure procedure is not investigated for PA-U so far);
- in [Table A.2](#) for the single low-pressure butt fusion procedure, the pressure, p_1 , has been changed from $(0,3 \pm 0,1)$ MPa to $(0,3 \pm 0,05)$ MPa to raise the minimum pressure from 0,2 MPa to 0,25 MPa;
- [Annex B](#) refers to ISO 11413 for test piece assemblies by electro fusion and to ISO 12176-2 for electro fusion equipment;
- Annex C of ISO 16486-5:2012, Assessment of fitness for purpose of transition fittings, has been deleted;
- new [Annex C](#), Derating coefficients for operating temperatures, has been transferred from ISO 16486-6;

- new [Annex D](#), Rapid crack propagation (RCP) resistance of pipe at temperature less than 0 °C, has been added.

A list of all parts in the ISO 16486 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document specifies the requirements for a piping system and its components made from unplasticized polyamide (PA-U), which is intended to be used for the supply of gaseous fuels.

Requirements and test methods for material and components of the piping system are specified in ISO 16486-1, ISO 16486-2, ISO 16486-3, and ISO 16486-4.

This document covers the characteristics for fitness for purpose of the system.

Recommended practice for installation is given in ISO 16486-6, which will not be implemented as European Standard under the Vienna Agreement.

NOTE Recommended practice for installation is also given in CEN/TS 12007-6, which has been prepared by Technical Committee CEN/TC 234, *Gas infrastructure*.

Assessment of conformity of the system is to form the subject the future ISO/TS 16486-7¹⁾.

1) Under preparation. Stage at the time of publication: ISO/AWI TS 16486-7:2021.

Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing —

Part 5: Fitness for purpose of the system

1 Scope

This document specifies the requirements of fitness for purpose of unplasticized polyamide (PA-U) piping system, intended to be buried and used for the supply of gaseous fuels. It also specifies the definitions of electrofusion and butt fusion joints.

This document specifies the method of preparation of test piece joints and the tests to be carried out on these joints for assessing the fitness for purpose of the system under normal and extreme conditions. It also specifies the test parameters for the test methods to which it refers.

The ISO 16486 series is applicable to PA-U piping systems, the components of which are connected by fusion jointing and/or mechanical jointing.

In conjunction with the other parts of ISO 16486, it is applicable to PA-U fittings, their joints and to joints with components of PA-U.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 1167-1, *Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 1: General method*

ISO 1167-4, *Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 4: Preparation of assemblies*

ISO 11413:2019, *Plastics pipes and fittings — Preparation of test piece assemblies between a polyethylene (PE) pipe and an electrofusion fitting*

ISO 11414:2009, *Plastics pipes and fittings — Preparation of polyethylene (PE) pipe/pipe or pipe/fitting test piece assemblies by butt fusion*

ISO 13953, *Polyethylene (PE) pipes and fittings — Determination of the tensile strength and failure mode of test pieces from a butt-fused joint*

ISO 13954, *Plastics pipes and fittings — Peel decohesion test for polyethylene (PE) electrofusion assemblies of nominal outside diameter greater than or equal to 90 mm*

ISO 13955, *Plastics pipes and fittings — Crushing decohesion test for polyethylene (PE) electrofusion assemblies*

ISO 13956, *Plastics pipes and fittings — Decohesion test of polyethylene (PE) saddle fusion joints — Evaluation of ductility of fusion joint interface by tear test*

ISO 16486-1, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 1: General*

ISO 16486-2, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 2: Pipes*

ISO 16486-3, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 3: Fittings*

ISO 16486-6, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 6: Code of practice for design, handling and installation*

ISO 17885, *Plastics piping systems — Mechanical fittings for pressure piping systems — Specifications*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 16486-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1 electrofusion joint

joint between a PA-U electrofusion socket or saddle fitting and a pipe or a spigot end fitting

Note 1 to entry: The electrofusion fittings are heated by the Joule effect of the heating element incorporated at their jointing surfaces, causing the material adjacent to them to melt and the pipe and fitting surfaces to fuse.

3.2 butt fusion joint

joint made by heating the planed ends of matching surfaces by holding them against a flat heating plate until the PA-U material reaches fusion temperature, quickly removing the heating plate and pushing the two softened ends against one another

Note 1 to entry: This definition refers to a butt fusion joint using a heating tool.

3.3 fusion compatibility

ability of two unplasticized polyamide materials of the same type to be fused together to form a joint which conforms to the performance requirements of this part of ISO 16486

3.4 transition fitting

factory-made fitting that makes a *transition joint* (3.5) between a unplasticized polyamide (PA-U) piping and a metallic pipe as described in ISO 16486-3

Note 1 to entry: The metallic parts of the fitting may be assembled to metallic pipes by screw threads, compression joints, welded or flanged connections. The fitting can allow for either a dismountable or permanently assembled joint. In some cases, the supporting ring may also act as a grip ring.

3.5 transition joint

joint at which two different piping materials (the PA-U and metal piping) are connected