

MOOTORIKÜTUSE TANKLAD. OSA 2: OHUTUSNÕUDED
TANKURITE JA ANNUSTITE KAITSESIDURITE
KOOSTULE JA KÄITUSELE

Petrol filling stations - Part 2: Safety requirements for
construction and performance of safe breaks for use on
metering pumps and dispensers

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 13617-2:2021 sisaldab Euroopa standardi EN 13617-2:2021 ingliskeelset teksti.	This Estonian standard EVS-EN 13617-2:2021 consists of the English text of the European standard EN 13617-2:2021.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 15.09.2021.	Date of Availability of the European standard is 15.09.2021.
Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 75.200

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autoriõiguse kaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about standards copyright protection, please contact the Estonian Centre for Standardisation and Accreditation: Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

**Petrol filling stations - Part 2: Safety requirements for
construction and performance of safe breaks for use on
metering pumps and dispensers**

Stations-service - Partie 2 : Exigences de sécurité
relatives à la construction et aux performances des
raccords cassants utilisés pour les distributeurs de
carburants

Tankstellen - Teil 2: Sicherheitstechnische
Anforderungen an Bau- und Arbeitsweise von
Abreißkupplungen für Zapfsäulen und druckversorgte
Zapfsäulen

This European Standard was approved by CEN on 14 June 2021.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	6
4 Explosion protection measures	7
5 Construction	7
5.1 General	7
5.2 Hose breaks	7
5.3 Inlet threads	8
5.3.1 Safe break type 1	8
5.3.2 Safe break type 2	9
6 Physical properties	9
7 Operational requirements	10
8 Overview of tests	11
9 Information for use	12
9.1 General	12
9.2 Marking and instruction	12
10 Environmental aspects	12
Annex A (normative) General requirements of test	13
A.1 General	13
A.2 Tightness test 1	13
A.3 Pressure separation test 1	13
Annex B (normative) Tests	14
B.1 Test liquid	14
B.2 Liquid compatibility pre-conditioning	14
B.3 Pre-conditioning of re-usable safe breaks by a mechanical impact test	14
B.4 Tightness test 2	15
B.5 Pressure separation test 2	15
B.6 Pressure test	15
B.7 Axial separation force test 1	15
B.8 Axial separation force test 2 to nozzle breaks and pump breaks	16
B.9 Non-axial separation force test 1 to nozzle breaks and pump breaks	16
B.10 Non-axial separation force test 2 to nozzle breaks and pump breaks	16
B.11 Axial separation force test 3	16
B.12 Axial separation force test 4	17
B.13 Liquid release test	17

B.14	Re-connection test 1	17
B.15	Re-connection test 2	17
B.16	Electrical resistance test	18
Annex C (informative)	Environmental aspects	19
Annex ZA (informative)	Relationship between this European Standard and the essential requirements of Directive 2014/34/EU aimed to be covered	21
Bibliography	23

European foreword

This document (EN 13617-2:2021) has been prepared by Technical Committee CEN/TC 393 “Equipment for storage tanks and for filling stations”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by March 2022, and conflicting national standards shall be withdrawn at the latest by March 2024.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 13617-2:2012.

In comparison with the 2012 edition, the following significant changes were made:

- safe breaks for aqueous urea solution added;
- Table 1 corrected to ensure compatibility between components according to EN 13012:2021, EN 13617-2:2021, EN 13617-4:2021 and EN 1360:2013;
- the production acceptance tests are modified to test at least every 500th unit;
- the liquid compatibility preconditioning fluid for fuel safe breaks is defined in EN 13617-1.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive 2014/34/EU.

For relationship with EU Directive, see informative Annex ZA, which is an integral part of this document.

EN 13617 consists of four parts:

- *Part 1: Safety requirements for construction and performance of metering pumps, dispensers and remote pumping units;*
- *Part 2: Safety requirements for construction and performance of safe breaks for use on metering pumps and dispensers;*
- *Part 3: Safety requirements for construction and performance of shear valves;*
- *Part 4: Safety requirements for construction and performance of swivels for use on metering pumps and dispensers.*

Any feedback and questions on this document should be directed to the users’ national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This document specifies safety requirements for the construction and performance of safe breaks to be fitted to metering pumps and dispensers installed at filling stations and used to dispense liquid fuels and aqueous urea solution into the tanks of motor vehicles, boats and light aircraft and into portable containers at flow rates up to $200 \text{ l} \cdot \text{min}^{-1}$.

This document applies to fuels of subdivision Group IIA according to EN ISO/IEC 80079-20-1 and also aqueous urea solution according to ISO 22241-1.

The requirements apply to safe breaks at ambient temperatures from -20°C to $+40^\circ\text{C}$ with the possibility for an extended temperature range.

This document pays particular attention to electrical, mechanical and hydraulic characteristics of, and electrical equipment incorporated within or mounted on, the safe break.

This document applies mainly to hazards related to the ignition of liquid fuels being dispensed or their vapour. This document also addresses electrical and mechanical hazards.

This document does not apply to equipment dispensing compressed or liquefied gases.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1127-1:2019, *Explosive atmospheres - Explosion prevention and protection - Part 1: Basic concepts and methodology*

EN 1360:2013, *Rubber and plastic hoses and hose assemblies for measured fuel dispensing systems - Specification*

EN 13483:2013, *Rubber and plastic hoses and hose assemblies with internal vapour recovery for measured fuel dispensing systems - Specification*

EN 13617-1:2021, *Petrol filling stations - Part 1: Safety requirements for construction and performance of metering pumps, dispensers and remote pumping units*

EN IEC 60079-0:2018, *Explosive atmospheres - Part 0: Equipment - General requirements (IEC 60079-0:2017)*

EN ISO 228-1:2003, *Pipe threads where pressure-tight joints are not made on the threads - Part 1: Dimensions, tolerances and designation (ISO 228-1:2000)*

EN ISO 1825:2017, *Rubber hoses and hose assemblies for aircraft ground fuelling and defuelling - Specification (ISO 1825:2017)*

EN ISO 8031:2020, *Rubber and plastics hoses and hose assemblies - Determination of electrical resistance and conductivity (ISO 8031:2020)*

EN ISO 80079-36:2016, *Explosive atmospheres - Part 36: Non-electrical equipment for explosive atmospheres - Basic method and requirements (ISO 80079-36:2016)*

ISO 261:1998, *ISO general purpose metric screw threads — General plan*

ISO 965-2:1998, *ISO general purpose metric screw threads — Tolerances — Part 2: Limits of sizes for general purpose external and internal screw threads — Medium quality*

ISO 11925-3:1997, *Reaction to fire tests — Ignitability of building products subjected to direct impingement of flame — Part 3: Multi-source test*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 13617-1:2021 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1

safe break

device to minimize fuel spillage and to stop fuel flow achieved by separation between nozzle and metering pump or dispenser within a defined range of forces

3.2

safe break type 1

safe break constructed for liquid lines only

3.3

safe break type 2

safe break constructed for liquid lines combined with vapour recovery lines

3.4

nozzle break

safe break fitted directly into the nozzle inlet, or integral with the nozzle

3.5

hose break

safe break fitted within the delivery hose circuit

3.6

pump break

safe break fitted directly to the fixed hydraulics

3.7

re-usable safe break

safe break that, once operated, can be re-assembled for further use

3.8

non re-usable safe break

safe break that, once operated, cannot be re-assembled for further use