

Extended application of results from fire resistance tests for service installations - Part 5: Combined penetration seals

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 15882-5:2021 sisaldab Euroopa standardi EN 15882-5:2021 ingliskeelset teksti.	This Estonian standard EVS-EN 15882-5:2021 consists of the English text of the European standard EN 15882-5:2021.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 13.10.2021.	Date of Availability of the European standard is 13.10.2021.
Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 13.220.99

**Standardite reproduutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele**

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonisesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autoriõiguse kaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega:  
Koduleht [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

**The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation**

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about standards copyright protection, please contact the Estonian Centre for Standardisation and Accreditation:  
Homepage [www.evs.ee](http://www.evs.ee); phone +372 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

EUROPEAN STANDARD  
NORME EUROPÉENNE  
EUROPÄISCHE NORM

EN 15882-5

October 2021

ICS 13.220.99

English Version

Extended application of results from fire resistance tests  
for service installations - Part 5: Combined penetration  
seals

Application étendue des résultats des essais de  
résistance au feu des installations de service - Partie 5 :  
Calfeutrements de trémie combinés

Erweiterter Anwendungsbereich der Ergebnisse aus  
Feuerwiderstandsprüfungen für Installationen - Teil 5:  
Kombinierte Abschottungen

This European Standard was approved by CEN on 25 July 2021.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

## Contents

	Page
<b>European foreword .....</b>	<b>3</b>
<b>1 Scope.....</b>	<b>4</b>
<b>2 Normative references.....</b>	<b>4</b>
<b>3 Terms and definitions.....</b>	<b>5</b>
<b>4 Extended application principles .....</b>	<b>5</b>
<b>5 Pre-conditions for extended application — Fire Resisting Ducts (ventilation ducts). 6</b>	<b>6</b>
<b>5.1 Basic tests required .....</b>	<b>6</b>
<b>5.2 Additional collaborative test requirements for the EXAP test with respect to fire resisting ducts (ventilation ducts).....</b>	<b>7</b>
<b>6 Specific rules to be applied to combined penetration applications — Fire resisting ducts .....</b>	<b>15</b>
<b>6.1 General.....</b>	<b>15</b>
<b>6.2 Service penetration field of extended application (permitted variations) .....</b>	<b>16</b>
<b>7 Pre-conditions for extended application — Fire dampers .....</b>	<b>17</b>
<b>7.1 Basic tests required .....</b>	<b>17</b>
<b>7.2 Additional collaborative test requirements for the EXAP test with respect to fire dampers general .....</b>	<b>19</b>
<b>8 Specific rules to be applied to combined penetration applications — Fire dampers</b>	<b>26</b>
<b>8.1 General.....</b>	<b>26</b>
<b>8.2 Field of extended application .....</b>	<b>27</b>
<b>9 Extended application report.....</b>	<b>29</b>
<b>Annex A (informative) Examples of the EXAP field of application — Explanatory notes .....</b>	<b>30</b>
<b>A.1 Worked example table .....</b>	<b>30</b>
<b>A.2 EXAP field application flow chart.....</b>	<b>32</b>
<b>A.3 Template for worked example.....</b>	<b>32</b>
<b>Annex B (normative) Combined penetration seal EXAP test setup and requirements — Explanatory notes.....</b>	<b>35</b>
<b>B.1 General.....</b>	<b>35</b>
<b>B.2 Test furnace .....</b>	<b>35</b>
<b>B.3 Fire resisting duct and service combinations.....</b>	<b>35</b>
<b>B.4 Fire damper and service combinations .....</b>	<b>36</b>
<b>B.5 Penetration sealing system .....</b>	<b>36</b>
<b>Bibliography .....</b>	<b>37</b>

## European foreword

This document (EN 15882-5:2021) has been prepared by Technical Committee CEN/TC 127 "Safety in fire", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2022, and conflicting national standards shall be withdrawn at the latest by April 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This series has the general title *Extended application of results from fire resistance tests for service installations* and consists of the following parts:

- Part 1: Fire resisting ducts
- Part 2: Fire dampers
- Part 3: Penetration seals
- Part 5: Combined penetration seals

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## 1 Scope

The purpose of this document is to provide the principles and guidance for the preparation of extended application documents for combined penetration seals where the systems were tested in accordance with (EN 1366-3 and EN 1366-1) or (EN 1366-3 and EN 1366-2). The field of the extended application document is additional to the direct field of application given within EN 1366-1, EN 1366-2 and EN 1366-3 and can be applied on a number of tests from each standard, which provide the relevant information for the formulation of an extended application.

This EXAP is intended to allow the penetration sealing of more than one service (e.g. cables, pipes, conduits) and four-sided fire resisting ducts (ventilation ducts) or fire dampers in the same penetration.

This EXAP is not used for extended applications in accordance with EN 1366-8, EN 1366-10 and/or EN 1366-12 (this will be dealt with in the next revision of the standard).

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1, *Fire resistance tests - Part 1: General requirements*

EN 1363-2, *Fire resistance tests - Part 2: Alternative and additional procedures*

EN 1366-1, *Fire resistance tests for service installations — Part 1: Ventilation ducts*

EN 1366-2, *Fire resistance tests for service installations - Part 2: Fire dampers*

EN 1366-3, *Fire resistance tests for service installations - Part 3: Penetration seals*

EN 15882-1, *Extended application of results from fire resistance tests for service installations — Part 1: Ducts*

EN 13501-1, *Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests*

EN 13501-2, *Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services*

EN ISO 13943, *Fire safety - Vocabulary (ISO 13943)*