

Fire resistance tests for service installations - Part 11:
Fire protective systems for cable systems and
associated components

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 1366-11:2018+A1:2021 sisaldab Euroopa standardi EN 1366-11:2018+A1:2021 ingliskeelset teksti.	This Estonian standard EVS-EN 1366-11:2018+A1:2021 consists of the English text of the European standard EN 1366-11:2018+A1:2021.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 22.12.2021.	Date of Availability of the European standard is 22.12.2021.
Standard on kättesaadav Eesti Standardimis- ja Akrediteerimiskeskusest.	The standard is available from the Estonian Centre for Standardisation and Accreditation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 13.220.50, 29.060.20, 91.140.50

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis- ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autoriõiguse kaitse kohta, võtke palun ühendust Eesti Standardimis- ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about standards copyright protection, please contact the Estonian Centre for Standardisation and Accreditation: Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

**Fire resistance tests for service installations - Part 11: Fire
protective systems for cable systems and associated
components**

Essais de résistance au feu des installations de service -
Partie 11 : Systèmes de protection incendie pour les
systèmes de câbles et composants associés

Feuerwiderstandsprüfungen für Installationen - Teil
11: Brandschutzsysteme für Kabelanlagen und
zugehörige Komponenten

This European Standard was approved by CEN on 9 April 2017 and includes Amendment 1 approved by CEN on 22 November 2021.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	4
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms and definitions	7
4 Test equipment	9
4.1 Furnace	9
5 Test conditions	9
5.1 Heating conditions	9
5.2 Pressure conditions	9
6 Test specimen	9
6.1 Dimensions	9
6.2 Number of tests	9
6.3 Design	9
7 Installation of test specimen	10
7.1 Fire protective system with cables	10
7.2 Fire protective systems with busbars	12
7.3 Special cases	12
8 Conditioning	13
9 Application of instrumentation	13
9.1 Furnace thermocouples (plate thermocouples)	13
9.2 Preheating inside the fire protective system	13
9.3 Additional thermocouples	13
10 Test procedure	14
10.1 General	14
10.2 Power supply	14
10.2.1 General	14
10.2.2 Continuity and short circuit checking arrangement for power cables	14
10.2.3 Continuity and short circuit checking arrangement for signal/control cables	15
10.2.4 Continuity and short circuit checking arrangement for busbars	16
11 Performance criteria	16
12 Test report	16
13 Field of direct application of test results	17
13.1 Types of cables	17
13.2 Application of test results of four-sided, three sided or two-sided fire protective systems	17
13.3 Assembly of fire protective system	19
13.4 Fixing of fire protective system to wall and ceiling	20
13.5 Types of cable management systems / busbars and load inside the fire protective system	21

13.6	Types of suspension device	21
13.7	Adjoining construction	22
13.8	Dimension of fire protective systems	23
13.9	Orientation of fire protective systems for cables and busbars	23
13.10	Special cases	23
13.10.1	Ventilation devices and inspection hatches	23
13.10.2	Removable lid	23
13.10.3	Penetrating systems	23
Annex A (informative)	Thermocouples inside the fire protective systems	31
Annex B (informative)	Preheating	32
Annex C (informative)	Performance criteria for communication/data cables	33
Bibliography		34

European foreword

This document (EN 1366-11:2018+A1:2021) has been prepared by Technical Committee CEN/TC 127, "Fire safety in buildings" the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2022 and conflicting national standards shall be withdrawn at the latest by June 2022.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1366-11:2018.

This document includes Amendment 1 approved by CEN on 22 November 2021.

The start and finish of text introduced or altered by amendment is indicated in the text by tags **A1** and **A1**.

The EN 1366 series, *Fire resistance tests for service installations* consists of the following:

Part 1: Ducts

Part 2: Fire dampers

Part 3: Penetration seals

Part 4: Linear joint seals

Part 5: Service ducts and shafts

Part 6: Raised access floors and hollow floors

Part 7: Closures for conveyors and trackbound transportation systems

Part 8: Smoke extraction ducts

Part 9: Single compartment smoke extraction ducts

Part 10: Smoke control dampers

Part 11: Fire protective systems for cable systems and associated components

Any feedback and questions on this document should be directed to the users' national standards body. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

The purpose of this test is to evaluate the ability of the protective system to allow cables and components of their installation (connectors, glands, junctions, mountings, etc.) to maintain during a defined time a reliable function whilst exposed to fire. The purpose of this test is to verify compliance with requirements regarding the circuit integrity of systems for example as those for firefighting lifts, pressure boosters, emergency lighting, fire alarm systems etc.

The fire exposure conditions and general arrangement in this European Standard are similar to those given in EN 50577, developed by CLC/TC 20, and prCLC/TR 50658 under development by CLC/TC 213. Each of these standards has been developed under a Mode 4 co-operation between CEN TC 127, CLC/TC 213 and CLC/TC 20.

CAUTION: The attention of all persons concerned with managing and carrying out this fire resistance test is drawn to the fact that fire testing may be hazardous and that there is a possibility that toxic and/or harmful smoke and gases may be evolved during the test. Mechanical and operational hazards may also arise during the construction of the test elements or structures, their testing and disposal of test residues.

An assessment of all potential hazards and risks to health should be made and safety precautions should be identified and provided. Written safety instructions should be issued. Appropriate training should be given to relevant personnel. Laboratory personnel should ensure that they follow written safety instructions at all times.

1 Scope

This European Standard describes the method to evaluate the performance of protective systems for electrical cable and busbar systems in order to maintain the circuit integrity under fire conditions to classify the protective system according to EN 13501-3 for the P classification. The test examines the behaviour of cable protection systems exposed to fire from outside. The tests specified in this standard are not aimed for assessing the performance of the fire protective system and the penetration seal for maintaining the requirements of the penetrated wall or ceiling (classification E / I).

This method is very different to EN 50200 for the PH classification and also to IEC 60331-11, IEC 60331-21, IEC 60331-23, and IEC 60331-25, which are not designed for fire protective systems for electrical cable systems.

This standard should be used in conjunction with EN 1363-1.

The test results apply to fire protective systems for electrical cable systems rated for voltages up to 1 kV.

The test procedure should also be used to determine the performance of protective systems for use with data and optical cables, however, verification procedures for such cables are still under development. Proposals are given in Annex C.

The protective system may include ventilation devices, inspection hatches, fixed or removable lids etc.

The tests specified in this standard are not aimed for assessing the performance of sprayed or painted coatings (e.g. intumescent or ablative coating, plastic film, epoxy resin) and similar protective layers (e.g. wrap, bandage) applied directly on the cables or bus bars as fire protective system. Also, cables and bus bars with intrinsic resistance to fire, and without fire protective systems around, are excluded (see CENELEC standard EN 50577).

This test method is not applicable for cabinets for electrical accessory containing bus systems, relays or similar.

A1 The cables identified in this document are for testing only. It is not intended that they shall be used in protective systems installed in buildings. **A1**

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1, *Fire resistance tests - Part 1: General Requirements*

EN 1363-2, *Fire resistance tests - Part 2: Alternative and additional procedures*

A1 EN 1364-1, *Fire resistance tests for non-loadbearing elements — Part 1: Walls*

EN 13501-2, *Fire classification of construction products and building elements — Part 2: Classification using data from fire resistance tests, excluding ventilation services* **A1**

EN 13501-3, *Fire classification of construction products and building elements - Part 3: Classification using data from fire resistance tests on products and elements used in building service installations: fire resisting ducts and fire dampers*

EN 50288-7, *Multi-element metallic cables used in analogue and digital communication and control - Part 7: Sectional specification for instrumentation and control cables*

EN 50525-2-11, *Electric cables - Low voltage energy cables of rated voltages up to and including 450/750 V (U₀/U) - Part 2-11: Cables for general applications - Flexible cables with thermoplastic PVC insulation*

EN 60269-1, *Low-voltage fuses - Part 1: General requirements (IEC 60269-1)*

EN 61537, *Cable management - Cable tray systems and cable ladder systems (IEC 61537)*

EN ISO 13943, *Fire safety - Vocabulary (ISO 13943)*

HD 603 S1, *Distribution cables of rated voltage 0,6/1 kV*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1363-1, EN ISO 13943, and the following, apply.

3.1

fire protective system

heat-insulating assembly of flexible or rigid materials inside which cables or cable management systems or busbars are arranged

Note 1 to entry: The protective system may be ducts, shafts, conduits, trunkings, or similar systems.

3.2

duct

horizontal self-supporting enclosure made of rigid boards or slabs for combustible or non-combustible cables or busbars with or without suspension device

Note 1 to entry: Jacket enclosures are included.

3.3

range of ducts

ducts with different cross sectional area and with the same thickness of the protective system for a given fire rating

3.4

shaft

vertical self-supporting enclosure made of rigid boards or slabs for combustible or non-combustible cables or busbars with or without suspension device

Note 1 to entry: Jacket enclosures are included.

3.5

suspension device

mechanical support provided in the form of clips, ties, hangers, ladder racks or trays, or any device designed to carry the load of the cables and the protective system

3.6

conductor

part of a cable which has the specific function of carrying current