

ÜLERÕHU KAITSESEADMED. OSA 10: KAITSEKLAPPIDE
JA KAITSEMEMBRAANIDE SUURUSE MÄÄRAMINE
GAASI/VEDELIKU KAHEFAASILISELE VOOLULE

Safety devices for protection against excessive
pressure - Part 10: Sizing of safety valves and bursting
discs for gas/liquid two-phase flow (ISO
4126-10:2024)

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>See Eesti standard EVS-EN ISO 4126-10:2024 sisaldab Euroopa standardi EN ISO 4126-10:2024 ingliskeelset teksti.</p> <p>Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.</p> <p>Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 03.04.2024.</p> <p>Standard on kättesaadav Eesti Standardimis-ja Akrediteerimiskeskusest.</p>	<p>This Estonian standard EVS-EN ISO 4126-10:2024 consists of the English text of the European standard EN ISO 4126-10:2024.</p> <p>This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation and Accreditation.</p> <p>Date of Availability of the European standard is 03.04.2024.</p> <p>The standard is available from the Estonian Centre for Standardisation and Accreditation.</p>
---	---

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 13.240

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardimis- ja Akrediteerimiskeskusele. Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardimis-ja Akrediteerimiskeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardimis-ja Akrediteerimiskeskusega: Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee.

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation and Accreditation. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation and Accreditation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation and Accreditation: Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee.

English Version

Safety devices for protection against excessive pressure -
Part 10: Sizing of safety valves and bursting discs for
gas/liquid two-phase flow (ISO 4126-10:2024)

Dispositifs de sécurité pour protection contre les
pressions excessives - Partie 10: Dimensionnement des
soupapes de sûreté et des disques de rupture pour les
débits diphasiques gaz/liquide (ISO 4126-10:2024)

Sicherheitseinrichtungen gegen unzulässigen
Überdruck - Teil 10: Auslegung von Sicherheitsventilen
und Berstscheiben bei Zweiphasenströmung
(flüssig/gas) (ISO 4126-10:2024)

This European Standard was approved by CEN on 2 October 2023.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

European foreword

This document (EN ISO 4126-10:2024) has been prepared by Technical Committee ISO/TC 185 "Safety devices for protection against excessive pressure" in collaboration with Technical Committee CEN/TC 69 "Industrial valves" the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2024, and conflicting national standards shall be withdrawn at the latest by October 2024.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a standardization request addressed to CEN by the European Commission. The Standing Committee of the EFTA States subsequently approves these requests for its Member States.

For the relationship with EU Legislation, see informative Annex ZA, which is an integral part of this document.

Any feedback and questions on this document should be directed to the users' national standards body/national committee. A complete listing of these bodies can be found on the CEN website.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Türkiye and the United Kingdom.

Endorsement notice

The text of ISO 4126-10:2024 has been approved by CEN as EN ISO 4126-10:2024 without any modification.

Contents

Page

Foreword	v
Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
3.1 General	1
3.2 Pressure	2
3.3 Flow rate	4
3.4 Flow area	5
3.5 Fluid state	5
3.6 Temperature	5
4 Symbols and abbreviated terms and figures	6
4.1 Symbols	6
4.2 Abbreviated terms	8
4.3 Figures	9
5 Application range of the method	11
5.1 General	11
5.2 Limitations of the method for calculating the two-phase mass flux in safety devices	11
5.2.1 Flashing flow	11
5.2.2 Condensing flow	12
5.2.3 Flashing flow for multi-component liquids	12
5.2.4 Dissolved gases	12
5.2.5 Compressibility coefficient ω	13
5.3 Limitations of the method for calculating the mass flow rate required to be discharged	13
5.3.1 Rate of temperature and pressure increase	13
5.3.2 Immiscible liquids	13
6 Sizing steps	13
6.1 General outline of sizing steps	13
6.2 Step 1 — Identification of the sizing case	14
6.3 Step 2 — Flow regime at the inlet of the vent line system	15
6.3.1 General	15
6.3.2 Phenomenon of level swell	15
6.3.3 Influence of liquid viscosity and foaming behaviour on the flow regime	15
6.3.4 Prediction of the flow regime (gas/vapour or two-phase flow)	17
6.4 Step 3 — Calculation of the mass flow rate required to be discharged	20
6.4.1 General	20
6.4.2 Pressure increase caused by an excess in-flow	20
6.4.3 Pressure increase due to external heating	22
6.4.4 Pressure increase due to thermal runaway reactions	25
6.5 Step 4 — Calculation of the dischargeable mass flux through and pressure change in the vent line system	29
6.5.1 General	29
6.5.2 Two-phase flow discharge coefficient, $K_{dr,2ph}$	32
6.5.3 Dimensionless mass flow rate, C	33
6.5.4 Compressibility coefficient, ω (numerical method)	34
6.5.5 Calculation of the downstream stagnation condition	35
6.5.6 Slip correction for non-flashing two-phase flow	35
6.5.7 Slip correction for two-phase flow in straight pipes	36
6.6 Step 5 — Ensure proper operation of safety valve vent line systems under plant conditions	36
6.7 Simultaneous calculation of the dischargeable mass flux and pressure change in the vent line system	36
6.8 Summary of calculation procedure	37

Annex A (informative) Identification of sizing scenarios	44
Annex B (informative) Example calculation of the mass flow rate to be discharged.....	46
Annex C (informative) Example of calculation of the dischargeable mass flux and pressure change through connected vent line systems.....	50
Annex D (informative) Environmental factor.....	67
Bibliography.....	68

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 185, *Safety devices for protection against excessive pressure*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 69, *Industrial valves*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 4126-10:2010), which has been technically revised.

The main changes are as follows:

- opening of the method for sizing of bursting discs;
- more thorough iteration for the calculation of the flow rate;
- allowing for slip;
- allowing for velocity in the outlet line and pressure losses in front and after the safety device;
- added an example for flow rate to be discharged ([Annex B](#));
- added an example for dischargeable mass flow rate added and method to estimate pressure drop in pipe flow ([Annex C](#));
- various correction.

A list of all parts in the ISO 4126 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

Well-established recommendations exist for the sizing of safety valves and bursting discs and the connected inlet and outlet lines for steady-state, single-phase gas/vapour or liquid flow. However, in the case of a two-phase vapour/liquid flow, the required relieving area to protect a system from overpressure is larger than that required for single-phase flow when the same vessel condition and heat release are considered. The requirement for a larger relief area results from the fact that, in two-phase flow, the liquid partially blocks the relieving area for the vapour flow, by which most of the energy is removed by evaporation from the vessel.

This document includes a widely applicable method for the sizing of the most typical safety valves and bursting discs in fluid services encountered in various industrial fields (see [Table 1](#)). It is based on the omega parameter method, which is extended by a thermodynamic non-equilibrium parameter. A balance is attempted between the accuracy of the method and the unavoidable uncertainties in the input and property data under the actual sizing conditions.

In case of two-phase flow, the safety device size can influence the fluid state and, hence, the mass flow rate to be discharged. Furthermore, the two-phase mass flow rate through a safety device essentially depends on the mass flow quality (mass fraction of vapour) of the fluid at the inlet of the device. Because these parameters are, in most cases, not readily at hand during the design procedure of a relief device, this document also includes a comprehensive procedure that covers the determination of the fluid-phase composition at the safety device inlet. This fluid-phase composition depends on a scenario that leads to the pressure increase. Therefore, the recommended sizing procedure starts with the definition of the sizing case and includes a method for the prediction of the mass flow rate required to be discharged and the resulting mass flow quality at the inlet of the safety device.

The formulae of ISO 4126-7:2013/Amd 1:2016 for single-phase flow up to the narrowest flow cross-section are included in this document, modified to SI units, to calculate the flow rates at the limiting conditions of single-phase gas and liquid flow.

In this document, the unit bar for pressures is being used $100\,000\text{ Pa} = 1\text{ bar}$.

Table 1 — Possible fluid state at the inlet of the safety valve or bursting disc that can result in two-phase flow

Fluid state at device inlet	Cases	Examples
liquid	subcooled (possibly flashing in the safety device) saturated with dissolved gas	cold water boiling water CO ₂ /water
gas/vapour	near saturated vapour (possibly condensing in the safety device)	steam
gas/liquid	vapour/liquid non-evaporating liquid and non-condensable gas (constant quality) gas/liquid mixture, when gas is desorbed or produced	steam/water air/water

Safety devices for protection against excessive pressure —

Part 10:

Sizing of safety valves and bursting discs for gas/liquid two-phase flow

1 Scope

This document specifies the sizing of safety valves and bursting discs for gas/liquid two-phase flow in pressurized systems such as reactors, storage tanks, columns, heat exchangers, piping systems or transportation tanks/containers, see [Figure 2](#). The possible fluid states at the safety device inlet that can result in two-phase flow are given in [Table 1](#).

NOTE The pressures used in this document are absolute pressures, not gauge pressures.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 4126-7:2013/Amd 1:2016, *Safety devices for protection against excessive pressure — Part 7: Common data*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 4126-7:2013/Amd 1:2016 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 General

3.1.1

pressurized system

equipment being protected against excessive pressure accumulation by a safety device

EXAMPLE Equipment can be reactors, storage tanks, columns, heat exchangers, piping systems and transport tanks/containers, etc.

3.1.2

critical filling threshold

ϕ_{limit}

maximum initial liquid filling threshold (liquid hold-up) in the *pressurized system* ([3.1.1](#)) at sizing conditions, up to where vapour disengagement occurs and single-phase gas or vapour flow can be expected

Note 1 to entry: The critical filling threshold is expressed as a ratio of the total volume of the system.

Note 2 to entry: For filling levels above the critical filling threshold, two-phase flow is assumed to occur.