

# INTERNATIONAL STANDARD



This extended version of IEC 61439-3:2024 includes the content of the references made to IEC 61439-1:2020

## Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO)



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

#### IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

#### IEC Products & Services Portal - [products.iec.ch](http://products.iec.ch)

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

# INTERNATIONAL STANDARD



This extended version of IEC 61439-3:2024 includes the content of the references made to IEC 61439-1:2020

## **Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO)**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

ICS 29.130.20

ISBN 978-2-8322-8671-5

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	9
1 Scope.....	12
2 Normative references .....	12
3 Terms and definitions .....	16
3.1 General terms .....	16
3.2 Constructional units of assemblies .....	19
3.3 External design of assemblies.....	20
3.4 Structural parts of assemblies.....	21
3.5 Conditions of installation of assemblies .....	22
3.6 Insulation characteristics .....	22
3.7 Protection against electric shock.....	25
3.8 Characteristics.....	29
3.9 Verification .....	33
3.10 Manufacturer .....	34
4 Symbols and abbreviations.....	34
5 Interface characteristics .....	35
5.1 General.....	35
5.2 Voltage ratings.....	36
5.2.1 Rated voltage ( $U_n$ ) (of the assembly).....	36
5.2.2 Rated operational voltage ( $U_e$ ) (of a circuit of an assembly) .....	36
5.2.3 Rated insulation voltage ( $U_i$ ) (of a circuit of an assembly).....	36
5.2.4 Rated impulse withstand voltage ( $U_{imp}$ ) (of the assembly) .....	36
5.3 Current ratings.....	36
5.3.1 Rated current of an assembly ( $I_{nA}$ ) .....	36
5.3.2 Rated current of a main outgoing circuit ( $I_{nC}$ ) .....	37
5.3.3 Group rated current of a main circuit ( $I_{ng}$ ) .....	37
5.3.4 Rated peak withstand current ( $I_{pk}$ ) .....	38
5.3.5 Rated short-time withstand current ( $I_{cw}$ ) (of a main circuit of an assembly).....	38
5.3.6 Rated conditional short-circuit current ( $I_{cc}$ ) (of an assembly or a circuit of an assembly) .....	38
5.4 Rated diversity factor (RDF).....	38
5.5 Rated frequency ( $f_n$ ) .....	39
5.6 Other characteristics .....	39
6 Information .....	39
6.1 Assembly designation marking.....	39
6.2 Documentation.....	40
6.2.1 Information relating to the assembly .....	40
6.2.2 Instructions for handling, installation, operation and maintenance.....	40
6.3 Device and/or component identification.....	41
7 Service conditions .....	41
7.1 Normal service conditions .....	41
7.1.1 Climatic conditions .....	41
7.1.2 Pollution degree .....	41
7.2 Special service conditions.....	42
7.3 Conditions during transport, storage and installation .....	42
8 Constructional requirements .....	43

8.1	Strength of materials and parts .....	43
8.1.1	General .....	43
8.1.2	Protection against corrosion .....	43
8.1.3	Properties of insulating materials .....	43
8.1.4	Resistance to ultra-violet (UV) radiation .....	44
8.1.5	Mechanical strength .....	44
8.1.6	Lifting provision .....	44
8.2	Degree of protection provided by an assembly enclosure .....	44
8.2.1	Protection against mechanical impact (IK code) .....	44
8.2.2	Protection against contact with live parts, ingress of solid foreign bodies and water (IP code) .....	45
8.2.3	Assembly with removable parts .....	45
8.3	Clearances and creepage distances .....	46
8.3.1	General .....	46
8.3.2	Clearances .....	46
8.3.3	Creepage distances .....	46
8.4	Protection against electric shock .....	47
8.4.1	General .....	47
8.4.2	Basic protection .....	47
8.4.3	Fault protection .....	48
8.4.4	Additional requirements for class II assemblies .....	51
8.4.5	Limitation of steady-state touch currents and charge .....	51
8.4.6	Operating and servicing conditions .....	52
8.5	Incorporation of switching devices and components .....	53
8.5.1	Fixed parts .....	53
8.5.2	Removable parts .....	53
8.5.3	Selection of switching devices and components .....	54
8.5.4	Installation of switching devices and components .....	54
8.5.5	Accessibility .....	55
8.5.6	Barriers .....	55
8.5.7	Direction of operation and indication of switching positions .....	55
8.5.8	Indicator lights and push-buttons .....	55
8.5.9	Power factor correction banks .....	55
8.6	Internal electrical circuits and connections .....	56
8.6.1	Main circuits .....	56
8.6.2	Auxiliary circuits .....	56
8.6.3	Bare and insulated conductors .....	57
8.6.4	Selection and installation of non-protected live conductors to reduce the possibility of short-circuits .....	58
8.6.5	Identification of the conductors of main and auxiliary circuits .....	58
8.6.6	Identification of the protective conductor (PE, PEL, PEM, PEN) and of the neutral conductor (N) and the mid-point conductor (M) of the main circuits .....	58
8.6.7	Conductors in AC circuits passing through ferromagnetic enclosures or plates .....	58
8.7	Cooling .....	58
8.8	Terminals for external cables .....	58
9	Performance requirements .....	60
9.1	Dielectric properties .....	60
9.1.1	General .....	60

9.1.2	Power-frequency withstand voltage .....	60
9.1.3	Impulse withstand voltage .....	61
9.1.4	Protection of surge protective devices .....	61
9.2	Temperature-rise limits .....	61
9.2.1	General .....	61
9.2.2	Adjustment of rated currents for alternative ambient air temperatures.....	62
9.3	Short-circuit protection and short-circuit withstand strength .....	62
9.3.1	General .....	62
9.3.2	Information concerning short-circuit withstand strength.....	62
9.3.3	Relationship between peak current and short-time current.....	63
9.3.4	Coordination of protective devices .....	63
9.4	Electromagnetic compatibility (EMC).....	63
10	Design verification .....	64
10.1	General.....	64
10.2	Strength of materials and parts .....	65
10.2.1	General .....	65
10.2.2	Resistance to corrosion .....	65
10.2.3	Properties of insulating materials.....	67
10.2.4	Resistance to ultraviolet (UV) radiation.....	69
10.2.5	Lifting .....	70
10.2.6	Verification of protection against mechanical impact (IK code).....	71
10.2.7	Marking .....	71
10.2.8	Mechanical operation.....	72
10.3	Degree of protection of assemblies (IP Code) .....	72
10.4	Clearances and creepage distances.....	73
10.5	Protection against electric shock and integrity of protective circuits .....	73
10.5.1	General .....	73
10.5.2	Effective earth continuity between the exposed-conductive-parts of the class I assembly and the protective circuit.....	73
10.5.3	Short-circuit withstand strength of the protective circuit .....	74
10.6	Incorporation of switching devices and components .....	74
10.6.1	General .....	74
10.6.2	Electromagnetic compatibility .....	75
10.7	Internal electrical circuits and connections .....	75
10.8	Terminals for external conductors .....	75
10.9	Dielectric properties .....	75
10.9.1	General .....	75
10.9.2	Power-frequency withstand voltage .....	75
10.9.3	Impulse withstand voltage .....	76
10.9.4	Testing of enclosures made of insulating material.....	78
10.9.5	External door or cover mounted operating handles of insulating material.....	78
10.9.6	Testing of conductors and hazardous live parts covered by insulating material to provide protection against electric shock.....	79
10.10	Temperature-rise .....	79
10.10.1	General .....	79
10.10.2	Verification by testing .....	79
10.10.3	Verification by comparison.....	86
10.10.4	Verification assessment.....	88
10.11	Short-circuit withstand strength.....	91

10.11.1	General .....	91
10.11.2	Circuits of assemblies which are exempted from the verification of the short-circuit withstand strength .....	92
10.11.3	Verification by comparison with a reference design – Using a checklist .....	92
10.11.4	Verification by comparison with a reference design(s) – Using calculation .....	92
10.11.5	Verification by test .....	93
10.12	Electromagnetic compatibility (EMC) .....	99
11	Routine verification .....	99
11.1	General .....	99
11.2	Degree of protection against contact with hazardous live parts, ingress of solid foreign bodies and water of enclosures .....	100
11.3	Clearances and creepage distances .....	100
11.4	Protection against electric shock and integrity of protective circuits .....	100
11.5	Incorporation of built-in components .....	100
11.6	Internal electrical circuits and connections .....	100
11.7	Terminals for external conductors .....	100
11.8	Mechanical operation .....	100
11.9	Dielectric properties .....	101
11.10	Wiring, operational performance and function .....	101
Annex A (normative)	Minimum and maximum cross-section of copper cables suitable for connection to terminals for external cables (see 8.8) .....	111
Annex B (normative)	Method of calculating the cross-sectional area of protective conductors with regard to thermal stresses due to currents of short duration .....	112
Annex C (informative)	User information template .....	113
Annex D (informative)	Design verification .....	114
Annex E (informative)	Rated diversity factor .....	115
E.1	General .....	115
E.2	Rated diversity factor for outgoing circuits within an assembly .....	115
E.2.1	General .....	115
E.2.2	Example of an assembly with an RDF of 0,68 .....	118
E.2.3	Example of an assembly with RDF declared for each section .....	119
Annex F (normative)	Measurement of clearances and creepage distances .....	120
F.1	Basic principles .....	120
F.2	Use of ribs .....	120
Annex G (normative)	Correlation between the nominal voltage of the supply system and the rated impulse withstand voltage of the equipment .....	125
Annex H (informative)	Operating current and power loss of copper cables .....	127
Annex I (informative)	Thermal equivalent of an intermittent current .....	129
Annex J (normative)	Electromagnetic compatibility (EMC) .....	130
J.1	General .....	130
Annex K (normative)	Operating current and power loss of bare copper bars .....	137
Annex L (informative)	Guidance on verification of temperature-rise .....	140
L.1	General .....	140
L.1.1	Principles .....	140
L.1.2	Current ratings of assemblies .....	140
L.2	Temperature-rise limits .....	141
L.3	Test .....	142

L.3.1	General .....	142
L.3.2	Method a) – Verification of the complete assembly (10.10.2.3.5) .....	142
L.3.3	Method b) – Verification considering individual functional units separately and the complete assembly (10.10.2.3.6) .....	142
L.3.4	Method c) – Verification considering individual functional units and the main and distribution busbars separately as well as the complete assembly (10.10.2.3.7) .....	143
L.4	Verification assessment .....	143
L.4.1	General .....	143
L.4.2	Single compartment assembly with a rated current ( $I_{nA}$ ) not exceeding 630 A .....	143
L.4.3	Assembly with rated currents ( $I_{nA}$ ) not exceeding 1600 A .....	143
L.5	Verification by comparison with a reference design .....	143
Annex M (normative) Verification of the short-circuit withstand strength of busbar structures by comparison with a reference design by calculation .....		145
M.1	General .....	145
M.2	Terms and definitions .....	145
M.3	Method of verification .....	146
M.4	Conditions for application .....	147
M.4.1	General .....	147
M.4.2	Peak short-circuit current .....	147
M.4.3	Thermal short-circuit strength .....	147
M.4.4	Busbar supports .....	147
M.4.5	Busbar connections, equipment connections .....	147
M.4.6	Angular busbar configurations .....	147
M.4.7	Calculations with special regard to conductor oscillation .....	148
Annex N (informative) List of notes concerning certain countries .....		149
Annex AA (informative) Items subject to agreement between the DBO manufacturer and the user .....		155
Annex BB (informative) Effects upon a DBO design and related ratings, instructions, etc. when used in a prosumer's electrical installation (PEI) .....		159
Annex CC (informative) Rated current of an assembly ( $I_{nA}$ ) .....		160
Annex DD (informative) List of notes concerning certain countries .....		162
Bibliography .....		175
Figure E.1 – Typical assembly .....		116
Figure E.2 – Example 1: Table E.1 – Functional unit loading for an assembly with a rated diversity factor of 0,68 .....		118
Figure E.3 – Example 2: Table E.1 – Functional unit loading for an assembly with a rated diversity factor of 0,6 in Section B and 0,68 in Section C .....		119
Figure F.1 – Measurement of clearance and creepage distances .....		124
Figure I.1 – Example of average heating effect calculation .....		129
Figure J.1 – Examples of ports .....		130
Figure L.1 – Verification of temperature-rise .....		144
Figure M.1 – Tested busbar structure (TS) .....		145
Figure M.2 – Non tested busbar structure (NTS) .....		146
Figure M.3 – Angular busbar configuration with supports at the corners .....		147
Figure CC.1 – Example of overloading where $I_n + I_{gen(s)}$ is greater than $I_{nA}$ .....		160



Figure DD.1 – Example of temperature rise verification by test of a complete split-load DBO as in 10.10.2.3.6.....	168
Figure DD.2 – Calibration of the test circuit.....	171
Figure DD.3 – Test circuit to prove coordination of characteristics .....	174
Table 1 – Minimum clearances in air (8.3.2).....	101
Table 2 – Minimum creepage distances (8.3.3) .....	102
Table 3 – Cross-sectional area of a copper protective conductor (8.4.3.2.2) .....	103
Table 4 – Conductor selection and installation requirements (8.6.4).....	103
Table 5 – Minimum terminal capacity for copper protective conductors (PE) (8.8) .....	103
Table 6 – Temperature-rise limits (9.2) .....	104
Table 7 – Values for the factor $n^a$ (9.3.3) .....	105
Table 8 – Power-frequency withstand voltage for main circuits (10.9.2) .....	105
Table 9 – Power-frequency withstand voltage for auxiliary circuits (10.9.2) .....	105
Table 10 – Impulse withstand test voltages (10.9.3).....	105
Table 11 – Copper test conductors for rated currents up to 400 A inclusive (10.10.2.3.2).....	106
Table 12 – Copper test conductors for rated currents from 400 A to 7 000 A (10.10.2.3.2).....	106
Table 13 – Short-circuit verification by comparison with reference designs: checklist (10.5.3.3, 10.11.3 and 10.11.4).....	107
Table 14 – Relationship between prospective fault current and diameter of copper wire ....	108
Table 15 – Climatic conditions .....	108
Table 101 – Values of assumed loading.....	109
Table 102 – Tightening torque values for the verification of mechanical strength .....	109
Table A.1 – Cross-section of copper cables suitable for connection to terminals for external cables .....	111
Table B.1 – Values of $k$ for insulated protective conductors not incorporated in cables or bare protective conductors in contact with cable covering.....	112
Table E.1 – Examples of loading for an assembly .....	117
Table F.1 – Minimum width of grooves .....	120
Table G.1 – Correspondence between the nominal voltage of the supply system and the equipment rated impulse withstand voltage .....	126
Table H.1 – Operating current and power loss of single-core copper cables with a permissible conductor temperature of 70 °C (ambient temperature inside the assembly: 55 °C).....	127
Table H.2 – Reduction factor $k_1$ for cables with a permissible conductor temperature of 70 °C (extract from IEC 60364-5-52:2009, Table B.52.14).....	128
Table J.1 – Tests for EMC immunity for environment A (see J.10.12.2).....	134
Table J.2 – Tests for EMC immunity for environment B (see J.10.12.2).....	135
Table J.3 – Acceptance criteria when electromagnetic disturbances are present.....	136
Table K.1 – Operating current and power loss of bare copper bars with rectangular cross-section, run horizontally and arranged with their largest face vertical, frequency 50 Hz to 60 Hz (ambient air temperature inside the assembly: 55 °C, temperature of the conductor 70 °C).....	137
Table K.2 – Factor $k_4$ for different temperatures of the air inside the assembly and/or for the conductors.....	138

Table AA.1 – Items subject to agreement between the DBO manufacturer and the user.....	155
Table DD.1 – Requirements for final circuit protective devices: Circuit-breakers complying with BS EN 60898 and RCBOs complying with BS EN 61009 .....	169
Table DD.2 – Requirements for final circuit protective devices: Semi-enclosed fuses complying with BS 3036 and cartridge fuses complying with BS 88.3 .....	169
Table DD.3 – Cross-sections of copper conductors on load side of protective device under test .....	170
Table DD.4 – Preparation for Test B .....	173

Document is a preview generated by EVS

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES –****Part 3: Distribution boards intended to be operated  
by ordinary persons (DBO)**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

**This extended version (EXV) of the official IEC Standard provides the user with the comprehensive content of the Standard.**

**IEC 61439-3:2024 EXV includes the content of IEC 61439-3:2024, and the references made to IEC 61439-1:2020.**

**The specific content of IEC 61439-3:2023 is displayed on a blue background.**

IEC 61439-3 has been prepared by subcommittee 121B: Low-voltage switchgear and controlgear assemblies, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low voltage. It is an International Standard.

This second edition cancels and replaces the first edition published in 2012. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) alignment with the structure of IEC 61439-1:2020;
- b) inclusion in the scope of more examples of the type of protection and control devices;
- c) deletion of type A and type B DBOs;
- d) addition of a new Annex BB related to DBOs used in a prosumer's electrical installation (PEI);
- e) addition of a new Annex CC related to rated current of a DBO with additional source of supply in parallel/simultaneously with another source that is connected to the DBO e.g. PV.

The text of this International Standard is based on the following documents:

Draft	Report on voting
121B/193/FDIS	121B/195/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at [www.iec.ch/members\\_experts/refdocs](http://www.iec.ch/members_experts/refdocs). The main document types developed by IEC are described in greater detail at [www.iec.ch/publications](http://www.iec.ch/publications).

This document is to be read in conjunction with IEC 61439-1:2020. The provisions of the general rules dealt with in IEC 61439-1 are only applicable to this document insofar as they are specifically cited. When this document states "addition", "modification" or "replacement", the relevant text in IEC 61439-1:2020 is to be adapted accordingly.

Subclauses that are numbered with a 101 (102, 103, etc.) suffix are additional to the same subclause in IEC 61439-1:2020.

Tables and figures in this document that are new are numbered starting with 101.

New annexes in this document are lettered AA, BB, etc.

The reader's attention is drawn to the fact that Annex DD lists all of the "in some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

A list of all parts in the IEC 61439 series, published under the general title *Low-voltage switchgear and controlgear assemblies*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

**IMPORTANT** – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

## LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES –

### Part 3: Distribution boards intended to be operated by ordinary persons (DBO)

#### 1 Scope

This part of IEC 61439 defines the specific requirements for distribution boards intended to be operated by ordinary persons (abbreviated DBO throughout this document, see 3.1.101) as follows:

- assemblies intended to be operated by ordinary persons (e.g. switching operations and replacing fuse-links), e.g. in domestic (household) applications;
- assemblies containing outgoing circuits with protective devices intended to be operated by ordinary persons, complying e.g. with IEC 60898-1, the IEC 61008 series, the IEC 61009 series, IEC 62606, IEC 62423 and IEC 60269-3;
- assemblies for applications where the nominal voltage to earth does not exceed 300 V AC (see Table G.1 of IEC 61439-1:2020);

NOTE The voltage limits for DC applications are under consideration.

- assemblies with a rated current ( $I_{nc}$ ) of the outgoing circuits not exceeding 125 A and a rated current ( $I_{nA}$ ) not exceeding 250 A;
- assemblies intended for use in connection with the generation, transmission, distribution and conversion of electrical energy, and for the control of equipment consuming electrical energy and for associated data processing;
- enclosed, stationary assemblies;
- assemblies for indoor or outdoor use.

DBOs can contain protection devices, control devices, signalling devices alone or a combination of devices e.g. circuit-breakers, load shedding relay, energy management, communication devices, lighting control.

This document does not apply to an empty enclosure nor to individual devices and self-contained components, such as circuit-breakers, fuse-switches, electronic equipment. which comply with the relevant product standards, it describes the integration of devices, or self-contained components, or both, into a DBO or into an empty enclosure forming a DBO.

This document applies to DBOs designed, manufactured, and verified on a one-off basis or fully standardized and manufactured in quantity.

This document does not apply to the specific types of assemblies covered by other parts of the IEC 61439 series.

NOTE Enclosures for electrical accessories for household and similar fixed electrical installations are covered in IEC 60670-24.

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-2:2007, *Environmental testing – Part 2-2: Tests – Test B: Dry heat*

IEC 60068-2-11:1981, *Basic environmental testing procedures – Part 2-11: Tests – Test Ka: Salt mist*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-75, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60073:2002, *Basic and safety principles for man-machine interface, marking and identification – Coding principles for indicators and actuators*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60269-3, *Low-voltage fuses – Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household and similar applications) – Examples of standardized systems of fuses A to F*

IEC 60364 (all parts), *Low-voltage electrical installations*

IEC 60364-4-41:2005, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60364-4-41:2005/AMD1:2017

IEC 60364-5-51:2005, *Electrical installations of buildings – Part 5-51: Selection and erection of electrical equipment – Common rules*

IEC 60364-5-52:2009, *Low-voltage electrical installations – Part 5-52: Selection and erection of electrical equipment – Wiring systems*

IEC 60364-8-82, *Low-voltage electrical installations – Part 8-82: Functional aspects – Prosumer's low-voltage electrical installations*

IEC 60439 (all parts), *Low-voltage switchgear and controlgear assemblies*<sup>1</sup>

IEC 60445:2017, *Basic and safety principles for man-machine interface, marking and identification – Identification of equipment terminals, conductor terminations and conductors*

IEC 60447:2004, *Basic and safety principles for man-machine interface, marking and identification – Actuating principles*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*<sup>2</sup>

IEC 60529:1989/AMD1:1999

IEC 60529:1989/AMD2:2013

IEC 60669-2-4, *Switches for household and similar fixed electrical installations – Part 2-4: Particular requirements – Isolating switches*

<sup>1</sup> Withdrawn. The IEC 60439 series has been cancelled and replaced by the IEC 61439 series.

<sup>2</sup> There is a consolidated document edition 2.2 (2013) that includes IEC 60529 (1989) and its Amendment 1 (1999) and Amendment 2 (2013).

IEC 60695-2-10:2013, *Fire hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

IEC 60695-2-11:2014, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products (GWEPT)*

IEC 60695-2-12, *Fire hazard testing – Part 2-12: Glowing/hot-wire based test methods – Glow-wire flammability index (GWFI) test method for materials*

IEC 60865-1:2011, *Short-circuit currents – Calculation of effects – Part 1: Definitions and calculation methods*

IEC TR 60890:2014, *A method of temperature-rise verification of low-voltage switchgear and controlgear assemblies by calculation*

IEC 60898-1, *Electrical accessories – Circuit-breakers for overcurrent protection for household and similar installations – Part 1: Circuit-breakers for a.c. operation*

IEC 60947-3, *Low-voltage switchgear and controlgear – Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units*

IEC 60947-4-1:2018, *Low-voltage switchgear and controlgear – Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters*

IEC 61000-4-2:2008, *Electromagnetic compatibility (EMC) – Part 4-2: Testing and measurement techniques – Electrostatic discharge immunity test*

IEC 61000-4-3:2006, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio frequency, electromagnetic field immunity test<sup>3</sup>*

IEC 61000-4-3:2006/AMD1:2007

IEC 61000-4-3:2006/AMD2:2010

IEC 61000-4-4:2012, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5:2014, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test<sup>4</sup>*

IEC 61000-4-5:2014/AMD1:2017

IEC 61000-4-6:2013, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61000-4-8:2009, *Electromagnetic compatibility (EMC) – Part 4-8: Testing and measurement techniques – Power frequency magnetic field immunity test*

IEC 61000-4-11:2004, *Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests*

IEC 61000-4-11:2004/AMD1:2017

<sup>3</sup> There is a consolidated edition 3.2 (2010) that includes IEC 61000-4-3 (2006) and Amendment 1 (2007) and Amendment 2 (2010).

<sup>4</sup> There is consolidated edition 3.1 (2017) that includes IEC 61000-4-5 (2014) and its Amendment 1 (2017).



IEC 61000-6-3:2006, *Electromagnetic compatibility (EMC) – Part 6-3: Generic standards – Emission standard for residential, commercial and light-industrial environments*  
IEC 61000-6-3:2006/AMD1:2010

IEC 61000-6-4:2018, *Electromagnetic compatibility (EMC) – Part 6-4: Generic standards – Emission standard for industrial environments*

IEC 61008 (all parts), *Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)*

IEC 61009 (all parts), *Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)*

IEC 61082-1:2014, *Preparation of documents used in electrotechnology – Part 1: Rules*

IEC 61180:2016, *High-voltage test techniques for low-voltage equipment – Definitions, test and procedure requirements, test equipment*

IEC 61439 (all parts), *Low-voltage switchgear and controlgear assemblies*

IEC 61439-1:2020, *Low-voltage switchgear and controlgear assemblies – Part 1: General rules*

IEC 61921:2017, *Power capacitors – Low-voltage power factor correction banks*

IEC 62208:2011, *Empty enclosures for low-voltage switchgear and controlgear assemblies – General requirements*

IEC 62262, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

IEC 62423:2009, *Type F and type B residual current operated circuit-breakers with and without integral overcurrent protection for household and similar uses*

IEC 62606, *General requirements for arc fault detection devices*

IEC 81346-1:2009, *Industrial systems, installations and equipment and industrial products – Structuring principles and reference designations – Part 1: Basic rules*

IEC 81346-2:2019, *Industrial systems, installations and equipment and industrial products – Structuring principles and reference designations – Part 2: Classification of objects and codes for classes*

CISPR 11:2015, *Industrial, scientific and medical equipment – Radio-frequency disturbance characteristics – Limits and methods of measurement*

CISPR 11:2015/AMD1:2016

CISPR 11:2015/AMD2:2019

CISPR 32:2015, *Electromagnetic compatibility of multimedia equipment – Emission requirements*

CISPR 32:2015/AMD1:2019

ISO 178:2010, *Plastics – Determination of flexural properties*

ISO 178:2010/AMD1:2013

ISO 179-1:2010, *Plastics – Determination of Charpy impact properties – Part 1: Non-instrumented impact test*

ISO 179-2:1997, *Plastics – Determination of Charpy impact properties – Part 2: Instrumented impact test*

ISO 179-2:1997/AMD1:2011

ISO 2409:2013, *Paints and varnishes – Cross-cut test*

ISO 4628-3:2016, *Paints and varnishes – Evaluation of degradation of coatings – Designation of quantity and size of defects, and of intensity of uniform changes in appearance – Part 3: Assessment of degree of rusting*

ISO 4892-2:2013, *Plastics – Methods of exposure to laboratory light sources – Part 2: Xenon-arc lamps*

ISO 7010, *Graphical symbols – Safety colours and safety signs – Registered safety signs*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61439-1:2020 and the following apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

#### 3.1 General terms

##### 3.1.1

##### **low-voltage switchgear and controlgear assembly**

combination of one or more low-voltage switching devices together with associated control, measuring, signalling, protective, regulating equipment, with all the internal electrical and mechanical interconnections and structural parts, as defined by the original manufacturer, which can be assembled in accordance with the original manufacturer's instructions

Note 1 to entry: Throughout this document, the term assembly(s) is used for a low-voltage switchgear and controlgear assembly(s)

Note 2 to entry: The term "switching device" includes mechanical switching devices and semiconductor switching devices, e.g. soft starters, semiconductor relays, frequency converters. The auxiliary circuits may also include electro-mechanical devices, e.g. control relays, terminal blocks, and electronic devices, e.g. electronic motor control devices, electronic measurement and protection devices, bus communication, programmable logic controller systems.

##### 3.1.2

##### **assembly system**

full range of mechanical and electrical components (enclosures, busbars, functional units, auxiliary circuits and associated controls, etc.), as defined by the original manufacturer, which can be assembled in accordance with the original manufacturer's instructions in order to produce various assemblies

##### 3.1.3

##### **main circuit**

all the conductive parts of an assembly included in a circuit which is intended to transmit electrical energy