

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Alarm systems – Intrusion and hold-up systems –
Part 3: Control and indicating equipment**

**Systèmes d'alarme – Systèmes d'alarme contre l'intrusion et les hold-up –
Partie 3: Equipement de contrôle et de signalisation**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Alarm systems – Intrusion and hold-up systems –
Part 3: Control and indicating equipment**

**Systèmes d'alarme – Systèmes d'alarme contre l'intrusion et les hold-up –
Partie 3: Equipement de contrôle et de signalisation**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XC

ICS 13.320

ISBN 978-2-88912-198-4

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	9
3 Terms, definitions and abbreviations	10
3.1 Terms and definitions	10
3.2 Abbreviations	13
4 Equipment attributes	13
4.1 General.....	13
4.2 Functionality.....	14
5 CIE construction.....	14
6 Security grade	14
7 Environmental performance.....	14
7.1 Requirements.....	14
7.2 Environmental and EMC tests	15
8 Functional requirements	15
8.1 Inputs.....	15
8.1.1 Intruder detection	15
8.1.2 Hold-up device	15
8.1.3 Tamper.....	15
8.1.4 Fault.....	15
8.1.5 User input.....	16
8.1.6 Masking.....	16
8.1.7 Movement detector range reduction.....	16
8.1.8 Non-I&HAS inputs	16
8.2 Outputs	16
8.3 Operation	16
8.3.1 Access levels	17
8.3.2 Authorization	17
8.3.3 Setting procedures	19
8.3.4 Unsetting procedure	20
8.3.5 Restore function	20
8.3.6 Inhibit function.....	20
8.3.7 Isolate operation.....	21
8.3.8 Verification of I&HAS functions	21
8.3.9 Alarm point soak test mode	21
8.3.10 Other functions	21
8.4 Processing	21
8.4.1 Processing of input signals or messages	21
8.4.2 Processing of user inputs	22
8.4.3 Monitoring of CIE processing.....	22
8.5 Indication	23
8.5.1 General	23
8.5.2 Visual indicators	24
8.5.3 Priority of indications	24
8.6 Notification outputs.....	24

8.6.1	Other notification	24
8.7	Tamper security (detection/protection)	24
8.7.1	Tamper protection	25
8.7.2	Tamper detection.....	25
8.7.3	Monitoring of substitution.....	27
8.8	Interconnections.....	27
8.9	Timing.....	27
8.10	Event recording.....	27
8.10.1	Event recording at the CIE.....	28
8.10.2	Event recording at the ARC or other remote location	28
8.11	Power supply.....	28
9	Product documentation.....	29
9.1	Installation and maintenance	29
9.2	Operating instructions	30
10	Marking and labelling	30
11	Tests	30
11.1	Test conditions.....	30
11.1.1	Laboratory conditions and tolerance	30
11.1.2	Mounting	30
11.1.3	CIE test configuration	31
11.1.4	Power supply.....	31
11.1.5	Event log checks	31
11.1.6	Documentation	32
11.2	Test procedures	32
11.2.1	Tolerances	32
11.2.2	Wire-free devices	32
11.3	Reduced functional test.....	32
11.4	Functional tests.....	33
11.4.1	Processing intruder alarm signals or messages	33
11.4.2	Processing of hold-up signals or messages	35
11.4.3	Processing of tamper signals or messages	37
11.4.4	Processing of fault signals or messages	38
11.4.5	Processing masking signals or messages	40
11.4.6	Processing reduction of range signals or messages.....	42
11.4.7	CIE processing in the presence of non-I&HAS inputs.....	43
11.5	Access level.....	44
11.5.1	Access to the functions and controls.....	44
11.6	Authorization requirements.....	45
11.6.1	Mechanical key tests	45
11.6.2	Logical key tests.....	46
11.6.3	Invalid authorization attempts	48
11.7	Operational tests.....	49
11.7.1	Setting procedures	49
11.7.2	Prevention of setting and overriding of prevention of setting procedures	51
11.7.3	The set state	52
11.7.4	Unsetting procedures	52
11.7.5	Setting and/or unsetting automatically at pre-determined times	54
11.7.6	Inhibit and isolate functions.....	55

11.7.7	Test functions.....	57
11.7.8	Other functions.....	57
11.7.9	Monitoring of CIE processing.....	58
11.7.10	Availability of indications.....	59
11.8	Tamper security tests.....	59
11.8.1	ACE type A.....	59
11.8.2	Tamper protection.....	59
11.8.3	Tamper detection – Access to the inside of the housing.....	60
11.8.4	Tamper detection – Removal from mounting.....	61
11.8.5	Tamper detection – Penetration of the housing.....	62
11.9	Substitution tests.....	62
11.9.1	Tests for monitoring of substitution of components.....	62
11.9.2	Tests for monitoring of substitution – Timing requirements.....	62
11.10	Testing of I&HAS timing performance.....	62
11.11	Testing for interconnections.....	63
11.11.1	Monitoring of interconnections.....	63
11.11.2	Testing of monitoring of periodic communication.....	63
11.11.3	Testing of verification during setting procedure.....	64
11.11.4	Test for security of communication.....	65
11.12	Event log.....	65
11.13	Marking and documentation.....	66
11.14	Environmental and EMC tests.....	66
Annex A (informative)	Interconnection types.....	68
Annex B (informative)	Summary of timing requirements.....	70
Annex C (normative)	Use of non-I&HAS interface.....	71
Annex D (informative)	Summary of function cross-references.....	72
Bibliography		75
Figure A.1	– Specific wired interconnections.....	68
Figure A.2	– Non-specific wired interconnections.....	69
Figure A.3	– Wire-free interconnections.....	69
Table 1	– Recognition of additional fault conditions.....	15
Table 2	– Recognition of biometric keys.....	18
Table 3	– Time intervals for methods of authorization used in combination.....	18
Table 4	– Detection of repeated invalid authorization attempts.....	19
Table 5	– Monitoring of processing.....	22
Table 6	– Indications supplementary to those of IEC 62642-1.....	23
Table 7	– Tamper protection.....	25
Table 8	– Tamper detection.....	26
Table 9	– Tool dimension for tamper detection.....	26
Table 10	– Removal from mounting.....	26
Table 11	– Additional events to be included in event log.....	27
Table 12	– Reduced functional test.....	33
Table 13	– Tests of the processing of intruder signals or messages.....	34
Table 14	– Tests of the processing of hold-up signals or messages.....	36

Table 15 – Tests of the processing of tamper signal or messages.....	37
Table 16 – Test of processing of fault signals or messages.....	39
Table 17 – Test of processing of masking signals or messages	41
Table 18 – Test of processing of reduction of range signals or messages	42
Table 19 – Test of CIE processing in the presence of non-I&HAS inputs.....	44
Table 20 – Test of the access to the functions and controls	44
Table 21 – Test for disabling user input device by invalid keys	48
Table 22 – Test for generation of tamper signal or message by invalid keys	49
Table 23 – Test of setting procedure.....	50
Table 24 – Test of prevention of setting and overriding of prevention of setting procedure	51
Table 25 – Test for unsetting procedure.....	53
Table 26 – Test of setting and/or unsetting automatically at pre-determined times	55
Table 27 – Inhibit and isolate functions	56
Table 28 – Verification of test functions	57
Table 29 – Test of CIE process monitoring.....	58
Table 30 – Test of availability of indications.....	59
Table 31 – Test of event log	65
Table 32 – Environmental and EMC tests	67
Table B.1 – Timing table	70
Table C.1 – Conditions for use of non-I&HAS interface for control and indicating purposes.....	71
Table D.1 – Cross-references	72

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ALARM SYSTEMS – INTRUSION AND HOLD-UP SYSTEMS –

Part 3: Control and indicating equipment

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62642-3 has been prepared by IEC technical committee 79: Alarm and electronic security systems.

This standard is based on EN 50131-3 (2006).

The text of this standard is based on the following documents:

FDIS	Report on voting
79/310/FDIS	79/321/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 62642 series can be found, under the general title *Alarm systems – Intrusion and hold-up systems*, on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

This part 3 of the IEC 62642 series of standards gives requirements for control and indicating equipment used in intrusion and hold-up alarm systems. The other parts of this series of standards are as follows:

- Part 1 System requirements
- Part 2-2 Intrusion detectors – Passive infrared detectors
- Part 2-3 Intrusion detectors – Microwave detectors
- Part 2-4 Intrusion detectors – Combined passive infrared / microwave detectors
- Part 2-5 Intrusion detectors – Combined passive infrared / ultrasonic detectors
- Part 2-6 Intrusion detectors – Opening contacts (magnetic)
- Part 2-71 Intrusion detectors – Glass break detectors – Acoustic
- Part 2-72 Intrusion detectors – Glass break detectors – Passive
- Part 2-73 Intrusion detectors – Glass break detectors – Active
- Part 3 Control and indicating equipment
- Part 4 Warning devices
- Part 5-3 Interconnections – Requirements for equipment using radio frequency techniques
- Part 6 Power supplies
- Part 7 Application guidelines
- Part 8 Security fog devices/systems

In order to insure the consistency of the whole IEC 62642 series, the terminology is defined at one place that is the master document IEC 62642-1 that gives general requirements concerning the intrusion system. Exception is made for specific terms to control and indicating equipment and where repetition is deemed essential for the clarity of this document.

Reference has been included to various implications arising from the detector standards. Full detail of the interconnection requirements could be the subject of a future standard.

A number of requirements are contained in this standard for which a formal test procedure can only be written by defining (and hence restricting) the technology by which the requirement is achieved. Accordingly, it has been recognised that such functions can be tested only by agreement between manufacturer and test house, according to documented information relating to how the required functionality has been achieved.

A table to cross reference IEC 62642-1 requirements against this standard and tests has been included in Annex D.

ALARM SYSTEMS – INTRUSION AND HOLD-UP SYSTEMS –

Part 3: Control and indicating equipment

1 Scope

This part of the IEC 62642 specifies the requirements, performance criteria and testing procedures for control and indicating equipment (CIE) intended for use in intrusion and hold-up alarm systems (I&HAS) installed in buildings. This document also applies to CIE to be used in IAS or HAS.

The CIE may incorporate processing functions of other I&HAS components or its processing requirements may be distributed among such components.

This standard specifies the requirements for CIE installed in buildings using specific or non-specific wired interconnections or wire-free interconnections. These requirements also apply to ancillary control equipment (ACE) that are installed inside or outside of the supervised premises and mounted in indoor or outdoor environments.

Where CIE shares means of detection, interconnection, control, communication, processing and/or power supplies with other applications, these requirements apply to I&HAS functions only.

This standard specifies performance requirements for CIE at each of the four security grades identified in the IEC 62642-1. Requirements are also specified for four environmental classes covering applications for indoor and outdoor locations.

This standard includes mandatory functions, which shall be provided on all CIE for the appropriate security grade, as well as optional functions that may additionally be provided.

NOTE In this standard reference to the term "I&HAS" is used throughout, except where there is specific need to differentiate between the IAS and HAS portions of a system. The term is intended to include IAS and HAS when such systems are installed separately.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-1:1988, *Environmental testing – Part 1: General and guidance*

IEC 60068-2-75:1997, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60073, *Basic and safety principles for man-machine interface, marking and identification – Coding principles for indicators and actuators*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 62599-1, *Alarm systems – Part 1: Environmental test methods*

IEC 62599-2, *Alarm systems – Part 2: Electromagnetic compatibility – Immunity requirements for components of fire and security alarm systems*

IEC 62642-1:2010, *Alarm systems – Intrusion and hold-up systems – Part 1: System requirements*

IEC 62642-5-3, *Alarm systems – Intrusion and hold-up systems – Part 5-3: Interconnections – Requirements for equipment using radio frequency techniques*

EN 50131-6:2008, *Alarm systems – Intrusion and hold-up systems – Part 6: Power supplies*¹

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in the IEC 62642-1, as well as the following, apply.

3.1.1

acknowledge

action of a user to accept an indication

3.1.2

alarm point

one or more detector(s) providing a common signal or message, at the CIE or at the ACE for the purpose of indication or processing

3.1.3

alarm signal or message

signal or message generated by an alarm point

3.1.4

biometric key

use of biometric characteristic by an authorized user to gain access to restricted functions or parts of a CIE

EXAMPLE: finger print or iris recognition.

3.1.5

conditioning

exposure of the Equipment Under Test (EUT) to environmental conditions in order to determine the effect of such conditions on the EUT

3.1.6

detector

device designed to generate an alarm signal or message in response to the sensing of an abnormal condition indicating the presence of a hazard

3.1.7

digital key

portable device containing digitally coded information used by an authorized user to gain access to restricted functions or parts of a CIE

EXAMPLE: magnetic card, electronic token or similar.

¹ The transformation of this document as IEC 62642-6 is under preparation.