

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Live working – Voltage detectors –
Part 3: Two-pole low-voltage type**

**Travaux sous tension – Détecteurs de tension –
Partie 3: Type bipolaire basse tension**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Live working – Voltage detectors –
Part 3: Two-pole low-voltage type**

**Travaux sous tension – Détecteurs de tension –
Partie 3: Type bipolaire basse tension**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

ICS 13.260; 29.240.20; 29.260.99

ISBN 2-8318-1066-3

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	10
4 Requirements.....	13
4.1 General requirements.....	13
4.1.1 Safety.....	13
4.1.2 Indication.....	13
4.1.3 Electromagnetic compatibility (EMC)	14
4.2 Functional requirements	14
4.2.1 Clear indication	14
4.2.2 Clear perceptibility.....	15
4.2.3 Temperature and humidity dependence of the indication	15
4.2.4 Frequency dependency for a.c. voltage detector.....	16
4.2.5 Ripple dependency for d.c. voltage detector	16
4.2.6 Response time	16
4.2.7 Power source dependability	16
4.2.8 Testing element.....	16
4.2.9 Time rating	16
4.3 Electrical requirements.....	17
4.3.1 Insulating material	17
4.3.2 Protection against electric shocks.....	17
4.3.3 Current limiting elements.....	17
4.3.4 Minimum clearance and creepage distances.....	17
4.3.5 Protection against electrical stresses.....	20
4.3.6 Lead(s).....	20
4.3.7 Probes.....	20
4.3.8 Connector(s) (if any).....	20
4.3.9 Accessible switches in the detecting circuit for temporary loading (if any).....	20
4.4 Mechanical requirements.....	20
4.4.1 Design.....	20
4.4.2 Dimensions, construction.....	22
4.4.3 Degree of protection provided by enclosures	22
4.4.4 Resistance to vibration	22
4.4.5 Drop resistance	22
4.4.6 Shock resistance	22
4.4.7 Possible disassembling	22
4.4.8 Surface temperature.....	23
4.4.9 Resistance to heat.....	23
4.4.10 Probes.....	23
4.4.11 Lead(s).....	23
4.5 Marking.....	23
4.5.1 General	23
4.5.2 Marking on the indicator	23

4.5.3	Marking on the probe and/or the lead	24
4.6	Instructions for use.....	24
4.7	Requirements in case of reasonably foreseeable misuse during live working.....	24
4.7.1	AC/DC voltage misuse.....	24
4.7.2	Maximum current to earth in case of misuse	25
4.7.3	Misuse in case of mistaking of the voltage of the low voltage network	26
5	Tests	26
5.1	General.....	26
5.2	Tests for general requirements.....	27
5.2.1	Indication.....	27
5.2.2	Electromagnetic compatibility (EMC)	27
5.3	Tests for functional requirements	28
5.3.1	Clear indication	28
5.3.2	Clear perceptibility of visual indication.....	30
5.3.3	Clear perceptibility of audible indication (when available)	32
5.3.4	Temperature and humidity dependence of the indication	34
5.3.5	Frequency dependency for a.c. voltage detector.....	35
5.3.6	Ripple dependency for d.c. voltage detector	36
5.3.7	Response time	36
5.3.8	Power source dependability.....	37
5.3.9	Testing element.....	37
5.3.10	Time rating	37
5.4	Tests for electrical requirements.....	38
5.4.1	Tests on the insulation	38
5.4.2	Protection against electric shocks.....	39
5.4.3	Current limiting elements.....	40
5.4.4	Minimum clearance and creepage distances.....	40
5.4.5	Protection against electrical stresses.....	40
5.4.6	Lead(s).....	41
5.4.7	Probe(s)	41
5.4.8	Connector(s)	41
5.4.9	Switches for temporary loading (if any).....	41
5.5	Tests for mechanical requirements.....	42
5.5.1	Design.....	42
5.5.2	Dimensions, construction.....	42
5.5.3	Degree of protection provided by enclosures	42
5.5.4	Vibration resistance.....	42
5.5.5	Drop resistance	43
5.5.6	Shock resistance	44
5.5.7	Possible disassembling	44
5.5.8	Surface temperature	44
5.5.9	Heat resistance	45
5.5.10	Probes.....	45
5.5.11	Lead(s).....	47
5.6	Marking.....	48
5.6.1	Visual inspection and measurement	48
5.6.2	Durability of marking.....	48
5.7	Instructions for use.....	48
5.7.1	Type test	48

5.7.2	Alternative test in case of voltage detectors having completed the production phase	49
5.8	Tests for reasonably foreseeable misuse during live working	49
5.8.1	AC/DC voltage misuse	49
5.8.2	Maximum current to earth in case of misuse	49
5.8.3	Misuse in case of mistaking of the voltage of the low voltage network	50
6	Conformity assessment	50
7	Modifications	50
Annex A (informative)	Differences with IEC 61010 series	51
Annex B (normative)	Supplementary functions Phase indication – Rotating field indication – Continuity check	56
Annex C (normative)	Instructions for use	62
Annex D (normative)	General type test procedure	63
Annex E (normative)	Classification of defects and associated requirements and tests	65
Annex F (informative)	In-service care and use	67
Bibliography	69
Figure 1a	– Illustration of the electrical insulation of an indicator casing	18
Figure 1b	– Illustration of the electrical insulation of a probe with a detachable lead	18
Figure 1	– Illustration of the electrical insulation features applicable to components of a voltage detector	18
Figure 2a	– Example of a voltage detector with the indicator integrated in a probe	21
Figure 2b	– Example of a voltage detector with the indicator not integrated in a probe	21
Figure 2	– Voltage detector	21
Figure 3	– Maximum rms a.c. current to earth in case of misuse	25
Figure 4	– Maximum d.c. current to earth in case of misuse	25
Figure 5	– Test set-up for the influence of interference voltage	29
Figure 6	– Test set-up for measurement of clear perceptibility of visual indication	31
Figure 7a	– Positioning of the voltage detector in the test set-up	33
Figure 7b	– Key measurement points on the hemisphere	33
Figure 7	– Test set-up for measurement of clear perceptibility of audible indication	33
Figure 8	– Test set-up for close adhesion of insulation of the insulated part of the contact electrode	46
Table 1	– Climatic categories of voltage detectors	16
Table 2	– Minimum clearance distances for basic insulation and for supplementary insulation	19
Table 3	– Minimum clearance distances for reinforced insulation	19
Table 4	– Parameters to be observed to check the climatic dependence	34
Table 5	– AC voltage values for test on the complete equipment	39
Table 6	– Maximum permissible surface temperatures	45
Table B.1	– Classification of defects and associated requirements and tests	61
Table D.1	– Sequential order for performing type tests	63
Table D.2	– Type tests out of sequence	64
Table E.1	– Classification of defects and associated requirements and tests	65
Table F.1	– Periodic testing	68

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**LIVE WORKING –
VOLTAGE DETECTORS –****Part 3: Two-pole low-voltage type**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61243-3 has been prepared by IEC technical committee 78: Live working.

This second edition cancels and replaces the first edition published in 1998. It is a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- no more switches are allowed for scale change;
- all the voltage detectors are now for use indoor and outdoor excluding the use under rain conditions;
- no contact electrode which has the construction of a hook is allowed;
- no more voltage classes (A and B) are considered;
- the concept of double or reinforced insulation design (or constructional arrangements providing an equivalent protection) is added;

- for testing, the consideration of normal and single fault conditions is added;
- EMC requirements and tests are upgraded;
- the influence of interference voltage is now considered;
- the classification of the voltage detector into an overvoltage category is increased to at least category III;
- the protection against electrical stresses is reinforced (transient and temporary overvoltages);
- the degree of protection provided by all the enclosures (IP code) is increased to be at least IP54, unless otherwise specified;
- the requirement and test for switches for temporary loading have been reviewed;
- the requirement for ELV indication has been reviewed (a redundant non-disconnectable indicating system is not anymore the unique means allowed);
- the ranges of climatic conditions for operation of voltage detectors of category N and of category S have been reviewed;
- the ball pressure test now refers to IEC 60695-10-2;
- a wear test concerning the insulating material of the lead(s) is added;
- the conformity assessment of voltage detectors having completed the production phase is added;
- the normative annex on supplementary functions has been reviewed;
- the normative annex on sampling plans and procedure has been deleted (not applicable according to IEC 61318);
- the informative annex on acceptance tests has been deleted (consideration now included in IEC 61318).

The text of this standard is based on the following documents:

FDIS	Report on voting
78/821/FDIS	78/832/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61243 series can be found, under the general title *Live working – Voltage detectors*, on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition; or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION

The devices covered by this standard are designed to be used in a live working environment to determine the status (presence or absence of operating voltage) of low-voltage installations.

The live working environment comes with its specific hazards and working conditions which are generally more severe than the ones encountered by workers in other fields than live working.

This International Standard is a product standard giving essential requirements and tests to verify that the devices perform well and will contribute to the safety of the users, provided they are used by skilled persons, and according to safe working procedures and to local or national regulations.

Voltage detectors are not considered as measuring or testing devices, separately covered by IEC 61010 series. However, in case of misuse by general electrical workers, the requirements and tests included in this document are intended to achieve an equivalent level of safety.

To take into consideration the specific needs of a live working environment, the following differences exist with IEC 61010 series:

- some requirements and tests exist in both standards but with different sanctions or pass test criteria (see A.1);
- some requirements of IEC 61010 are not included in this standard with the rationale (see A.2);
- some additional requirements of this standard are not specified in IEC 61010 with the rationale (see A.3).

This International Standard has been prepared according to the requirements of IEC 61477, where applicable.

The product covered by this standard may have an impact on the environment during some or all stages of its life cycle. These impacts can range from slight to significant, be of short-term or long-term, and occur at the global, regional or local level.

This standard does not include requirements and test provisions for the manufacturers of the product, or recommendations to the users of the product for environmental improvement. However, all parties intervening in its design, manufacture, packaging, distribution, use, maintenance, repair, reuse, recovery and disposal are invited to take account of environmental considerations.

LIVE WORKING – VOLTAGE DETECTORS –

Part 3: Two-pole low-voltage type

1 Scope

This part of IEC 61243 is applicable to hand-held two-pole voltage detectors with its accessories (crocodile clips and detachable leads) to be used in contact with parts of electrical systems:

- for a.c. voltages not exceeding 1 000 V at nominal frequencies between $16\frac{2}{3}$ Hz and up to 500 Hz,

and/or

- for d.c. voltages not exceeding 1 500 V.

NOTE The a.c. voltages defined in this standard refer either to phase-to-phase voltages or phase to neutral voltages.

Contact electrode extensions are not covered by this standard.

Voltage detectors covered by this standard are intended to be used under dry and humid conditions, both indoor and outdoor. They are not intended to be used under rain conditions.

Voltage detectors covered by this standard are not intended to be used for continuous operation.

Voltage detectors covered by this standard are intended to be used up to 2 000 m above sea level.

This standard also includes provisions for the following supplementary functions when available (see Annex B):

- phase indication,
- rotating field indication, and
- continuity check.

Other supplementary functions are not covered by this standard.

Voltage detectors covered by this standard are not considered as measuring devices. Relevant safety requirements for measuring devices are included in IEC 61010 series.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-6, *Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)*

IEC 60068-2-31:2008, *Environmental testing – Part 2-31: Tests – Test Ec: Rough handling shocks, primarily for equipment-type specimens*

IEC 60068-2-75:1997, *Environmental testing – Part 2: Tests – Test Eh: Hammer tests*

IEC 60112, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60304, *Standard colours for insulation for low-frequency cables and wires*

IEC 60417, *Graphical symbols for use on equipment*

IEC/TS 60479-1:2005, *Effects of current on human beings and livestock – Part 1: General aspects*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*
Amendment 1:1999¹

IEC 60664-1:2007, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60664-3, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60695-10-2:2003, *Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test*

IEC 60942, *Electroacoustics – Sound calibrators*

IEC 61010-031:2002, *Safety requirements for electrical equipment for measurement, control and laboratory use – Part 031: Safety requirements for hand-held probe assemblies for electrical measurement and test*
Amendment 1:2008²

IEC 61010-1:2001, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*

IEC 61140:2001, *Protection against electric shock – Common aspects for installation and equipment*
Amendment 1:2004

IEC 61180-1, *High-voltage test techniques for low-voltage equipment – Part 1: Definitions, test and procedure requirements*

IEC 61180-2, *High-voltage test techniques for low-voltage equipment – Part 2: Test equipment*

IEC 61260, *Electroacoustics – Octave-band and fractional-octave-band filters*

IEC 61318, *Live working – Conformity assessment applicable to tools, devices and equipment*

IEC 61326-1:2005, *Electrical equipment for measurement, control and laboratory use – EMC requirements – Part 1: General requirements*

IEC 61477, *Live working – Minimum requirements for the utilization of tools, devices and equipment*

¹ There exists a consolidated edition 2.1 (2001) that includes Edition 2 and its Amendment 1.

² There exists a consolidated edition 1.1 (2008) that includes Edition 1 and its Amendment 1.

IEC 61557-7:2007, *Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. – Equipment for testing, measuring or monitoring of protective measures – Part 7: Phase sequence*

IEC 61672-1, *Electroacoustics – Sound level meters – Part 1: Specifications*

ISO 286-1, *ISO system of limits and fits – Part 1: Bases of tolerances, deviations and fits*

ISO 286-2, *ISO system of limits and fits – Part 2: Tables of standard tolerance grades and limit deviations for holes and shafts*

ISO 354, *Acoustics – Measurement of sound absorption in a reverberation room*

ISO 3744:1994, *Acoustics – Determination of sound power levels of noise sources using sound pressure – Engineering method in an essentially free field over a reflecting plane*

ISO 3745, *Acoustics – Determination of sound power levels of noise sources using sound pressure – Precision methods for anechoic and hemi-anechoic rooms*

ISO 7000:2004, *Graphical symbols for use on equipment – Index and synopsis*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61318 and the following apply.

3.1

basic insulation

insulation applied to live parts of a voltage detector to provide basic protection against electric shock

NOTE Basic insulation does not necessarily include insulation used exclusively for functional purposes (3.10.1 of IEC 61140).

[3.17.2 of IEC 60664-1, modified]

3.2

clear indication

unambiguous detection and indication of the voltage state between the contact electrodes

[IEV 651-10-10, modified]

3.3

clear perceptibility

case where the indication is unmistakably discernible by the user under specific environmental conditions when the voltage detector is in its operating position

3.4

contact electrode

conductive part of the probe which establishes the electric connection to the part to be checked

[IEV 651-10-09, modified]

NOTE In certain designs, a part of the contact electrode is covered with insulating material.