

**Akustika.Torustikku paigaldatud summuti  
summutusvõime mõõtmine ilma läbivooluta.  
Laboriseiremeetod**

Acoustics - Measurement of insertion loss of ducted  
silencers without flow - Laboratory survey method

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN ISO 11691:2009 sisaldab Euroopa standardi EN ISO 11691:2009 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 30.10.2009 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 19.08.2009.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN ISO 11691:2009 consists of the English text of the European standard EN ISO 11691:2009.

This standard is ratified with the order of Estonian Centre for Standardisation dated 30.10.2009 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 19.08.2009.

The standard is available from Estonian standardisation organisation.

ICS 91.120.20

### Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:  
Aru 10 Tallinn 10317 Eesti; [www.evs.ee](http://www.evs.ee); Telefon: 605 5050; E-post: [info@evs.ee](mailto:info@evs.ee)

### Right to reproduce and distribute Estonian Standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:  
Aru str 10 Tallinn 10317 Estonia; [www.evs.ee](http://www.evs.ee); Phone: +372 605 5050; E-mail: [info@evs.ee](mailto:info@evs.ee)

English Version

**Acoustics - Measurement of insertion loss of ducted silencers  
without flow - Laboratory survey method (ISO 11691:1995)**

Acoustique - Détermination de la perte d'insertion de  
silencieux en conduit sans écoulement - Méthode de  
mesurage en laboratoire (ISO 11691:1995)

Akustik - Messung des Einfügungsdämpfungsmaßes von  
Schalldämpfern in Kanälen ohne Strömung -  
Laborverfahren der Genauigkeitsklasse 3 (ISO  
11691:1995)

This European Standard was approved by CEN on 3 August 2009.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

## Foreword

The text of ISO 11691:1995 has been prepared by Technical Committee ISO/TC 43 "Acoustics" of the International Organization for Standardization (ISO) and has been taken over as EN ISO 11691:2009 by Technical Committee CEN/TC 211 "Acoustics" the secretariat of which is held by DS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by January 2010, and conflicting national standards shall be withdrawn at the latest by January 2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 11691:1995.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EC Directives.

For relationship with EC Directives, see informative Annexes ZA and ZB, which are integral parts of this document.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

### Endorsement notice

The text of ISO 11691:1995 has been approved by CEN as a EN ISO 11691:2009 without any modification.

**Annex ZA**  
(informative)

**Relationship between this European Standard and the Essential  
Requirements of EU Directive 98/37/EC**

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association to provide a means of conforming to Essential Requirements of the New Approach Directive 98/37/EC, amended by 98/79/EC on machinery.

Once this standard is cited in the Official Journal of the European Communities under that Directive and has been implemented as a national standard in at least one Member State, compliance with the normative clauses of this standard confers, within the limits of the scope of this standard, a presumption of conformity with the relevant Essential Requirements of that Directive and associated EFTA regulations.

**WARNING** - Other requirements and other EU Directives may be applicable to the product(s) falling within the scope of this standard.

## **Annex ZB** (informative)

### **Relationship between this European Standard and the Essential Requirements of EU Directive 2006/42/EC**

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association to provide a means of conforming to Essential Requirements of the New Approach Directive 2006/42/EC on machinery.

Once this standard is cited in the Official Journal of the European Communities under that Directive and has been implemented as a national standard in at least one Member State, compliance with the normative clauses of this standard confers, within the limits of the scope of this standard, a presumption of conformity with the relevant Essential Requirements of that Directive and associated EFTA regulations.

**WARNING —** Other requirements and other EU Directives may be applicable to the product(s) falling within the scope of this standard.

This document is a preview generated by EVS

## Introduction

The insertion loss of absorbent silencers is generally not affected by the air flow, provided that the flow velocity does not exceed approximately 20 m/s in the narrowest cross-section of the silencer. In practice, non-uniform flow distributions must be considered, therefore the limit velocity of 20 m/s corresponds to a design velocity of 10 m/s to 15 m/s.

# Acoustics — Measurement of insertion loss of ducted silencers without flow — Laboratory survey method

## 1 Scope

### 1.1 General

This International Standard specifies a laboratory substitution method to determine the insertion loss without flow of ducted, mainly absorbent, circular and rectangular silencers, as well as other duct elements for use in ventilating and air-conditioning systems.

NOTE 1 Laboratory measurement procedures for ducted silencers with superimposed flow are described in ISO 7235.

This International Standard is applicable to silencers where the design velocity does not exceed 15 m/s. As the method does not include self-generated flow noise, this International Standard is not suitable for tests on silencers where this type of noise is of great importance for the evaluation of the silencer performance.

The insertion loss determined according to this International Standard in a laboratory will not necessarily be the same as the insertion loss that will be obtained in an installation in the field. Different sound and flow fields in the duct will yield different results. As this International Standard requires regular test ducts, the results may include some flanking transmission via structural vibrations in the duct walls, that sets an upper limit to the insertion loss that can be determined.

NOTE 2 ISO 7235 gives methods for determining this limit.

This International Standard is intended to be used for circular silencers with diameters of 80 mm to 2 000 mm or rectangular silencers with cross-sectional areas within the same range.

### 1.2 Measurement uncertainty

Exact information on the precision of the method cannot be given at this time. Therefore this International Standard is denoted a survey standard.

Interlaboratory tests are necessary for the determination of the standard deviation of reproducibility,  $\sigma_R$ , of the method (relevant terms and methods are given in ISO 5725-1). It is, however, estimated that this method will have a  $\sigma_R$  which is comparable to that of ISO 7235. See table 1.

**Table 1 — Estimated values of the standard deviation of reproducibility**

Midband frequencies of one-third-octave band Hz	Standard deviation of reproducibility, $\sigma_R$ dB
50 to 1 250	2
1 600 to 10 000	3

## 2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this International Standard. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

ISO 3741:1988, *Acoustics — Determination of sound power levels of noise sources — Precision methods for broad-band sources in reverberation rooms*.



ISO 3743-1:1994, *Acoustics — Determination of sound power levels of noise sources — Engineering methods for small, movable sources in reverberant fields — Part 1: Comparison method for hard-walled test rooms.*

ISO 3744:1994, *Acoustics — Determination of sound power levels of noise sources using sound pressure — Engineering method in an essentially free field over a reflecting plane.*

ISO 7235:1991, *Acoustics — Measurement procedures for ducted silencers — Insertion loss, flow noise and total pressure loss.*

ISO 9614-1:1993, *Acoustics — Determination of sound power levels of noise sources using sound intensity — Part 1: Measurement at discrete points.*

IEC 651:1979, *Sound level meters*, and Amendment 1:1993.

IEC 804:1985, *Integrating-averaging sound level meters*, Amendment 1:1989 and Amendment 2:1993.

IEC 942:1988, *Sound calibrators.*

IEC 1260:—<sup>1)</sup>, *Electroacoustics — Octave-band and fractional-octave-band filters.*

### 3 Definitions

For the purposes of this International Standard, the following definitions apply.

**3.1 insertion loss, *D*:** Reduction in level of sound power propagating through a duct due to the insertion of a silencer into the duct system in place of a substitution duct. It is expressed in decibels.

**3.2 test duct:** Straight standard duct of constant cross-section in front of and behind the silencer under test. The purpose of the test ducts is to separate the test object from the sound source and the reverberation room.

**3.3 substitution duct:** Standard duct element having, if possible, the same length and same connecting cross-sections as the test object. It is conical if the cross-sectional areas of the entrance and exit of the silencer are different from each other. If the planes of the connections of the silencer are not parallel to each other, the connections shall be made with smooth curved ducts with a bend radius of the walls as large as possible.

**3.4 transition element:** Element which fits and connects the duct of the sound source to the test duct and, in some cases, the test duct to the silencer.

**3.5 standard duct:** Sheet metal duct commercially available directly from stock and normally used in practical applications together with the silencer under test.

NOTE 3 Normal wall thicknesses for standard ducts lie in the range 0,4 mm for small circular ducts to 1,25 mm for large circular ducts. A common thickness for rectangular ducts is 0,9 mm.

## 4 Test facility

### 4.1 General

The test facility shall consist of the equipment shown in figure 1. It contains the following:

- the sound measuring equipment (see 4.2);
- the sound source equipment (see 4.3);
- the transition element(s) (see 4.4);
- the test ducts (see 4.5);
- the substitution duct (see 4.5);
- the measurement environment appropriate to the standard used to determine the sound power level.

NOTE 4 If ISO 3741 is used to determine the sound power level, a reverberation room is used (see 4.6). This is the preferred method.

### 4.2 Sound measuring equipment

The instrumentation system, including the microphone and cable, shall meet the requirements for a type 1 instrument specified in IEC 651 or, in the case of integrating-averaging sound level meters, the requirements of IEC 804. Filters shall meet the requirements of IEC 1260.

Before and after each series of measurements, a class 1 sound calibrator complying with IEC 942 with a tolerance of  $\pm 0,3$  dB shall be applied to the microphone for verifying the calibration of the entire measuring system at one or more frequencies over the frequency range of interest.

1) To be published. (Revision of IEC 225:1966.)