Eurocode 4:

Design of composite steel and concrete structures Part 1-1: General rules and rules for buildings

Eurokoodeks 4:

Terasest ja betoonist komposiitkonstruktsioonide projekteerimine

Osa 1-1: Üldreeglid ja reeglid hoonete projekteerimiseks



EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 1994-1-1:2006+NA:2007 sisaldab Euroopa standardi EN 1994-1-1:2004 ingliskeelset teksti ning Eesti rahvuslikku lisa NA:2007.

This Estonian Standard EVS-EN 1994-1-1:2006+NA:2007 consists of the Standard English of the European EN 1994-1-1:2004 and the Estonian National Annex NA:2007.

Standard on sellekohase teate avaldamisega EVS Teatajas.

This has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.

standardimisorganisatsioonide Euroopa poolt liikmetele **E**uroopa standardi rahvuslikele teksti kättesaadavaks tegemise kuupäev on 15.12.2004.

Date of Availability of the European standard text is 15.12.2004.

Standard on kättesaadav Eesti Sandardikeskusest.

Window, is a preview denerated by this was a preview denerated by the preview dener The standard is available from Estonian Centre for

ICS 91.010.30; 91.080.10; 91.080.40

Standardite reprodutseerimis- ja levitamisõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega: Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon: 605 5050; e-post: info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone: 605 5050; e-mail: info@evs.ee

EUROPEAN STANDARD

EN 1994-1-1

NORME EUROPÉENNE EUROPÄISCHE NORM

December 2004

ICS 91.010.30; 91.080.10; 91.080.40

Supersedes ENV 1994-1-1:1992

English version

Focode 4: Design of composite steel and concrete structures Part 1-1: General rules and rules for buildings

Eurocode 4: Calcul des ain uctures mixtes acier-béton -Partie 1-1: Règles générales et règles our les bâtiments Eurocode 4: Bemessung und Konstruktion von Verbundtragwerken aus Stahl und Beton - Teil 1-1: Allgemeine Bemessungsregeln und Anwendungsregeln für den Hochbau

This European Standard was approve EN on 27 May 2004.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria Begium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents	Page
Foreword	. 8
Section 1 General	12
1.1 Scope	. 12
1.1.1 Scope of Eurocode 4.	12
1.1.2 Scope of Part 1.1 of Eurocode 4.	
1.2 Normative references	
1.2.1 General reference standards	13
1.2.2 Other reference spandards	
1.4 Distinction between principles and application rules.	14
1.5 Definitions	14
1.5.1 General	14
1.5.7 Additional terms and definitions used in this Standard	14
1 6 Symbols	15
2.	10
1.6 Symbols	22
\sim	
1 Doguromonto	22
2.2 Principles of limit state design	23
2.3 Basic variables.	23
2.3.1 Actions and environmental influences 2.3.2 Material and product properties 2.3.3 Classification of actions 2.4 Verification by the partial factor method. 2.4.1 Design values	23
2.3.2 Material and product properties.	23
2.3.3 Classification of actions	23
2.4 Verification by the partial factor method.	. 23
2.4.1 Design values.	23
2.4.1 Design values 2.4.1.1 Design values of actions	23
2.4.1.1 Design values of actions. 2.4.1.2 Design values of material or product properties. 2.4.1.3 Design values of geometrical data. 2.4.1.4 Design resistances 2.4.2 Combination of actions. 2.4.3 Verification of static equilibrium (EQU).	23
2.4.1.3 Design values of geometrical data	24
2.4.1.4 Design resistances	. 24
2.4.2 Combination of actions.	24
2.4.3 Verification of static equilibrium (EQU)	24
Section 3 Materials	24
3.1 Concrete	24
3.1 Concrete	25
3.2 Reinforcing steel	
	25 25
3.4 Connecting devices.	
3.4.1 General	25
3.5 Profiled steel sheeting for composite slabs in buildings	25
Section 4 Durability	25
4.1 General	
4.2 Profiled steel sheeting for composite slabs in buildings	. ∠0

Section 5 Structural analysis	26
5.1 Structural modelling for analysis	26
\mathcal{E}	26
	26
	26
	27
J	27
	27
	28
5.3.2 Imperfections in buildings	28
5.3.2.1 General.	28
5.3.2.2 Global imperfections.	29
5.3.2.3 Member imperfections	29
5.4 Calculation of action effects.	
5.4.1 Methods of global analysis	
5.4.1.1 General	29
5.4.2 Linear elastic analysis.	30
5.4.2 Linear elastic analysis 5.4.2.1 General 5.4.2.1	30
5.4.2.2 Creep and shrinkage	31
5.4.2.2 Creep and shrinkage	32
5.4.2.4 Stages and sequence of construction.	33
5 4 2 5 Temperature effects	33
5.4.2.6 Pre-stressing by controlled imposed deformations	33
5.4.3 Non-linear global analysis	33
5.4.4 Linear elastic analysis with limited redistribution for buildings	34
5.4.5 Rigid plastic global analysis for buildings	35
5.5 Classification of cross-sections.	36
5.5 Classification of cross-sections. 5.5.1 General.	36
5.5.2 Classification of composite sections without conce encasement	37
5.5.3 Classification of composite sections for buildings with concrete	
encasement	37
Section 6 Ultimate limit states.	38
6.1 Beams	38
6.1.1 Reams for buildings	
6.1.1 Beams for buildings	40
6.2 Resistances of cross-sections of beams.	40
6.2.1 Bending resistance.	40
	40
	40
6.2.1.3 Plastic resistance moment of sections with partial shear	10
1	42
	43
	44
· · · · · · · · · · · · · · · · · · ·	45
	45
1	45

6.2.2.3 Shear buckling resistance	45
6.2.2.4 Bending and vertical shear	45
6.3 Resistance of cross-sections of beams for buildings with partial	
encasement	46
6.3.1 Scope	
6.3.2 Bending resistance	46
6.3.3 Resistance to vertical shear.	47
6.3.4 Bending and vertical shear.	
6.4 Lateral-torsional buckling of composite beams	48
6.4.1 General	48
6.4.2 Verification of ateral-torsional buckling of continuous composite	
beams with cross sections in Class 1, 2 and 3 for buildings	
6.4.3 Simplified verification for buildings without direct calculation	51
6.5 Transverse forces on webs	52
6.5.1 General	52
6.5.2 Flange-induced buckling of webs.	52
6.6 Shear connection	52
6.6.1 General	52
6.6 Shear connection. 6.6.1 General. 6.6.1.1 Basis of design.	52
6.6.1.2 Limitation on the use of partial shear connection in beams	
	53
6.6.1.3 Spacing of shear connectors is earns for buildings	
6.6.2 Longitudinal shear force in beams for buildings	55
6.6.2.1 Beams in which non-linear or elastic theory is used for	
resistances of one or more cross-sections.	55
6.6.2.2 Beams in which plastic theory is used to resistance of	
cross-sections.	55
6.6.3 Headed stud connectors in solid slabs and concrete encasement	55
6.6.3.1 Design resistance	55
6.6.3.2 Influence of tension on shear resistance	56
6.6.4 Design resistance of headed studs used with profiled steet sheeting	
in buildings.	56
6.6.4.1 Sheeting with ribs parallel to the supporting beams.	56
6.6.4.2 Sheeting with ribs transverse to the supporting beams \(\mathbb{N} \)	57
6.6.4.3 Biaxial loading of shear connectors. 6.6.5 Detailing of the shear connection and influence of execution.	58
6.6.5 Detailing of the shear connection and influence of execution	58
6.6.5.1 Resistance to separation.	58
6.6.5.2 Cover and concreting for buildings. 6.6.5.3 Local reinforcement in the slab.	58
6.6.5.3 Local reinforcement in the slab.	59
6.6.5.4 Haunches other than formed by profiled steel sheeting)59
6.6.5.5 Spacing of connectors.	60
6.6.5.6 Dimensions of the steel flange.	
6.6.5.7 Headed stud connectors.	
6.6.5.8 Headed studs used with profiled steel sheeting in buildings	
6.6.6 Longitudinal shear in concrete slabs.	
6.6.6.1 General	
6.6.6.2 Design resistance to longitudinal shear.	61
6.6.6.3 Minimum transverse reinforcement.	62
6.6.4 Longitudinal shear and transverse reinforcement in beams	
for buildings	62

6.7 Composite columns and composite compression members	63
6.7.1 General	63
6.7.2 General method of design	65
6.7.3 Simplified method of design	66
6.7.3.1 General and scope.	66
6.7.3.2 Resistance of cross-sections	67
6.7.3.3 Effective flexural stiffness, steel contribution ratio and	
relative slenderness	69
6.7.3.4 Methods of analysis and member imperfections	
6.7.3.5 Resistance of members in axial compression	70
6.7.3.6 Resistance of members in combined compression and	
uniaxial bending	
6.7.3.7 Combined compression and biaxial bending	
6.7.4 Shear connection and load introduction.	
6.7.4.1 General. Q	
6.7.4.2 Load introduction.	
6.7.4.3 Longitudinal spear outside the areas of load introduction	77
6.7.5 Detailing Provisions. 6.7.5.1 Concrete cover of steel profiles and reinforcement.	76
6.7.5.1 Concrete cover of steel profiles and reinforcement	78
6.7.5.2 Longitudinal and transverse reinforcement. 6.8 Fatigue. 6.8.1 General.	78
6.8 Fatigue	78
6.8.1 General	78
6.8.2 Partial factors for fatigue assessment for buildings	79
6.8.3 Fatigue strength.	79
6.8.4 Internal forces and fatigue loadings	80
6.8.2 Partial factors for fatigue assessment for buildings. 6.8.3 Fatigue strength. 6.8.4 Internal forces and fatigue loadings. 6.8.5 Stresses 6.8.5.1 General. 6.8.5.2 Concrete.	80
6.8.5.1 General	80
6.8.5.2 Concrete	80
6.8.5.2 Concrete 6.8.5.3 Structural steel 6.8.5.4 Reinforcement 6.8.5.5 Shear connection 6.8.6 Stress ranges 6.8.6.1 Structural steel and reinforcement 6.8.6.2 Shear connection	80
6.8.5.4 Reinforcement.	81
6.8.5.5 Shear connection.	81
6.8.6 Stress ranges	82
6.8.6.1 Structural steel and reinforcement.	82
6.8.6.2 Shear connection	82
6.8.7 Fatigue assessment based on nominal stress ranges 6.8.7 I Structural steel, reinforcement, and concrete	83
6.8.7.1 Structural steel, reinforcement, and concrete	83
6.8.7.2 Shear connection.	83
Section 7 Serviceability limit states	84
7.1 General	84
7.2 Stresses	
7.2.1 General	
7.2.2 Stress limitation for buildings.	
7.3 Deformations in buildings	
7.3.1 Deflections.	
7.3.2 Vibration.	
7.4 Cracking of concrete	
7.4.1 General	
7.4.2 Minimum reinforcement.	
7.4.3 Control of cracking due to direct loading	88

Section 8 Composite joints in frames for buildings	89
8.1 Scope	89
8.2 Analysis, modelling and classification	90
8.2.1 General	
8.2.2 Elastic global analysis	90
8.2.3 Classification of joints	
8.3 Design methods	
8.3.1 Basis and scope	
8.3.2 Resistance	
8.3.3 Rotational stiffiess	
8.3.4 Rotation capacity	91
8.4 Resistance of components 8.4.1 Scope 8.4.2 Basic joint components	92
8.4.1 Scope	92
8.4.2 Basic joint components	92
8.4.2.1 Longitudinal steel reinforcement in tension.	92
8.4.2.2 Steel contact plate in compression	92
8.4.3 Column web in transverse empression	93
8.4.4 Reinforced components 8.4.4.1 Column web panel in shear	93
8.4.4.1 Column web panel in shear	93
8.4.4.2 Column web in compression	93
Section 9 Composite slabs with profiled steel sheeting for buildings	0.4
9.1 General	94
9.1 General	94
9.1.1 Scope	94
9.1.2 Definitions	95
9.1.2.1 Types of shear connection.	95
() 1 2 2 Early choor connection am nortial choor composition	()4
9.2 Detailing provisions.	96
9.2.1 Slab thickness and reinforcement.	96
9.2.2 Aggregate	97
9.2 Detailing provisions. 9.2.1 Slab thickness and reinforcement. 9.2.2 Aggregate. 9.2.3 Bearing requirements. 9.3 Actions and action effects. 9.3.1 Design situations.	97
9.3 Actions and action effects.	97
9.3.1 Design situations.	97
9.5.2 Actions for profiled steel sheeting as shuttering	90
9.3.3 Actions for composite slab.	98
9.4 Analysis for internal forces and moments.	
9.4.1 Profiled steel sheeting as shuttering.	
9.4.2 Analysis of composite slab.	98
9.4.3 Effective width of composite slab for concentrated point and	00
line loads.	99
9.5 Verification of profiled steel sheeting as shuttering for ultimate	100
limit states.	100
9.6 Verification of profiled steel sheeting as shuttering for	100
serviceability limit states.	
9.7 Verification of composite slabs for ultimate limit states	
9.7.1 Design criterion	
9.7.3 Longitudinal shear for slabs without end anchorage	
9.7.4 Longitudinal shear for slabs with end anchorage	
7.1.7 Doughtuman shear for slaus with the anthorage	104

	9.7.5 Vertical shear	104
9.8.1 Control of cracking of concrete. 104 9.8.2 Deflection. 105 Annex A (Informative) Stiffness of joint components in buildings. 106 A.1 Scope. 106 A.2 Stiffness coefficients. 106 A.2.1 Basic toolt components. 106 A.2.1.1 Longitudinal steel reinforcement in tension. 106 A.2.1.2 Steel contact plate in compression. 106 A.2.2 Other composite is in composite joints. 108 A.2.2.1 Column web in inconverse compression. 108 A.2.2.2 Column web in inconverse compression. 108 A.2.3.1 Column web pagel in shear. 108 A.2.3.2 Column web in inconverse compression. 108 A.3 Deformation of the shear connection. 109 Annex B (Informative) Standard tests. 110 B.1 General. 110 B.2.2 Tests on shear connectors. 110 B.2.1 General. 110 B.2.2 Testing arrangements. 111 B.2.3 Testing procedure. 112 B.2.5 Test evaluation. 112 B.3.1 General. 113 B.3.2 Testing arrangement. 114 B.3.3 Preparation of specimen	9.7.6 Punching shear	104
9.8.1 Control of cracking of concrete. 104 9.8.2 Deflection. 105 Annex A (Informative) Stiffness of joint components in buildings. 106 A.1 Scope. 106 A.2 Stiffness coefficients. 106 A.2.1 Basic toolt components. 106 A.2.1.1 Longitudinal steel reinforcement in tension. 106 A.2.1.2 Steel contact plate in compression. 106 A.2.2 Other composite is in composite joints. 108 A.2.2.1 Column web in inconverse compression. 108 A.2.2.2 Column web in inconverse compression. 108 A.2.3.1 Column web pagel in shear. 108 A.2.3.2 Column web in inconverse compression. 108 A.3 Deformation of the shear connection. 109 Annex B (Informative) Standard tests. 110 B.1 General. 110 B.2.2 Tests on shear connectors. 110 B.2.1 General. 110 B.2.2 Testing arrangements. 111 B.2.3 Testing procedure. 112 B.2.5 Test evaluation. 112 B.3.1 General. 113 B.3.2 Testing arrangement. 114 B.3.3 Preparation of specimen	9.8 Verification of composite slabs for serviceability limit states	104
9.8.2 Deflection 105 Annex A (Informative) Stiffness of joint components in buildings 106 A.1 Scope. 106 A.2 Stiffness coedicients 106 A.2.1 Basic location of the stream of the str		
A.1 Scope		
A.1 Scope	Annex A (Informative) Stiffness of joint components in buildings	106
A.2 Stiffness coefficients. 106 A.2.1 Basic joint components. 106 A.2.1.1 Iongitudinal steel reinforcement in tension 106 A.2.1.2 Steel contact plate in compression. 106 A.2.2 Other completents in composite joints 108 A.2.2.1 Columb set by panel in shear. 108 A.2.2.2 Column web in transverse compression. 108 A.2.3.2 Reinforced components 108 A.2.3.1 Column web panel in shear. 108 A.2.3.2 Column web panel in shear. 108 A.2.3.2 Column web in transverse compression. 108 A.3.3 Deformation of the shear confection. 109 Annex B (Informative) Standard tests. 110 B.1 General 110 B.2.1 General 110 B.2.2 Testing arrangements. 110 B.2.3 Preparation of specimens. 111 B.2.4 Testing procedure. 112 B.2.5 Test evaluation 112 B.3.5 Testing of composite floor slabs 113 B.3.1 General 113 B.3.2 Testing of composite floor slabs 113 B.3.3 Testing of composite floor slabs 113 B.3.4 Test loading procedure. 115 B.3.5 Determination of specimens. 115 B.3.6 Determination of the design values for m and k 116 B.3.6 Determination of the design values for m and k 116 B.3.6 Determination of the design values for m and k 116 B.3.6 Determination of the design values for m and k 116 B.3.6 Determination of the design values for m and k 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118		
A.2.1 Basic just components. 106 A.2.1.1 Longitudinal steel reinforcement in tension. 106 A.2.1.2 Steel contact plate in compression. 106 A.2.2 Other composents in composite joints. 108 A.2.2.1 Column web panel in shear. 108 A.2.2.1 Column web in transverse compression. 108 A.2.2.2 Column web in transverse compression. 108 A.2.3.1 Column web panel in shear. 108 A.2.3.2 Column web in transverse compression. 108 A.3.2.5 Column web in transverse compression. 108 A.3 Deformation of the shear connection. 109 Annex B (Informative) Standard tests. 110 B.1 General 110 B.2.1 General 110 B.2.2 Testing arrangements 110 B.2.3 Preparation of specimens 111 B.2.4 Testing procedure 112 B.2.5 Test evaluation 112 B.3 Testing of composite floor slabs 113 B.3.1 General 113 B.3.2 Testing arrangement 114 B.3.3 Preparation of specimens 115 B.3.4 Test loading procedure 115 B.3.5 Determination of design values for m and k 116 B.3.6 Determination of the design values for m and k 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118		
A 2.1.1 Engitudinal steel reinforcement in tension 106 A 2.1.2 Steel contact plate in compression. 106 A 2.2.0 Other compose that in composite joints 108 A 2.2.1 Columb by banel in shear. 108 A 2.2.2 Column web in transverse compression. 108 A 2.3.3 Reinforced component 108 A 2.3.1 Column web pagel in shear. 108 A 2.3.2 Column web in transverse compression. 108 A 3.0 Deformation of the shear confection. 109 Annex B (Informative) Standard tests 110 B 1 General 110 B 2 Tests on shear connectors 110 B 2.1 General 110 B 2.2 Testing arrangements 110 B 2.3 Preparation of specimens 111 B 2.4 Testing procedure 112 B 2.5 Test evaluation 112 B 3.1 General 113 B 3.1 General 114 B 3.3 Preparation of specimens 115 B 3.4 Testing of composite floor slabs 113 B 3.3 Preparation of specimens 115 B 3.4 Test loading procedure 115 B 3.5 Determination of design values for m and k 116 B 3.6 Determination of the design values for m and k 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118		
A.2.1.2 Steel contact plate in compression. 106 A.2.2 Other completents in composite joints. 108 A.2.2.1 Columb web panel in shear. 108 A.2.2.2 Column web in transverse compression. 108 A.2.3.2 Column web in transverse compression. 108 A.2.3.1 Column web panel in shear. 108 A.2.3.2 Column web panel in shear. 108 A.2.3.2 Column web in transverse compression. 108 A.3 Deformation of the shear connection. 109 Annex B (Informative) Standard tests. 110 B.1 General. 110 B.2.1 General. 110 B.2.2 Tests on shear connectors. 110 B.2.3 Preparation of specimens. 111 B.2.4 Testing arrangements. 110 B.2.5 Test evaluation. 112 B.3.5 Test ing procedure. 112 B.3.1 General. 113 B.3.2 Testing of composite floor slabs. 113 B.3.3 Preparation of specimens. 114 B.3.3 Preparation of specimens. 115 B.3.4 Test loading procedure. 115 B.3.5 Determination of design values for m and k 116 B.3.6 Determination of the design values for m and k 116 B.3.6 Determination of the design values for $r_{u,Rd}$ 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118	5V ±	
A.2.2 Other composite is in composite joints. A.2.2.1 Column web panel in shear. A.2.2.2 Column web in transverse compression. A.2.3 Reinforced component. A.2.3.1 Column web papel in shear. A.2.3.2 Column web papel in shear. A.2.3.2 Column web in transverse compression. A.3 Deformation of the shear connection. Annex B (Informative) Standard tests. I10 B.1 General. B.2 Tests on shear connectors. B.2.1 General. B.2.2 Testing arrangements. B.2.3 Preparation of specimens. B.2.4 Testing procedure. B.2.5 Test evaluation. B.3.5 Testing of composite floor slabs. B.3.1 General. B.3.2 Testing arrangement. B.3.3 Preparation of specimens. B.3.4 Test loading procedure. B.3.5 Determination of design values for m and k . B.3.6 Determination of the design values for m and k . B.3.7 Annex C (Informative) Shrinkage of concrete for composite structures for buildings.		
A.2.2.1 Columb web panel in shear. A.2.2.2 Column web in transverse compression. A.2.3 Reinforced components. A.2.3 Reinforced components. A.2.3.1 Column web panel in shear. A.2.3.2 Column web in transverse compression. A.3 Deformation of the shear connection. 108 Annex B (Informative) Standard tests. 110 B.1 General. B.2 Tests on shear connectors. 110 B.2.1 General. B.2.1 General. B.2.2 Testing arrangements. 110 B.2.3 Preparation of specimens. 111 B.2.4 Testing procedure. 112 B.2.5 Test evaluation. 112 B.3 Testing of composite floor slabs. 113 B.3.1 General. 113 B.3.2 Testing arrangement. 114 B.3.3 Preparation of specimens. 115 B.3.4 Test loading procedure. 115 B.3.5 Determination of design values for m and k . 116 B.3.6 Determination of the design values for m and k . 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118		
A.2.2.2 Column web in transverse compression	A 2.2.1 Column web nanel in shear	108
A.2.3 Reinforced components A.2.3.1 Column web papel in shear. A.2.3.2 Column web in transverse compression. A.3 Deformation of the shear connection. 109 Annex B (Informative) Standard tests. 110 B.1 General. 110 B.2 Tests on shear connectors. 110 B.2.1 General. 110 B.2.2 Testing arrangements. 110 B.2.3 Preparation of specimens. 111 B.2.4 Testing procedure. 112 B.2.5 Test evaluation. 112 B.3.1 General. 113 B.3.2 Testing of composite floor slabs. 113 B.3.2 Testing arrangement. 114 B.3.3 Preparation of specimens. 115 B.3.4 Test loading procedure. 115 B.3.5 Determination of design values for m and k . 116 B.3.6 Determination of the design values for $\tau_{\text{U,Rd}}$. 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118		
A.2.3.1 Column web papel in shear. A.2.3.2 Column web in transverse compression. A.3 Deformation of the shear connection. 109 Annex B (Informative) Standard tests. 110 B.1 General. B.2.1 Tests on shear connectors. B.2.1 General. B.2.2 Testing arrangements. B.2.3 Preparation of specimens. 110 B.2.4 Testing procedure. B.2.5 Test evaluation. B.3.1 General. B.3.1 General. B.3.2 Testing of composite floor slabs. 113 B.3.2 Testing arrangement. B.3.3 Preparation of specimens. 114 B.3.3 Preparation of specimens. 115 B.3.4 Test loading procedure. 115 B.3.5 Determination of design values for m and k . 116 B.3.6 Determination of the design values for $\tau_{\text{U,Rd}}$. 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings.		
A.2.3.2 Column web in transverse compression. A.3 Deformation of the shear connection. 109 Annex B (Informative) Standard tests. 110 B.1 General. B.2 Tests on shear connectors. B.2.1 General. B.2.2 Testing arrangements. 110 B.2.3 Preparation of specimens. 111 B.2.4 Testing procedure. 112 B.2.5 Test evaluation. 112 B.3 Testing of composite floor slabs. 113 B.3.1 General. 113 B.3.2 Testing arrangement. 114 B.3.3 Preparation of specimens. 115 B.3.4 Test loading procedure. 115 B.3.5 Determination of design values for m and k . 116 B.3.6 Determination of the design values for $\tau_{u,Rd}$. 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118		
A.3 Deformation of the shear confection. 109 Annex B (Informative) Standard tests. 110 B.1 General. 110 B.2 Tests on shear connectors. 110 B.2.1 General. 110 B.2.2 Testing arrangements. 110 B.2.3 Preparation of specimens. 111 B.2.4 Testing procedure. 112 B.2.5 Test evaluation. 112 B.3 Testing of composite floor slabs. 113 B.3.1 General. 113 B.3.2 Testing arrangement. 114 B.3.3 Preparation of specimens. 115 B.3.4 Test loading procedure. 115 B.3.5 Determination of design values for m and k 116 B.3.6 Determination of the design values for $\tau_{u,Rd}$. 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118	A 2 3 2 Column web in transverse compression	108
Annex B (Informative) Standard tests. B.1 General. B.2 Tests on shear connectors. B.2.1 General. B.2.2 Testing arrangements. B.2.3 Preparation of specimens. B.2.4 Testing procedure. B.2.5 Test evaluation. B.3 Testing of composite floor slabs. B.3.1 General. B.3.2 Testing arrangement. B.3.3 Preparation of specimens. B.3.4 Test loading procedure. B.3.5 Determination of design values for m and k . B.3.6 Determination of the design values for $\tau_{u,Rd}$. Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118	A 3 Deformation of the shear conjection	109
B.1 General	40	10)
B.1 General	Annex B (Informative) Standard tests.	110
B.2.5 Test evaluation. 112 B.3 Testing of composite floor slabs. 113 B.3.1 General. 113 B.3.2 Testing arrangement. 114 B.3.3 Preparation of specimens. 115 B.3.4 Test loading procedure. 115 B.3.5 Determination of design values for m and k . 116 B.3.6 Determination of the design values for $\tau_{u,Rd}$. 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118	B 1 General	110
B.2.5 Test evaluation. 112 B.3 Testing of composite floor slabs. 113 B.3.1 General. 113 B.3.2 Testing arrangement. 114 B.3.3 Preparation of specimens. 115 B.3.4 Test loading procedure. 115 B.3.5 Determination of design values for m and k . 116 B.3.6 Determination of the design values for $\tau_{u,Rd}$. 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118	B 2 Tests on shear connectors	110
B.2.5 Test evaluation. 112 B.3 Testing of composite floor slabs. 113 B.3.1 General. 113 B.3.2 Testing arrangement. 114 B.3.3 Preparation of specimens. 115 B.3.4 Test loading procedure. 115 B.3.5 Determination of design values for m and k . 116 B.3.6 Determination of the design values for $\tau_{u,Rd}$. 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118	B 2.1 General	110
B.2.5 Test evaluation. 112 B.3 Testing of composite floor slabs. 113 B.3.1 General. 113 B.3.2 Testing arrangement. 114 B.3.3 Preparation of specimens. 115 B.3.4 Test loading procedure. 115 B.3.5 Determination of design values for m and k . 116 B.3.6 Determination of the design values for $\tau_{u,Rd}$. 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118	B 2.2 Testing arrangements	110
B.2.5 Test evaluation. 112 B.3 Testing of composite floor slabs. 113 B.3.1 General. 113 B.3.2 Testing arrangement. 114 B.3.3 Preparation of specimens. 115 B.3.4 Test loading procedure. 115 B.3.5 Determination of design values for m and k . 116 B.3.6 Determination of the design values for $\tau_{u,Rd}$. 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118	B 2 3 Preparation of specimens	111
B.2.5 Test evaluation. 112 B.3 Testing of composite floor slabs. 113 B.3.1 General. 113 B.3.2 Testing arrangement. 114 B.3.3 Preparation of specimens. 115 B.3.4 Test loading procedure. 115 B.3.5 Determination of design values for m and k . 116 B.3.6 Determination of the design values for $\tau_{u,Rd}$. 117 Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 118	B.2.4 Testing procedure	112
Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 117	B.2.5 Test evaluation.	112
Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 117	B.3 Testing of composite floor slabs.	113
Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 117	B.3.1 General	113
Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 117	B.3.2 Testing arrangement.	.114
Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 117	B.3.3 Preparation of specimens	115
Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 117	B.3.4 Test loading procedure.	.115
Annex C (Informative) Shrinkage of concrete for composite structures for buildings. 117	B.3.5 Determination of design values for m and k .	116
Annex C (Informative) Shrinkage of concrete for composite structures for buildings	B.3.6 Determination of the design values for τ_{uRd} .	117
for buildings		
for buildings	Annex C (Informative) Shrinkage of concrete for composite structures	
		118
Bibliography118		
	Bibliography	118

Foreword

This document (EN 1994-1-1:2004), Eurocode 4: Design of composite steel and concrete structures: Part 1-1 General rules and rules for buildings, has been prepared on behalf of Technical Committee CEN/TC 250 "Structural Eurocodes", the Secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2005, and conflicting national standards shall be withdrawn at the latest by March 2010.

This document supersedes ENV 1994-1-1:1992.

CEN/TC 250 is responsible for all Structural Eurocodes.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

Background of the Eurocode programme

In 1975, the Commission of the European Community decided on an action programme in the field of construction, based on article 95 of the Lenty. The objective of the programme was the elimination of technical obstacles to trade and the harmonisation of technical specifications.

Within this action programme, the Commission took the initiative to establish a set of harmonised technical rules for the design of construction works which, in a first stage, would serve as an alternative to the national rules in force in the Member States and, ultimately, would replace them.

For fifteen years, the Commission, with the help of a Steering Committee with Representatives of Member States, conducted the development of the Eurocodes programme, which led to the first generation of European codes in the 1980s.

In 1989, the Commission and the Member States of the EU and EFTA decided, on the basis of an agreement¹ between the Commission and CEN, to transfer the preparation and the publication of the Eurocodes to CEN through a series of Mandates, in order to provide them with a future status of European Standard (EN). This links *de facto* the Eurocodes with the provisions of all the Council's Directives and/or Commission's Decisions dealing with European standards *(e.g.* the Council Directive 89/106/EEC on construction products - CPD - and Council Directives 93/37/EEC, 92/50/EEC and 89/440/EEC on public works and services and equivalent EFTA Directives initiated in pursuit of setting up the internal market).

The Structural Eurocode programme comprises the following standards generally consisting of a number of Parts:

8

¹ Agreement between the Commission of the European Communities and the European Committee for Standardisation (CEN) concerning the work on EUROCODES for the design of building and civil engineering works (BC/CEN/03/89).

EN 1990	Eurocode:	Basis of Structural Design
EN 1991	Eurocode 1:	Actions on structures
EN 1992	Eurocode 2:	Design of concrete structures
EN 1993	Eurocode 3:	Design of steel structures
EN 1994	Eurocode 4:	Design of composite steel and concrete structures
EN 1995	Eurocode 5:	Design of timber structures
EN 1996	Eurocode 6:	Design of masonry structures
EN 1997	Eurocode 7:	Geotechnical design
EN 1998	Eurocode 8:	Design of structures for earthquake resistance
EN 1999	Eurocode 9:	Design of aluminium structures

Eurocode standards recognise the responsibility of regulatory authorities in each Member State and have safeguarded their right to determine values related to regulatory safety matters at national level where these continue to ary from State to State.

Status and field of application of Eurocodes

The Member States of the EU and EFTA recognise that Eurocodes serve as reference documents for the following purposes:

- as a means to prove compliance of building and civil engineering works with the essential requirements of Council Directive 89/106/EEC, particularly Essential Requirement N°1 Mechanical resistance and stability and Essential Requirement N°2 Safety in case of fire;
- as a basis for specifying contracts for construction works and related engineering services;
- as a framework for drawing up harmonised technical specifications for construction products (ENs and ETAs)

The Eurocodes, as far as they concern the construction works themselves, have a direct relationship with the Interpretative Documents² referred to in Article 12 of the CPD, although they are of a different nature from harmonised product standards³. Therefore, technical aspects arising from the Eurocodes work need to be adequately considered by CEN technical Committees and/or EOTA Working Groups working on product standards with a view to prieving full compatibility of these technical specifications with the Eurocodes.

The Eurocode standards provide common structural design rules for weryday use for the design of whole structures and component products of both a traditional and an innevative nature. Unusual forms of construction or design conditions are not specifically covered and additional expert consideration will be required by the designer in such cases.

² According to Art. 3.3 of the CPD, the essential requirements (ERs) shall be given concrete form in interpretative documents for the creation of the necessary links between the essential requirements and the mandates for harmonised ENs and ETAGs/ETAs.

³ According to Art. 12 of the CPD the interpretative documents shall:

a) give concrete form to the essential requirements by harmonising the terminology and the technical bases and indicating classes or levels for each requirement where necessary;

b) indicate methods of correlating these classes or levels of requirement with the technical specifications, e.g. methods of calculation and of proof, technical rules for project design, etc.;

c) serve as a reference for the establishment of harmonised standards and guidelines for European technical approvals.

The Eurocodes, de facto, play a similar role in the field of the ER 1 and a part of ER 2.

National Standards implementing Eurocodes

The National Standards implementing Eurocodes will comprise the full text of the Eurocode (including any annexes), as published by CEN, which may be preceded by a National title page and National foreword, and may be followed by a National annex.

The National annex may only contain information on those parameters which are left open in the Eurocode for national choice, known as Nationally Determined Parameters, to be used for the design of buildings and civil engineering works to be constructed in the country concerned, i.e.:

- values and/or classes where alternatives are given in the Eurocode,
- values to be used where a symbol only is given in the Eurocode,
- country specific data (go raphical, climatic, etc.), e.g. snow map,
- the procedure to be used where alternative procedures are given in the Eurocode.

It may also contain

- decisions on the use of informative annexes, and references to non-contradictory emplementary information to assist the user to apply the Eurocode.

Links between Eurocodes and harmonised technical specifications (ENs and ETAs) for products

There is a need for consistency between the harminised technical specifications for construction products and the technical rules for works⁴. Furthermore, all the information accompanying the CE Marking of the construction products which refer Eurocodes shall clearly mention which Nationally Determined Parameters have been taken into account.

Additional information specific to EN 1994-1-1

EN 1994-1-1 describes the Principles and requirements for sates, serviceability and durability of composite steel and concrete structures, together with specific provisions for buildings. It is based on the limit state concept used in conjunction with a partial factor method.

For the design of new structures, EN 1994-1-1 is intended to be used, for direct application, together with other Parts of EN 1994, Eurocodes EN 1990 to 1993 and Eurocodes EN 1997 and 1998.

EN 1994-1-1 also serves as a reference document for other CEN TCs concerning nctural matters.

EN 1994-1-1 is intended for use by:

- committees drafting other standards for structural design and related product, testing and execution standards:
- clients (e.g. for the formulation of their specific requirements on reliability levels and durability);
- designers and constructors;
- relevant authorities.

⁴ see Art.3.3 and Art.12 of the CPD, as well as clauses 4.2, 4.3.1, 4.3.2 and 5.2 of ID 1.

Numerical values for partial factors and other reliability parameters are recommended as basic values that provide an acceptable level of reliability. They have been selected assuming that an appropriate level of workmanship and of quality management applies. When EN 1994-1-1 is used as a base document by other CEN/TCs the same values need to be taken.

National annex for EN 1994-1-1

This standard gives values with notes indicating where national choices may have to be made. Therefore the National Standard implementing EN 1994-1-1 should have a National annex containing all Nationally Determined Parameters to be used for the design of buildings and civil engineering works to be constructed in the relevant country.

National choice is allowed in EN 1994-1-1 through the following clauses:

- 2.4.1.1(1)
- 2.4.1.2(5)
- 2.4.1.2(6)
- 2.4.1.2(7)
- 3.1(4)
- 3.5(2)
- 6.4.3(1)(h)
- 6.6.3.1(1)
- 6.6.3.1(3)
- 6.6.4.1(3)
- 6.8.2(1)
- 6.8.2(2)
- 9.1.1(2)
- 9.6(2)
- 9.7.3(4)
- 9.7.3(8)
- 9.7.3(9)
- B.2.5(1)
- B.3.6(5)

accompany is a preview denerated by this

Section 1 General

1.1 Scope

1.1.1 Scope of Eurocode 4

- (1) Eurocode 4 applies to the design of composite structures and members for buildings and civil engineering works. It complies with the principles and requirements for the safety and serviceability of structures, the basis of their design and verification that are given in EN 1990 - Basis of structural design.
- (2) Eurocode 4 is concerned only with requirements for resistance, serviceability, durability and fire resistance of composite structures. Other requirements, e.g. concerning thermal or sound insulation, are not considered.
- eused in conjunction with: (3) Eurocode 4 is intended to

EN 1990 Eurocode: Basis of structural design

EN 1991 Eurocode 1: Actions on structures

ENs, hENs, ETAGs and ETAs for construction products relevant for composite structures

EN 1090 Execution of steel structures and Juminium structures

EN 13670 Execution of concrete structures

EN 1992 Eurocode 2: Design of concrete structure

EN 1993 Eurocode 3: Design of steel structures

EN 1997 Eurocode 7: Geotechnical design

EN 1998 Eurocode 8: Design of structures for earthquake resistance, when composite structures are built in seismic regions.

(4) Eurocode 4 is subdivided in various parts:

Part 1-1: General rules and rules for buildings

Part 1-2: Structural fire design

Part 2: Bridges.

- 1.1.2 Scope of Part 1-1 of Eurocode 4

 (1) Part 1-1 of Eurocode 4 gives a general basis for the design of composite structures together with specific rules for buildings.
- (2) The following subjects are dealt with in Part 1-1:

Section 1: General

Section 2: Basis of design

Section 3: Materials

Section 4: Durability

Section 5: Structural analysis

Section 6: Ultimate limit states

Section 7: Serviceability limit states

Section 8: Composite joints in frames for buildings

Section 9: Composite slabs with profiled steel sheeting for buildings

1.2 Normative references

The following normative documents contain provisions which, through references in this text, constitute provisions of this European standard. For dated references, subsequent amendments to or revisions of any of these publications do not apply. However, parties to agreements based on this European standard are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references the latest edition of the normative document referred to applies.

1.2.1 General reference standards

EN 1090-2¹

Execution of steel structures and aluminium structures - Technical rules for the execution of steel structures

EN 1990: 2002

Basis of structural design.

1.2.2 Other reference standards

EN 1992-1-1 ¹	Eurocoda: Design of concrete structures: General rules and rules for buildings
EN 1993-1-1 ¹	Eurocode 3. Design of steel structures: General rules and rules for buildings
EN 1993-1-3 ¹	Eurocode 3: Design of steel structures: Cold-formed thin gauge members and sheeting
EN 1993-1-5 ¹	Eurocode 3: Design of teel structures: Plated structural elements
EN 1993-1-8 ¹	Eurocode 3: Design of steet structures: Design of joints
EN 1993-1-9 ¹	Eurocode 3: Design of steel structures: Fatigue strength of steel structures
EN 10025-1: 2002	Hot-rolled products of structural steels: General delivery conditions
EN 10025-2: 2002	Hot-rolled products of structural steels Sechnical delivery conditions for non-alloy structural steels
EN 10025-3: 2002	Hot-rolled products of structural steels: Technical delivery conditions for normalized/normalized rolled weldable fine grain structural steels
EN 10025-4: 2002	Hot-rolled products of structural steels: Technical delivery conditions for thermomechanical rolled weldable fine grain structural steels
EN 10025-5: 2002	Hot-rolled products of structural steels: Technical delivery conditions for structural steels with improved atmospheric corrosion resistance

_

¹ To be published

EN 10025-6: 2002 Hot-rolled products of structural steels: Technical delivery conditions for flat

products of high yield strength structural steels in the quenched and tempered

condition

EN 10147: 2000 Continuously hot-dip zinc coated structural steels strip and sheet: Technical

delivery conditions

EN 10149-2: 1995 Hot-rolled flat products made of high yield strength steels for cold-forming:

Delivery conditions for thermomechanically rolled steels

EN 10149-3: 1995 Pot-rolled flat products made of high yield strength steels for cold-forming:

Dervery conditions for normalised or normalised rolled steels

1.3 Assumptions

(1) In addition to the general assumptions of EN 1990 the following assumptions apply:

- those given in clauses 1.3 of Ex 292-1-1 and EN1993-1-1.

1.4 Distinction between principles and application rules

(1) The rules in EN 1990, 1.4 apply.

1.5 Definitions

1.5.1 General

(1) The terms and definitions given in EN 1990, 1.5, 1992-1-1, 1.5 and EN 1993-1-1, 1.5 apply.

1.5.2 Additional terms and definitions used in this Standard

1.5.2.1 Composite member

a structural member with components of concrete and of structural or cold-formed steel, interconnected by shear connection so as to limit the longituding slip between concrete and steel and the separation of one component from the other

1.5.2.2 Shear connection

an interconnection between the concrete and steel components of a composite member that has sufficient strength and stiffness to enable the two components to be designed as parts of a single structural member

1.5.2.3 Composite behaviour

behaviour which occurs after the shear connection has become effective due hardening of concrete

1.5.2.4 Composite beam

a composite member subjected mainly to bending

1.5.2.5 Composite column

a composite member subjected mainly to compression or to compression and bending