

PAIKSETE SAASTEALLIKATE HEITED**Proovivõtt gaasikontsentratsioonide automaatseks
määramiseks statsionaarsetes seiresüsteemides**

Stationary source emissions

Sampling for the automated determination of gas
emission concentrations for permanently-installed
monitoring systems

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-ISO 10396:2008 "Paiksete saasteallikate heited. Proovivõtt gaasikontsentratsioonide automaatseks määramiseks statsionaarsetes seiresüsteemides" sisaldab rahvusvahelise standardi ISO 10396:2007 "Stationary source emissions – Sampling for the automated determination of gas emission concentrations for permanently-installed monitoring systems" identset ingliskeelset teksti.	This Estonian Standard EVS-ISO 10396:2008 consists of the identical English text of the International Standard ISO 10396:2007 "Stationary source emissions – Sampling for the automated determination of gas emission concentrations for permanently-installed monitoring systems".
Standardi avaldamise korraldas Eesti Standardikeskus.	Estonian standard is published by the Estonian Centre for Standardisation.
Standard EVS-ISO 10396:2008 on kinnitatud Eesti Standardikeskuse 29.01.2008 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teataja 2008. aasta veebruarikuu numbris.	This standard is ratified with the order of Estonian Centre for Standardisation dated 29.01.2008 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from Estonian Centre for Standardisation.

Käsitlusala

Käesolev standard määratleb töövõtted ja -vahendid, mis võimaldavad teatud piirides saada esinduslikke proove gaasikontsentratsioonide automaatseks määramiseks gaasilistes heitvooludes. Metoodika sobib hapniku (O₂), süsinikdioksiidi (CO₂), süsinikmonoksiidi (CO), vääveldioksiidi (SO₂), lämmastikmonoksiidi (NO) ja lämmastikdioksiidi (NO₂) või lämmastikoksiidide NO ja NO₂ üldkoguse määramiseks.

On selge, et mõnede põlemisprotsesside ja olukordade puhul võib käesoleva standardi rakendatavus olla piiratud. Sellised olukorrad nõuavad ettevaatust ja tehnilist asjatundlikkust, eriti kui tegemist on millegagi järgmisest:

- a) sööbivad või kõrge reaktsioonivõimega komponendid, nt ammoniaak, vesinikkloriid ja väävelhape;
- b) kõrge vaakumi, rõhu või temperatuuri all olevad gaasivoolud;
- c) määrjad suitsugaasid;
- d) protsessi juhitamatutest muutustest tingitud voolukiiruse, temperatuuri või kontsentratsiooni kõikumised;
- e) gaaside kihistumine gaasivoolude mittesegunemise tõttu;
- f) keskkonnaseadmete abil tehtud mõõtmised;
- g) suhteliselt madalad gaasikontsentratsioonid.

ICS 13.040.40 Püsiallikate heitmed

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse poolt antud kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:

Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

Right to reproduce and distribute belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:

Aru str 10 Tallinn 10317 Estonia; www.evs.ee; Phone: 605 5050; E-mail: info@evs.ee

Contents

Page

Foreword.....	iv
Introduction	v
1 Scope	1
1.1 General	1
1.2 Limitations	1
2 Normative references	1
3 Terms and definitions	2
4 Principle	2
4.1 General	2
4.2 Extractive sampling	3
4.3 Non-extractive sampling	3
5 Representative sampling – Factors to be considered	3
5.1 Nature of the source	3
5.2 Location	4
5.3 Other factors	5
6 Apparatus and equipment	5
6.1 Construction materials	5
6.2 Components of extractive sampling equipment	5
6.3 Components of non-extractive equipment	8
7 System operation	10
7.1 Checking for leaks	10
7.2 Calibration, function and set-up	10
7.3 Maintenance of sampling systems	11
8 Documentation	11
Annex A (informative) Recommended construction materials	19
Bibliography	24

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 10396 was prepared by Technical Committee ISO/TC 146, *Air quality*, Subcommittee SC 1, *Stationary source emissions*.

This second edition cancels and replaces the first edition (ISO 10396:1993), which has been technically revised.

Introduction

This International Standard describes the use of methodologies for the sampling of stack gases for the determination of pollutants by automated measuring systems (AMS). The methodology applies to the sampling of oxygen (O_2), carbon dioxide (CO_2), carbon monoxide (CO), sulfur dioxide (SO_2), nitrogen monoxide (NO) and nitrogen dioxide (NO_2), or the sum of NO and NO_2 as nitrogen oxides.

This document is a preview generated by EVS

Stationary source emissions — Sampling for the automated determination of gas emission concentrations for permanently-installed monitoring systems

1 Scope

1.1 General

This International Standard specifies procedures and equipment that will permit, within certain limits, representative sampling for the automated determination of gas concentrations of effluent gas streams. The application is limited to the determination of oxygen (O₂), carbon dioxide (CO₂), carbon monoxide (CO), sulfur dioxide (SO₂), nitrogen monoxide (NO) and nitrogen dioxide (NO₂), or the sum of NO and NO₂ as nitrogen oxides.

1.2 Limitations

It is recognized that there are some combustion processes and situations that may limit the applicability of this International Standard. Where such conditions exist, caution and competent technical judgment are required, especially when dealing with any of the following:

- a) corrosive or highly reactive components such as ammonia, hydrogen chloride and sulfuric acid;
- b) high vacuum, high pressure or high temperature gas streams;
- c) wet flue gases;
- d) fluctuations in velocity, temperature or concentration due to uncontrollable variation in the process;
- e) gas stratification due to the non-mixing of gas streams;
- f) measurements made using environmental control devices;
- g) relatively low levels of gas concentrations.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 10780:1994, *Stationary source emissions — Measurement of velocity and volume flowrate of gas streams in ducts*