

**Lifts (elevators), escalators and moving walks - Risk assessment and reduction methodology (ISO 14798:2009)**

This document is a preview generated by EVS

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN ISO 14798:2013 sisaldab Euroopa standardi EN ISO 14798:2013 ingliskeelset teksti.	This Estonian standard EVS-EN ISO 14798:2013 consists of the English text of the European standard EN ISO 14798:2013.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 09.01.2013.	Date of Availability of the European standard is 09.01.2013.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 91.140.90

### Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:  
Aru 10, 10317 Tallinn, Eesti; [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

### The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:  
Aru 10, 10317 Tallinn, Estonia; [www.evs.ee](http://www.evs.ee); phone 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

ICS 91.140.90

English Version

## Lifts (elevators), escalators and moving walks - Risk assessment and reduction methodology (ISO 14798:2009)

Ascenseurs, escaliers mécaniques et trottoirs roulants -  
Méthodologie de l'appréciation et de la réduction du risque  
(ISO 14798:2009)

Aufzüge, Fahrtreppen und Fahrsteige - Verfahren zur  
Risikobeurteilung und -minderung (ISO 14798:2009)

This European Standard was approved by CEN on 24 November 2012.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

## Foreword

The text of ISO 14798:2009 has been prepared by Technical Committee ISO/TC 178 "Lifts, escalators and moving walks" of the International Organization for Standardization (ISO) and has been taken over as EN ISO 14798:2013 by Technical Committee CEN/TC 10 "Lifts, escalators and moving walks" the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 2013, and conflicting national standards shall be withdrawn at the latest by July 2013.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN/CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

### Endorsement notice

The text of ISO 14798:2009 has been approved by CEN as a EN ISO 14798:2013 without any modification.

# Contents

Page

Foreword .....	iv
Introduction .....	v
<b>1 Scope .....</b>	<b>1</b>
<b>2 Terms and definitions .....</b>	<b>1</b>
<b>3 General principles .....</b>	<b>3</b>
<b>3.1 Concept of safety .....</b>	<b>3</b>
<b>3.2 Concept of risk assessment.....</b>	<b>3</b>
<b>4 Risk analysis procedure .....</b>	<b>5</b>
<b>4.1 Step 1 — Determination of the reason for conducting a risk assessment.....</b>	<b>5</b>
<b>4.2 Step 2 — Formation of a risk assessment team .....</b>	<b>5</b>
<b>4.3 Step 3 — Determination of the subject of risk assessment and related factors .....</b>	<b>6</b>
<b>4.4 Step 4 — Identification of scenarios: hazardous situations, causes and effects.....</b>	<b>8</b>
<b>4.5 Step 5 — Risk estimation.....</b>	<b>9</b>
<b>5 Step 6 — Risk evaluation.....</b>	<b>15</b>
<b>6 Step 7 — Has the risk been sufficiently mitigated?.....</b>	<b>15</b>
<b>7 Step 8 — Reduction of risk — Protective measures.....</b>	<b>16</b>
<b>8 Documentation .....</b>	<b>17</b>
<b>Annex A (normative) Risk assessment template.....</b>	<b>18</b>
<b>Annex B (informative) Quick references to hazards (Table B.1), hazardous situations (Table B.2), causes (Table B.3), effects (Table B.4) and harm (Table B.5) .....</b>	<b>20</b>
<b>Annex C (normative) Estimation of risk elements — Severity (Table C.1) and probability (Table C.2) .....</b>	<b>25</b>
<b>Annex D (normative) Risk estimation and evaluation.....</b>	<b>26</b>
<b>Annex E (informative) Role of the team moderator .....</b>	<b>28</b>
<b>Annex F (informative) Examples of a risk assessment and protective measures .....</b>	<b>32</b>
<b>Bibliography.....</b>	<b>38</b>

## Introduction

The objective of this International Standard is to describe principles and set procedures for a consistent and systematic risk assessment methodology relevant to lifts (elevators), escalators, moving walks (“lifts”, for short). The risk analysis and assessment principles and process described in this International Standard may, however, be used for assessment of risk relevant to equipment other than lifts.

This risk assessment methodology is a tool used to identify risk of harm resulting from various hazards, hazardous situations and harmful events. Knowledge and experience of the design, use, installation, maintenance, incidents, accidents and related harm are brought together in order to assess the risk during all phases of the life of lifts<sup>1)</sup> (elevators), escalators and moving walks (hereafter referred to as “lifts”), from design and construction up to decommissioning. The users of the methodology do not make medical judgements but, rather, evaluate events that can possibly lead to levels of harm defined in this International Standard. By itself, this International Standard does not provide a presumption of conformity to any safety requirements for lifts, including those noted in Clause 1.

NOTE Risk assessment is not an exact science, as there is a certain degree of subjectivity in the process.

It is recommended that this International Standard be incorporated into training courses and manuals so as to provide basic instructions on safety aspects to those involved in

- a) assessing designs, operations, testing and use of lift equipment, and
- b) writing of specifications or standards incorporating safety requirements for lifts.

This International Standard describes a qualitative methodology for risk assessment that relies very much on the judgement and deliberations of the members of the risk assessment team who carry out the assessment. To ensure the most realistic and consistent assessment, it is essential that the methodology be followed faithfully. Aids such as numeric methods of assessment that follow the format described in this International Standard are not precluded from use. It should, however, be recognized that numeric aids to qualitative methods may still retain some of the subjectivity inherent in the qualitative process.

Clause 3 describes the concepts of safety and risk assessment. Clause 4 describes the procedure of risk analysis, including risk estimation. The procedure for risk evaluation is set out in Clause 5 and assessment in Clause 6. Clause 7 deals with protective measures. Clause 8 specifies relevant documentation.

---

1) Hereafter in this International Standard, the term “lift” is used instead of the term “elevator”. In addition, the term “lift” is also used instead of the terms “lifts, escalators and moving walks”.

# Lifts (elevators), escalators and moving walks — Risk assessment and reduction methodology

## 1 Scope

This International Standard establishes general principles and specific procedures for assessing risk.

The purpose of this International Standard is to provide a process for making decisions relevant to the safety of lifts during the

- a) design, construction, installation and servicing of lifts, lift components and systems,
- b) development of generic procedures for the use, operation, testing, compliance verification and servicing of lifts, and
- c) development of technical specifications and standards affecting the safety of lifts.

While examples in this International Standard refer primarily to risks of harm to persons, the risk assessment procedure set out in this International Standard can be equally effective for assessing other types of risk relevant to lifts, such as the risk of damage to property and environment.

## 2 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

### 2.1

#### **cause**

circumstance, condition, event or action that in a hazardous situation contributes to the production of an effect

### 2.2

#### **effect**

result of a cause in the presence of a hazardous situation

### 2.3

#### **harm**

physical injury or damage to the health of people, or damage to property or the environment

[ISO/IEC Guide 51:1999, 3.3]

### 2.4

#### **harmful event**

occurrence in which a hazardous situation results in harm

[ISO/IEC Guide 51:1999, 3.4]

**NOTE** In this International Standard, the term “harmful event” is interpreted as a combination of cause and effect.