

**Gaasivarustussüsteemid. Terastorustiku keevitamine.
Talituslikud nõuded**

**Gas infrastructure - Welding steel pipework - Functional
requirements**

This document is a preview generated by EVS

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 12732:2013+A1:2014 sisaldab Euroopa standardi EN 12732:2013+A1:2014 inglisekeelset teksti.	This Estonian standard EVS-EN 12732:2013+A1:2014 consists of the English text of the European standard EN 12732:2013+A1:2014.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 23.04.2014.	Date of Availability of the European standard is 23.04.2014.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 25.160.40

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English Version

Gas infrastructure - Welding steel pipework - Functional requirements

Infrastructures gazières - Soudage des tuyauteries en acier
- Prescriptions fonctionnelles

Gasinfrastruktur - Schweißen an Rohrleitungen aus Stahl -
Funktionale Anforderungen

This European Standard was approved by CEN on 14 March 2013 and includes Amendment 1 approved by CEN on 3 February 2014.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	6
1 Scope	7
2 Normative references	8
3 Terms and definitions	11
4 Quality system	13
4.1 General	13
4.2 Welding contractors	14
4.3 Welders	15
4.4 Welding supervisory and coordination personnel	15
4.5 Testing companies and personnel	15
4.5.1 General	15
4.5.2 Non-destructive testing (NDT)	15
4.5.3 Destructive testing (DT)	15
5 Welding consumables	15
6 Production welding	16
6.1 General requirements	16
6.1.1 General	16
6.1.2 Working area	16
6.1.3 Layout of weld joints	17
6.1.4 Types of weld joints	17
6.1.5 Joint edge preparation	17
6.1.6 Weld fit-up	17
6.1.7 Different wall thickness	17
6.1.8 Pipe branches and nozzles	17
6.1.9 Laminations	17
6.1.10 Butt welds cross joints	17
6.2 Joint preparation	17
6.2.1 Pipe end preparation	17
6.2.2 Alignment of the joints	17
6.3 Preheating	18
6.4 Tacking	18
6.5 Welding	18
6.6 Actions after welding	18
6.7 Repair of weld defects	19
7 Special procedures	19
7.1 General	19
7.2 Attachment of structural parts	19
7.3 Attachment of cathodic protection connections	19
7.4 Hot-tapping and other welding work on in-service pipelines	20
8 Inspection of the weld joint	20
8.1 General	20
8.2 Scope of inspection	20
8.3 Non-destructive testing and assessment levels	22
8.4 Time of inspection	23
8.5 Acceptance criteria	23
8.6 Recording of test results	24

9	Documentation	24
9.1	General	24
9.2	Archiving requirements	24
10	Specific requirements for gas infrastructure with a MOP up to and including 16 bar	24
10.1	General	24
10.2	Welders	24
10.3	Welding supervisory personnel	25
10.4	Production welding	25
10.4.1	General	25
10.4.2	Joint preparation	25
10.4.3	Welding	25
10.5	Requirements for records and documentation	25
11	Specific requirements for gas infrastructure with a MOP greater than 16 bar	26
11.1	General	26
11.2	Welders	26
11.3	Welding supervisory personnel	26
11.4	Qualification of welding procedures	26
11.4.1	General	26
11.4.2	Filler material requirements for welding procedure qualification	26
11.4.3	Impact testing	27
11.4.4	Transverse tensile test	27
11.4.5	All-weld-metal tensile test	28
11.5	Production welding	28
11.5.1	General	28
11.5.2	Joint preparation	28
11.5.3	Welding	28
11.5.4	Repairs of weld defects	29
11.5.5	Welding consumables	29
11.6	Destructive testing of production welds	29
11.7	Acceptance requirements	29
11.8	Requirements for records and documentation	30
12	Specific requirements for metering, regulating and compressor stations	31
12.1	General	31
12.2	Specific requirements	31
Annex A	(informative) Qualification procedure for pipeline welders (Girth welds and branch connections)	32
A.1	General	32
A.2	Approval test	32
A.2.1	Execution of the approval test	32
A.2.2	Range of test pieces	32
A.2.3	Supervision of execution of approval test	33
A.3	Inspection	33
A.3.1	General	33
A.3.2	Testing girth welds	34
A.3.3	Testing weldolets	34
A.4	Approval range	34
A.4.1	General	34
A.4.2	Dimension ranges	34

A.4.3	Techniques	34
A.5	Certificate	35
A.5.1	General	35
A.5.2	Duration of validity	35
Annex B	(informative) Testing of lamination defects	36
Annex C	(informative) Time-of-flight diffraction technique (TOFD)	37
C.1	General	37
C.2	Additional and substitutional requirements to EN ISO 10863:2011	37
C.2.1	Addition to the whole document EN ISO 10863:2011	37
C.2.2	Addition to EN ISO 10863:2011, Clause 3 "Terms and definitions"	37
C.2.3	Addition to EN ISO 10863:2011, Clause 5, "Examination Levels"	39
C.2.4	Addition to EN ISO 10863:2011, 7.2.2, "Ultrasonic probes"	39
C.2.5	Substitution of EN ISO 10863:2011, Clause 11, 3rd paragraph "Weld testing"	39
C.2.6	Substitution of EN ISO 10863:2011, 12.5.2 "Sizing"	40
Annex D	(informative) Critical aspects for hot-tap welding or welding on in-service pipelines	45
D.1	General	45
D.2	Recommendations	45
D.2.1	Equipment	45
D.2.2	Supervision	45
D.2.3	Safety precautions	45
D.2.4	Identification	45
D.2.5	Filler materials	45
D.3	Weld preparation	46
D.4	Welding procedure specification (WPS)	46
D.4.1	Description of the WPS	46
D.4.2	Qualification of the WPS	46
D.4.3	Approval of the WPS	46
D.5	Qualification of the welder	46
D.6	Precautions	46
D.7	Execution	47
D.8	Repairs	47
D.9	WPS qualification record	47
Annex E	(informative) Visual examination of joints	49
E.1	General	49
E.2	Recommendations	49
Annex F	(informative) Manual ultrasonic testing of weld joints for wall thickness between approximately 6 mm and 8 mm	50
F.1	General	50

F.2	Setting	50
F.2.1	Setting of range	50
F.2.2	Sensitivity adjustment when using the Distance Gain Size method	50
Annex G	(normative) Acceptance criteria - Recommendations for on-site production welds	54
G.1	General	54
G.2	Acceptance criteria according to EN ISO 5817	54
G.3	Summary of requirements for defect acceptance levels and defect limits	57
G.3.1	General	57
G.3.2	Requirements	58
G.4	Method and acceptance criteria for ultrasonic inspection assessment	65
G.4.1	Distance Gain Size method	65
G.4.2	Comparative Element method	65
G.4.3	General	65
G.4.4	Assessment of indications using automatic pulse-echo technique	67
Annex H	(informative) Brazing and aluminothermic welding of leads for cathodic protection systems	68
H.1	Joining techniques	68
H.2	Procedure qualification	68
H.3	Operation qualification	70
H.4	Production joints	70
Annex I	(informative) Significant technical changes between this European Standard and the previous edition	71
Bibliography	72

Foreword

This document (EN 12732:2013+A1:2014) has been prepared by Technical Committee CEN/TC 234 "Gas infrastructure", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2014, and conflicting national standards shall be withdrawn at the latest by October 2014.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes A1 EN 12732:2013 A1.

This document includes Amendment 1 approved by CEN on 2014-02-03.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A1 A1.

This European Standard has been prepared under mandate M/017 given to CEN by the Commission of the European Communities and the European Free Trade Association.

Annex I provides details of significant technical changes between this European Standard and the previous edition.

There is a complete suite of functional standards prepared by CEN/TC 234 "Gas infrastructure" to cover all parts from the input of gas to the transmission system up to the inlet connection of the gas appliances, whether for domestic, commercial or industrial purposes.

In preparing this standard a basic understanding of gas infrastructure by the user has been assumed.

Gas infrastructure is complex and the importance on safety of its construction and use has led to the development of very detailed codes of practice and operating manuals in the member countries. These detailed statements embrace recognised standards of gas engineering and the specific requirements imposed by the legal structures of the member countries.

CEN/TC 234 will continue its work updating this standard to the latest developments at regular intervals.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This European Standard contains requirements for the production and testing of weld joints for the installation and modification of onshore steel pipelines and pipework used in gas infrastructure, including in-service pipelines, for all pressure ranges for the carriage of processed, non-toxic and non-corrosive natural gas according to EN ISO 13686 and for the carriage of non-conventional gases such as injected biomethane,

where

- the pipeline elements are made of unalloyed or low-alloyed carbon steel;
- the pipeline is not located within commercial or industrial premises as integral part of the industrial process on those premises except for any pipelines and facilities delivering gas to such premises;
- the pipework is not located within household installations according to EN 1775;
- the design temperature of the system is between -40 °C up to and including 120 °C.

The onshore steel pipelines and pipework used in gas infrastructure include in-service pipelines, for all pressure ranges for the carriage of processed, non-toxic and non-corrosive natural gas according to EN ISO 13686 and for the carriage of non-conventional gases complying with EN ISO 13686, and for which a detailed technical evaluation of the functional requirements (such as injected biomethane) is performed ensuring there are no other constituents or properties of the gases that can affect the integrity of the pipeline.

This standard is not applicable to welds produced prior to the publication of this European Standard.

Table 1 assigns the application areas to quality requirement categories as a function of the working pressure and pipe materials used.

Table 1 — Allocation to quality requirement categories

Quality requirement category	Area of activity applies to	
B	Pressure range and base material	<p>≤ 5 bar</p> <p>Group 1.1, 1.2 and 1.4 according to CEN ISO/TR 15608</p> <p>$R_{t0,5} \leq 360 \text{ N/mm}^2$</p> <p>Examples of use: Mains and service pipes in gas distribution systems, pipework in stations</p>
C	Pressure range and base material	<p>> 5 bar ≤ 16 bar</p> <p>Group 1.1, 1.2 and 1.4 according to CEN ISO/TR 15608</p> <p>$R_{t0,5} \leq 360 \text{ N/mm}^2$</p> <p>Examples of use: Pipelines including pipework in stations and gas distribution systems</p>
D	Pressure range or base material	<p>> 16 bar^a</p> <p>Group 1, 2 and 3 according to CEN ISO/TR 15608</p>

Quality requirement category	Area of activity applies to	
	Examples of use: Pipelines including pipework in stations and gas transmission systems	
Key $R_{t0,5}$ is the specified minimum yield strength according to EN ISO 3183.		
NOTE 1 "Category A" for pipework up to and including 100 mbar, as mentioned in the previous version EN 12732:2000, has been incorporated in the pressure range of "Category B" and has been deleted from this table.		
NOTE 2 Gas infrastructure with a MOP up to and including 16 bar is generally dedicated to gas distribution.		
^a Pipelines having hoop stresses at design pressure up to 30 % of specified minimum yield strength ($R_{t0,5}$) and operated at a pressure up to 24 bar may be allocated to quality requirement Category C by the pipeline operator.		

Additional requirements may be specified when, for example:

- the strain on pipelines and systems,
- the materials,
- the line routing,
- the design or the welding technique

are considered critical.

This European Standard specifies common basic principles for gas infrastructure. Users of this European Standard should be aware that there can exist more detailed national standards and/or codes of practice in the CEN member countries.

This European Standard is intended to be applied in association with these national standards and/or codes of practice setting out the above-mentioned basic principles.

In the event of conflicts in terms of more restrictive requirements in national legislation/regulation with the requirements of this standard, the national legislation/regulation takes precedence as illustrated in CEN/TR 13737 (all parts).

NOTE CEN/TR 13737 (all parts) contains:

- clarification of relevant legislation/regulations applicable in a country;
- if appropriate, more restrictive national requirements;
- national contact point for the latest information.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 287-1, *Qualification test of welders — Fusion welding — Part 1: Steels*

EN 1418:1997, *Welding personnel — Approval testing of welding operators for fusion welding and resistance weld setters for fully mechanized and automatic welding of metallic materials*

EN 1708-1, *Welding - Basic welded joint details in steel - Part 1: Pressurized components*

EN 10204, *Metallic products - Types of inspection documents*

EN ISO 636, *Welding consumables — Rods, wires and deposits for tungsten inert gas welding of non-alloy and fine-grain steels — Classification (ISO 636)*

EN ISO 2560, *Welding consumables — Covered electrodes for manual metal arc welding of non-alloy and fine grain steels — Classification (ISO 2560)*

EN ISO 3183, *Petroleum and natural gas industries — Steel pipe for pipeline transportation systems (ISO 3183)*

EN ISO 3452 (all parts), *Non-destructive testing — Penetrant testing (ISO 3452)*

EN ISO 3834-1, *Quality requirements for fusion welding of metallic materials — Part 1: Criteria for the selection of the appropriate level of quality requirements (ISO 3834-1)*

EN ISO 3834-2, *Quality requirements for fusion welding of metallic materials — Part 2: Comprehensive quality requirements (ISO 3834-2)*

EN ISO 3834-3, *Quality requirements for fusion welding of metallic materials — Part 3: Standard quality requirements (ISO 3834-3)*

EN ISO 3834-4, *Quality requirements for fusion welding of metallic materials — Part 4: Elementary quality requirements (ISO 3834-4)*

EN ISO 5817, *Welding — Fusion-welded joints in steel, nickel, titanium and their alloys (beam welding excluded) — Quality levels for imperfections (ISO 5817)*

EN ISO 6520-1, *Welding and allied processes — Classification of geometric imperfections in metallic materials — Part 1: Fusion welding (ISO 6520-1)*

EN ISO 6892-1, *Metallic materials — Tensile testing — Part 1: Method of test at room temperature (ISO 6892-1)*

EN ISO 9692-1, *Welding and allied processes — Recommendations for joint preparation — Part 1: Manual metal-arc welding, gas-shielded metal-arc welding, gas welding, TIG welding and beam welding of steels (ISO 9692-1)*

EN ISO 9712, *Non-destructive testing — Qualification and certification of NDT personnel (ISO 9712)*

EN ISO 10863:2011, *Non-destructive testing of welds - Ultrasonic testing - Use of time-of-flight diffraction technique (TOFD) (ISO 10863:2011)*

EN ISO 14171, *Welding consumables — Solid wire electrodes, tubular cored electrodes and electrode/flux combinations for submerged arc welding of non alloy and fine grain steels — Classification (ISO 14171)*

EN ISO 14174, *Welding consumables — Fluxes for submerged arc welding and electroslag welding — Classification (ISO 14174)*

EN ISO 14175, *Welding consumables — Gases and gas mixtures for fusion welding and allied processes (ISO 14175)*

EN ISO 14341, *Welding consumables — Wire electrodes and weld deposits for gas shielded metal arc welding of non alloy and fine grain steels - Classification (ISO 14341)*

EN ISO 14731, *Welding coordination — Tasks and responsibilities (ISO 14731)*

EN ISO 15607:2003, *Specification and qualification of welding procedures for metallic materials - General rules (ISO 15607:2003)*

CEN ISO/TR 15608, *Welding — Guidelines for a metallic materials grouping system (ISO/TR 15608)*

EN ISO 15609-1, *Specification and qualification of welding procedures for metallic materials — Welding procedure specification — Part 1: Arc welding (ISO 15609-1)*

EN ISO 15609-2, *Specification and qualification of welding procedures for metallic materials — Welding procedure specification — Part 2: Gas welding (ISO 15609-2)*

EN ISO 15610, *Specification and qualification of welding procedures for metallic materials — Qualification based on tested welding consumables (ISO 15610)*

EN ISO 15611, *Specification and qualification of welding procedures for metallic materials — Qualification based on previous welding experience (ISO 15611)*

EN ISO 15612, *Specification and qualification of welding procedures for metallic materials — Qualification by adoption of a standard welding procedure (ISO 15612)*

EN ISO 15613, *Specification and qualification of welding procedures for metallic materials — Qualification based on pre-production welding test (ISO 15613)*

EN ISO 15614-1, *Specification and qualification of welding procedures for metallic materials — Welding procedure test — Part 1: Arc and gas welding of steels and arc welding of nickel and nickel alloys (ISO 15614-1)*

EN ISO/IEC 17020, *Conformity assessment — Requirements for the operation of various types of bodies performing inspection (ISO/IEC 17020)*

EN ISO/IEC 17025, *General requirements for the competence of testing and calibration laboratories (ISO/IEC 17025)*

EN ISO 17636-1, *Non-destructive testing of welds — Radiographic testing — Part 1: X- and gamma-ray techniques with film (ISO 17636-1)*

EN ISO 17636-2, *Non-destructive testing of welds — Radiographic testing — Part 2: X- and gamma-ray techniques with digital detectors (ISO 17636-2)*

EN ISO 17632, *Welding consumables — Tubular cored electrodes for gas shielded and non-gas shielded metal arc welding of non-alloy and fine grain steels — Classification (ISO 17632)*

EN ISO 17637, *Non-destructive testing of welds — Visual testing of fusion-welded joints (ISO 17637)*

EN ISO 17638, *Non-destructive testing of welds — Magnetic particle testing (ISO 17638)*

EN ISO 17640, *Non-destructive testing of welds — Ultrasonic testing — Techniques, testing levels, and assessment (ISO 17640)*

EN ISO 18275, *Welding consumables — Covered electrodes for manual metal arc welding of high-strength steels — Classification (ISO 18275)*

IIW-IAB -252-07, *Personnel with responsibility for welding coordination*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply. Symbols used in formulae are defined where they occur.

3.1

design temperature

DT

temperature on which the design calculations are based

3.2

gas

gaseous fuel which is in a gaseous state at a temperature of 15 °C under atmospheric pressure (1,013 25 bar absolute)

3.3

gas infrastructure

all pipelines, stations and installations from the input of gas to the transmission system up to the inlet connection of the gas appliances, whether for domestic, commercial or industrial purposes

3.4

gas distribution system

pipeline system including piping above and below ground and all other equipment necessary to deliver the gas to the consumer

3.5

gas transmission

activity intended to convey gas from one place to another through pipelines in order to deliver gas to distribution systems or to industrial consumers

3.6

installation

equipment and facilities for the extraction, production, chemical treatment, measurement, control, storage or off-take of the transported gas

3.7

maximum operating pressure

MOP

maximum pressure at which a system can be operated continuously under normal conditions

Note 1 to entry: normal conditions are: no fault in any device or stream

3.8

national requirements

requirements following from national legislation or more detailed or stringent national standards

3.9

onshore pipeline

buried and/or above ground pipeline including those sections laid in or across inland lakes or water courses