

**Fire resistance tests for service installations - Part 12:  
Non-mechanical fire barrier for ventilation ductwork**

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN 1366-12:2014 sisaldab Euroopa standardi EN 1366-12:2014 inglisekeelset teksti.	This Estonian standard EVS-EN 1366-12:2014 consists of the English text of the European standard EN 1366-12:2014.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 01.10.2014.	Date of Availability of the European standard is 01.10.2014.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 13.220.50

### Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:  
Aru 10, 10317 Tallinn, Eesti; [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

### The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:  
Aru 10, 10317 Tallinn, Estonia; [www.evs.ee](http://www.evs.ee); phone 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

ICS 13.220.50

English Version

## Fire resistance tests for service installations - Part 12: Non-mechanical fire barrier for ventilation ductwork

Essais de résistance au feu des installations techniques -  
Partie 12: Barrière résistante au feu non mécanique pour  
les conduits de ventilation

Feuerwiderstandsprüfungen für Installationen - Teil 12:  
Nichtmechanische Brandschutzverschlüsse für  
Lüftungsleitungen

This European Standard was approved by CEN on 13 June 2014.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

# Contents

Page

Foreword.....	4
Introduction .....	5
1 Scope .....	6
2 Normative references .....	6
3 Terms and definitions .....	6
4 Test equipment .....	7
4.1 General.....	7
4.2 Connecting duct.....	7
4.3 Volume flow measuring station.....	7
4.4 Condensing unit.....	7
4.5 Gas temperature measuring devices.....	8
4.6 Exhaust fan system .....	8
5 Test conditions .....	8
6 Test specimen .....	8
6.1 Size.....	8
6.2 Number of tests.....	8
6.2.1 General.....	8
6.2.2 Supporting construction.....	9
6.2.3 Method of installation in the supporting construction .....	9
6.2.4 Method of installation on to the supporting construction.....	9
6.2.5 Method of installation away from the supporting construction .....	9
6.3 Design .....	10
6.3.1 General.....	10
6.3.2 Orientation to be tested .....	10
6.3.3 Non-mechanical fire barriers installed within a wall or floor opening .....	10
6.3.4 Non-mechanical fire barriers mounted on to the face of a wall or floor .....	10
6.3.5 Non-mechanical fire barriers mounted remote from a wall or floor .....	10
7 Installation of test specimen .....	11
7.1 General.....	11
7.2 Supporting construction.....	11
7.3 Minimum separation .....	11
8 Conditioning.....	12
8.1 General.....	12
8.2 Water-based sealing materials .....	12
9 Application of instrumentation.....	12
9.1 Thermocouples .....	12
9.1.1 Furnace thermocouples (plate thermometers) .....	12
9.1.2 Unexposed surface temperature .....	12
9.2 Furnace pressure.....	12
9.2.1 General.....	12
9.2.2 Pressure differential measurement, furnace and connecting duct .....	12
10 Test procedure .....	13
10.1 Determination of leakage of connecting duct and measuring station .....	13
10.2 Fire test procedure .....	13

<b>11</b>	<b>Performance criteria.....</b>	<b>14</b>
<b>12</b>	<b>Test report.....</b>	<b>15</b>
<b>13</b>	<b>Field of direct application of test results .....</b>	<b>16</b>
<b>13.1</b>	<b>Size of non-mechanical fire barrier .....</b>	<b>16</b>
<b>13.2</b>	<b>Non-mechanical fire barriers installed within structural openings.....</b>	<b>16</b>
<b>13.3</b>	<b>Non-mechanical fire barriers installed onto the face of a wall or a floor .....</b>	<b>16</b>
<b>13.4</b>	<b>Non-mechanical fire barriers remote from a wall or floor .....</b>	<b>16</b>
<b>13.5</b>	<b>Fire from above.....</b>	<b>17</b>
<b>13.6</b>	<b>Separation between non-mechanical fire barriers and between non-mechanical fire barriers and construction elements .....</b>	<b>17</b>
<b>13.7</b>	<b>Supporting constructions .....</b>	<b>17</b>
<b>Annex A (normative)</b>	<b>EOTA TR026 - Characterization, Aspects of Durability and Factory Production Control for Reactive Materials, Components and Products .....</b>	<b>30</b>
<b>Bibliography.....</b>		<b>31</b>

## Foreword

This document (EN 1366-12:2014) has been prepared by Technical Committee CEN/TC 127 “Fire safety in buildings”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2015 and conflicting national standards shall be withdrawn at the latest by April 2015.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directives.

EN 1366, *Fire resistance tests for service installations*, consists of the following parts:

- *Part 1: Ventilation ducts;*
- *Part 2: Fire dampers;*
- *Part 3: Penetration seals;*
- *Part 4: Linear joint seals;*
- *Part 5: Service ducts and shafts;*
- *Part 6: Raised access and hollow core floors;*
- *Part 7: Conveyor systems and their closures;*
- *Part 8: Smoke extraction ducts;*
- *Part 9: Single compartment smoke extraction ducts;*
- *Part 10: Smoke control dampers;*
- *Part 11: Fire protective systems for cable systems and associated components (in preparation);*
- *Part 12: Non-mechanical fire barrier for ventilation ductwork (this document);*
- *Part 13: 1-, 2-, 3- sided ducts (in preparation);*
- *Part 14: Kitchen extract ducts;*
- *Part 15: Mixed penetrations including pipes cables, ducts and dampers.*

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

## Introduction

The purpose of the test is to evaluate the ability of a non-mechanical (no moving parts) fire barrier (see Annex A) to prevent fire and smoke spreading from one fire compartment to another through the air ductwork system which may penetrate fire separating walls and floors.

Non-mechanical fire barriers are unable to achieve an “S” classification, which requires a known limited ambient leakage, as they are unable to be closed except under fire conditions.

The non-mechanical fire barrier is attached (directly or remotely via a section of ducting), to a fire separating element in a manner representative of practice.

Tests are performed starting with the non-mechanical fire barrier in its cold standard state to expose it to furnace conditions.

Temperature and integrity measurements are carried out in various parts of the test construction during the test. The leakage of the non-mechanical fire barrier system is measured (continuously during the test) by direct flow measurements while maintaining a constant pressure differential across the closed non-mechanical fire barrier of 300 Pa.

### Caution:

The attention of all persons concerned with managing and carrying out this fire resistance test is drawn to the fact that fire testing may be hazardous and that there is a possibility that toxic and/or harmful smoke and gases may be evolved during the test. Mechanical and operational hazards may also arise during the construction of the test elements or structures, their testing and disposal of test residues.

An assessment of all potential hazards and risks to health should be made and safety precautions should be identified and provided. Written safety instructions should be issued. Appropriate training should be given to relevant personnel. Laboratory personnel should ensure that they follow written safety instructions at all times.

## 1 Scope

This part of EN 1366 specifies a method for determining the fire resistance of non-mechanical fire barriers installed in fire separating elements designed to withstand heat and the passage of smoke and gases at high temperature. This European Standard is used in conjunction with EN 1363-1 and EN 1366-2.

This European Standard is not suitable for testing non-mechanical fire barriers in suspended ceilings without modification.

This European Standard is not suitable for testing fire dampers, see EN 1366-2.

This European Standard is not suitable for testing such products as air transfer grilles, as the pressures and flows involved are different and may cause differing behaviour.

## 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1, *Fire resistance tests - Part 1: General Requirements*

EN 1363-2, *Fire resistance tests - Part 2: Alternative and additional procedures*

EN 1366-2, *Fire resistance tests for service installations - Part 2: Fire dampers*

EN ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full - Part 1: General principles and requirements (ISO 5167-1)*

EN ISO 5167-2, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full - Part 2: Orifice plates (ISO 5167-2)*

EN ISO 5167-3, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full - Part 3: Nozzles and Venturi nozzles (ISO 5167-3)*

EN ISO 13943, *Fire safety - Vocabulary (ISO 13943)*

## 3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1363-1, EN 1366-2 and EN ISO 13943, together with the following, apply.

### 3.1

#### **non-mechanical fire barrier**

open device with no moving parts for use in HVAC ventilation systems at fire boundaries that only closes to maintain compartmentation in the event of a fire

### 3.2

#### **test specimen**

non-mechanical fire barrier, connecting frame and (if applicable) the perimeter penetration sealing system