

VAHELDUVVOOLU-MÕÕTESEADMED. ERINÕUDED. OSA  
24: STAATILISED  
PÕHISAGEDUS-REAKTIIVENERGIAARVESTID (KLASSID  
0,5 S, 1 S JA 1)

Electricity metering equipment (a.c.) - Particular  
requirements - Part 24: Static meters for reactive  
energy at fundamental frequency (classes 0,5 S, 1 S and  
1)

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN 62053-24:2015 sisaldab Euroopa standardi EN 62053-24:2015 ingliskeelset teksti.	This Estonian standard EVS-EN 62053-24:2015 consists of the English text of the European standard EN 62053-24:2015.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 16.01.2015.	Date of Availability of the European standard is 16.01.2015.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

## ICS 29

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:

Aru 10, 10317 Tallinn, Eesti; koduleht [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Aru 10, 10317 Tallinn, Estonia; homepage [www.evs.ee](http://www.evs.ee); phone +372 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

ICS 17.220.20; 91.140.50

English Version

Electricity metering equipment (a.c.) - Particular requirements -  
Part 24: Static meters for reactive energy at fundamental  
frequency (classes 0,5 S, 1 S and 1)  
(IEC 62053-24:2014)

Équipement de comptage de l'électricité (c.a.) - Exigences  
particulières - Partie 24: Compteurs statiques d'énergie  
réactive à la fréquence fondamentale  
(classes 0,5 S, 1 S et 1)  
(IEC 62053-24:2014)

Wechselstrom-Elektrizitätszähler - Besondere  
Anforderungen - Teil 24: Elektronische Grundschrwingungs-  
Blindverbrauchsähler  
der Genauigkeitsklassen 0,5 S, 1 S und 1  
(IEC 62053-24:2014)

This European Standard was approved by CENELEC on 2014-07-24. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

## Foreword

The text of document 13/1569/FDIS, future edition 1 of IEC 62053-24, prepared by IEC/TC 13 "Electrical energy measurement and control" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62053-24:2015.

The following dates are fixed:

- latest date by which the document has to be (dop) 2015-07-16  
implemented at national level by  
publication of an identical national  
standard or by endorsement
- latest date by which the national (dow) 2017-07-24  
standards conflicting with the  
document have to be withdrawn

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive.

For the relationship with EU Directive see informative Annex ZZ, which is an integral part of this document.

## Endorsement notice

The text of the International Standard IEC 62053-24:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61869-2:2012	NOTE	Harmonized as EN 61869-2:2012 (not modified).
IEC 62053-21:2003	NOTE	Harmonized as EN 62053-21:2003 (not modified).
IEC 62053-23:2003	NOTE	Harmonized as EN 62053-23:2003 (not modified).
IEC 62053-61:1998	NOTE	Harmonized as EN 62053-61:1998 (not modified).

**Annex ZA**  
(normative)

**Normative references to international publications  
with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: [www.cenelec.eu](http://www.cenelec.eu)

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 62052-11	2003	Electricity metering equipment (AC) - General requirements, tests and test conditions - Part 11: Metering equipment	EN 62052-11	2003

## **Annex ZZ** (informative)

### **Coverage of Essential Requirements of EU Directives**

This European Standard has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association and within its scope this standard covers all relevant essential requirements as given in Annex I of the EU Directive 2004/108/EC.

Compliance with this standard provides one means of conformity with the specified essential requirements of the Directive concerned.

**WARNING:** Other requirements and other EU Directives can be applied to the products falling within the scope of this standard.

## CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references .....	7
3 Terms and definitions .....	8
4 Standard electrical values .....	8
5 Mechanical requirements.....	8
6 Climatic conditions .....	8
7 Electrical requirements .....	8
7.1 General.....	8
7.2 Power consumption.....	9
7.2.1 General .....	9
7.2.2 Voltage circuits.....	9
7.2.3 Current circuits.....	9
7.3 Influence of short-time overcurrents .....	9
7.4 Influence of self-heating.....	10
7.5 AC voltage test .....	11
8 Accuracy requirements .....	11
8.1 General.....	11
8.2 Limits of error due to variation of the current.....	11
8.3 Limits of error due to influence quantities.....	12
8.3.1 General .....	12
8.3.2 Tests of the influence of DC and even harmonics in the current circuit .....	14
8.3.3 Continuous magnetic induction of external origin .....	14
8.3.4 Harmonics .....	14
8.4 Test of starting and no-load condition .....	15
8.4.1 General .....	15
8.4.2 Initial start-up of the meter.....	15
8.4.3 Test of no-load condition .....	15
8.4.4 Starting.....	16
8.5 Meter constant.....	16
8.6 Accuracy test conditions .....	16
8.7 Interpretation of test results .....	17
Annex A (normative) Test circuit diagram for DC and even harmonics .....	18
Annex B (normative) Electromagnet for testing the influence of externally produced magnetic fields .....	20
Annex C (informative) Geometric representation of active and reactive power .....	21
Annex D (informative) Effect of phase displacement .....	23
D.1 Phase displacement and matching of current transformers and meters for reactive energy .....	23
Annex E (informative) Treatment of harmonics and tests for harmonics .....	24
E.1 Non-sinusoidal conditions and reactive power definition.....	24
E.2 Tests for accuracy under non-sinusoidal conditions .....	24
E.3 Fifth harmonic test .....	25
Bibliography.....	26

Figure A.1 – Test circuit diagram for half-wave rectification .....	18
Figure A.2 – Half-wave rectified waveform .....	19
Figure B.1 – Electromagnet for testing the influence of externally produced magnetic fields.....	20
Figure C.1 – Recommended geometric representation .....	21
Figure C.2 – Alternative geometric representation .....	22
Table 1 – Power consumption in voltage circuits for single-phase and polyphase meters including the power supply .....	9
Table 2 – Power consumption in current circuits .....	9
Table 3 – Variations due to short-time overcurrents .....	10
Table 4 – Variations due to self-heating .....	10
Table 5 – AC voltage tests .....	11
Table 6 – Percentage error limits (single-phase meters and polyphase meters with balanced loads) .....	12
Table 7 – Percentage error limits (polyphase meters carrying a single-phase load, but with balanced polyphase voltages applied to voltage circuits) .....	12
Table 8 – Influence quantities .....	13
Table 9 – Starting current .....	16
Table 10 – Voltage and current balance .....	16
Table 11 – Reference conditions.....	17
Table 12 – Interpretation of test results.....	17
Table D.1 – Limits of phase displacement for measuring current transformers and corresponding measurement error for reactive energy measurement .....	23



## INTRODUCTION

This part of IEC 62053 is to be used with the following relevant parts of the IEC 62052, IEC 62053 and IEC 62059 series, *Electricity metering equipment*:

IEC 62052-11:2003, *Electricity metering equipment (a.c.) – General requirements, tests and test conditions – Part 11: Metering equipment*

IEC 62053-21:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 21: Static meters for active energy (classes 1 and 2)*

IEC 62053-22:2003, *Electricity metering equipment (a.c.) – Particular requirements – Part 22: Static meters for active energy (classes 0,2 S and 0,5 S)*

IEC 62053-31:1998, *Electricity metering equipment (a.c.) – Particular requirements – Part 31: Pulse output devices for electromechanical and electronic meters (two wires only)*

IEC 62053-52:2005, *Electricity metering equipment (a.c.) – Particular requirements – Part 52: Symbols*

IEC 62053-61:1998, *Electricity metering equipment (a.c.) – Particular requirements – Part 61: Power consumption and voltage requirements*

IEC 62059-11:2002, *Electricity metering equipment (a.c.) – Dependability – Part 11: General concepts*

IEC 62059-21:2002, *Electricity metering equipment (a.c.) – Dependability – Part 21: Collection of meter dependability data from the field*

IEC 62059-31-1:2008, *Electricity metering equipment – Dependability – Part 31-1: Accelerated reliability testing – Elevated temperature and humidity*

IEC 62059-32-1:2011, *Electricity metering equipment – Dependability – Part 32-1: Durability – Testing of the stability of metrological characteristics by applying elevated temperature*

IEC 62059-41:2006, *Electricity metering equipment – Dependability – Part 41: Reliability prediction*

This part is a standard for type testing electricity meters. It covers the particular requirements for meters, used indoors and outdoors. It does not deal with special implementations (such as metering-part and/or displays in separate housings).

This standard is intended to be used in conjunction with IEC 62052-11. When any requirement in this standard concerns an item already covered in IEC 62052-11, the requirements of this standard take precedence over the requirements of IEC 62052-11.

This standard distinguishes:

- between transformer operated meters of accuracy class index 0,5 S and 1 S and direct connected meters of accuracy class index 1;
- between protective class I and protective class II meters;
- between meters for use in networks equipped with or without earth fault neutralizers.

The test levels are regarded as minimum values that provide for the proper functioning of the meter under normal working conditions. For special application, other test levels might be necessary and should be agreed on between the user and the manufacturer.