

Wind turbines - Part 25-3: Communications for
monitoring and control of wind power plants -
Information exchange models

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 61400-25-3:2015 sisaldab Euroopa standardi EN 61400-25-3:2015 ingliskeelset teksti.	This Estonian standard EVS-EN 61400-25-3:2015 consists of the English text of the European standard EN 61400-25-3:2015.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 20.11.2015.	Date of Availability of the European standard is 20.11.2015.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 27.180

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:

Aru 10, 10317 Tallinn, Eesti; koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Aru 10, 10317 Tallinn, Estonia; homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

**Wind turbines - Part 25-3: Communications for monitoring and
control of wind power plants - Information exchange models
(IEC 61400-25-3:2015)**

Eoliennes - Partie 25-3: Communications pour la
surveillance et la commande des centrales éoliennes -
Modèles d'échange d'information
(IEC 61400-25-3:2015)

Windenergieanlagen - Teil 25 3: Kommunikation für die
Überwachung und Steuerung von Windenergieanlagen -
Dienste-Modelle für den Informationsaustausch
(IEC 61400-25-3:2015)

This European Standard was approved by CENELEC on 2015-08-04. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

European foreword

The text of document 88/540/FDIS, future edition 2 of IEC 61400-25-3, prepared by IEC TC 88 "Wind turbines" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61400-25-3:2015.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2016-05-20
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2018-08-04

This document supersedes EN 61400-25-3:2007.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61400-25-3:2015 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61850-7-3	NOTE	Harmonized as EN 61850-7-3.
IEC 61850-7-4	NOTE	Harmonized as EN 61850-7-4.

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61400-25-1	-	Wind turbines -- Part 25-1: Communications for monitoring and control of wind power plants - Overall description of principles and models	EN 61400-25-1	-
IEC 61400-25-2	2015	Wind turbines -- Part 25-2: Communications for monitoring and control of wind power plants - Information models	EN 61400-25-2	2015
IEC 61400-25-4	2008	Wind turbines -- Part 25-4: Communications for monitoring and control of wind power plants - Mapping to communication profile	EN 61400-25-4	2008
IEC 61850-7-2	2010	Communication networks and systems for power utility automation -- Part 7-2: Basic information and communication structure - Abstract communication service interface (ACSI)	EN 61850-7-2	2010

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references.....	8
3 Terms and definitions	8
4 Abbreviated terms	9
5 General.....	9
6 Information exchange models overview	10
7 Operational functions.....	12
7.1 General.....	12
7.2 Association and authorisation model.....	12
7.3 Control model	13
7.3.1 General	13
7.3.2 Direct control / Select before operate (SBO)	14
7.3.3 Operate / TimeActivatedOperate	14
7.3.4 Normal security / Enhanced security.....	14
7.4 Monitoring, reporting and logging model	14
8 Management functions.....	16
8.1 General.....	16
8.2 User management/access security model	16
8.3 Setup model.....	16
8.4 Time synchronisation model	16
8.5 Diagnostic (self-monitoring) model.....	16
9 The ACSI for wind power plant information models.....	17
9.1 General.....	17
9.2 Services of association and authorisation	17
9.3 Services of GenServerClass	18
9.4 Services of GenLogicalDeviceClass.....	18
9.5 Services of GenLogicalNodeClass	18
9.6 Services of GenDataObjectClass	18
9.7 Services of DataSetClass	19
9.8 Services of ReportControlBlockClass.....	19
9.9 Services of LogControlBlockClass and LogClass	20
9.10 Services of ControlClass	21
Annex A (informative) Examples of reporting and logging services	22
A.1 Reporting example	22
A.2 Logging example.....	22
Annex B (normative) Relationship between ACSI services and functional constraints	24
Annex C (informative) Relationship between ACSI defined in IEC 61850-7-2 and IEC 61400-25-3	26
Annex D (normative) ACSI conformance statement.....	28
D.1 General.....	28
D.2 ACSI basic conformance statement	28
D.3 ACSI models conformance statement	28
D.4 ACSI service conformance statement	30

Bibliography	32
Figure 1 – Conceptual communication model of the IEC 61400-25 series	8
Figure 2 – Association and authorisation model (conceptual)	12
Figure 3 – Control model (conceptual)	13
Figure 4 – Monitoring, reporting and logging model (conceptual)	15
Figure 5 – Conceptual information exchange model for a wind power plant	17
Figure 6 – Buffered report control block – conceptual	20
Figure 7 – Log control block – conceptual	21
Figure A.1 – Mapping of information models to data sets for reporting (example)	22
Figure A.2 – Logging basics (example)	23
Figure C.1 – Conceptual service model of the ACSI	27
Table 1 – Information exchange models	11
Table 2 – Comparison of the information retrieval methods	16
Table 3 – Data filter	20
Table B.1 – Relationship between ACSI Services and Functional Constraints	24
Table D.1 – Basic conformance statement	28
Table D.2 – ACSI models conformance statement	29
Table D.3 – ACSI service conformance statement (1 of 2)	30
Table D.4 – Time	31

INTRODUCTION

The IEC 61400-25 series defines communications for monitoring and control of wind power plants. The modeling approach of the IEC 61400-25 series has been selected to provide abstract definitions of classes and services such that the specifications are independent of specific protocol stacks, implementations, and operating systems. The mapping of these abstract classes and services to a specific communication profile is not inside the scope of this part (IEC 61400-25-3) but inside the scope of IEC 61400-25-4.

This part of IEC 61400-25 defines services of the model of the information exchange of intelligent electronic devices in wind power plants. The services are referred to as the abstract communication service interface (ACSI). The ACSI has been defined so as to be independent of the underlying communication systems.

The information exchange model is defined in terms of

- a hierarchical class model of all information that can be accessed,
- information exchange services that operate on these classes,
- parameters associated with each information exchange service.

The ACSI description technique abstracts away from all the different approaches to implement the cooperation of the various devices.

These abstract service definitions are mapped into concrete object definitions that are to be used for a particular protocol. Mapping to specific protocol stacks is specified in IEC 61400-25-4.

NOTE 1 Abstraction in ACSI has two meanings. Firstly, only those aspects of a real device (for example, a rotor) or a real function that are visible and accessible over a communication network are modelled. This abstraction leads to the hierarchical class models and their behaviour defined in IEC 61400-25-2. Secondly, the ACSI abstracts from the aspect of concrete definitions on how the devices exchange information; only a conceptual cooperation is defined. The concrete information exchange is defined in IEC 61400-25-4.

NOTE 2 Performance of the IEC 61400-25 series implementations are application specific. The IEC 61400-25 series does not guarantee a certain level of performance. This is beyond the scope of the IEC 61400-25 series. However, there is no underlying limitation in the communications technology to prevent high speed application (millisecond level responses).

WIND TURBINES –

Part 25-3: Communications for monitoring and control of wind power plants – Information exchange models

1 Scope

The focus of the IEC 61400-25 series is on the communications between wind power plant components such as wind turbines and actors such as SCADA systems. Internal communication within wind power plant components is outside the scope of the IEC 61400-25 series.

The IEC 61400-25 series is designed for a communication environment supported by a client-server model. Three areas are defined, that are modelled separately to ensure the scalability of implementations: (1) wind power plant information models, (2) information exchange model, and (3) mapping of these two models to a standard communication profile.

The wind power plant information model and the information exchange model, viewed together, constitute an interface between client and server. In this conjunction, the wind power plant information model serves as an interpretation frame for accessible wind power plant data. The wind power plant information model is used by the server to offer the client a uniform, component-oriented view of the wind power plant data. The information exchange model reflects the whole active functionality of the server. The IEC 61400-25 series enables connectivity between a heterogeneous combination of client and servers from different manufacturers and suppliers.

As depicted in Figure 1, the IEC 61400-25 series defines a server with the following aspects:

- information provided by a wind power plant component, e. g., “wind turbine rotor speed” or “total power production of a certain time interval” is modelled and made available for access. The information modelled in the IEC 61400-25 series is defined in IEC 61400-25-2;
- services to exchange values of the modelled information defined in IEC 61400-25-3;
- mapping to a communication profile, providing a protocol stack to carry the exchanged values from the modelled information (IEC 61400-25-4).

The IEC 61400-25 series only defines how to model the information, information exchange and mapping to specific communication protocols. The IEC 61400-25 series excludes a definition of how and where to implement the communication interface, the application program interface and implementation recommendations. However, the objective of the IEC 61400-25 series is that the information associated with a single wind power plant component (such as a wind turbine) is accessible through a corresponding logical device.

This part of IEC 61400-25 specifies an abstract communication service interface describing the information exchange between a client and a server for:

- data access and retrieval,
- device control,
- event reporting and logging,
- self-description of devices (device data dictionary),
- data typing and discovery of data types.