

English Version

**Plastics piping systems for water supply and for buried and
above-ground drainage and sewerage under pressure -
Unplasticized poly(vinyl chloride) (PVC-U) - Part 7: Guidance for
the assessment of conformity**

Systèmes de canalisations en plastique pour l'alimentation
en eau, pour branchements et collecteurs d'assainissement
enterrés et aériens avec pression - Poly(chlorure de vinyle)
non plastifié (PVC-U) - Partie 7: Guide pour l'évaluation de
la conformité

Kunststoff-Rohrleitungssysteme für die Wasserversorgung
und für erdverlegte und nicht erdverlegte Entwässerungs-
und Abwasserdruckleitungen - Weichmacherfreies
Polyvinylchlorid (PVC-U) - Teil 7: Empfehlungen für die
Beurteilung der Konformität

This Technical Specification (CEN/TS) was approved by CEN on 9 December 2013 for provisional application.

The period of validity of this CEN/TS is limited initially to three years. After two years the members of CEN will be requested to submit their comments, particularly on the question whether the CEN/TS can be converted into a European Standard.

CEN members are required to announce the existence of this CEN/TS in the same way as for an EN and to make the CEN/TS available promptly at national level in an appropriate form. It is permissible to keep conflicting national standards in force (in parallel to the CEN/TS) until the final decision about the possible conversion of the CEN/TS into an EN is reached.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	3
Introduction.....	4
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 Abbreviated terms	9
5 General.....	9
6 Testing and inspection.....	9
6.1 Grouping.....	9
6.1.1 General.....	9
6.1.2 Size groups.....	10
6.1.3 Fitting/valve groups.....	10
6.2 Type tests (TTs)	10
6.3 Batch release tests (BRTs)	16
6.4 Process verification tests (PVTs).....	18
6.5 Audit tests (ATs)	20
6.6 Indirect tests (ITs).....	23
6.7 Test records	23
Annex A (informative) Basic test Matrix for PVC-U Water and Pressure Sewer piping components ...	24
Bibliography.....	26

Foreword

This document (CEN/TS 1452-7:2014) has been prepared by Technical Committee CEN/TC 155 "Plastics piping systems and ducting systems", the secretariat of which is held by NEN.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes ENV 1452-7:2000, CEN/TS 1456-2:2003, which have been technically revised.

EN ISO 1452, *Plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure — Unplasticized poly(vinyl chloride) (PVC-U)*, consists of the following parts:

- *Part 1: General*
- *Part 2: Pipes*
- *Part 3: Fittings*
- *Part 4: Valves*
- *Part 5: Fitness for purpose of the system*

This part of EN ISO 1452 gives guidance for the assessment of conformity of compounds/formulations, products, joints and assemblies in accordance with the applicable parts of EN ISO 1452 intended to be included in the manufacturer's quality plan as part of the quality management system and for the establishment of certification procedures:

Part 7: Guidance for the assessment of conformity.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to announce this Technical Specification: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

Figures 1 and 2 are intended to provide general information on the concept of testing and organization of those tests used for the purpose of the assessment of conformity. For each type of tests (i.e. type testing (TT), batch release test (BRT), process verification test (PVT) and audit test (AT), this part of EN ISO 1452 details the applicable characteristics to be assessed as well as the frequency and sampling of testing.

A typical scheme for the assessment of conformity of compounds/formulations, pipes, fittings, valves, joints or assemblies by manufacturers is given in Figure 1.




Figure 1 — Typical scheme for the assessment of conformity by a manufacturer

A typical scheme for the assessment of conformity of compounds/formulations, pipes, fittings, valves, joints or assemblies by manufacturers, including a certification, is given in Figure 2.




Figure 2 — Typical scheme for the assessment of conformity by a manufacturer, including a certification

1 Scope

This part of EN ISO 1452 gives guidance for the assessment of conformity of compounds/formulations, products, joints and assemblies in accordance with the applicable parts of EN ISO 1452 intended to be included in the manufacturer's quality plan as part of the quality management system and for the establishment of certification procedures.

NOTE 1 It is recommended that the quality management system conforms to or is no less stringent than the relevant requirements to EN ISO 9001 [1].

NOTE 2 If certification is involved, the certification body and inspection body is preferably compliant with EN ISO/IEC 17065 [5] or EN ISO/IEC 17021 [3], as applicable.

In conjunction with Parts 1 to 5 of EN ISO 1452 (see Foreword) this document is applicable to unplasticized poly(vinyl chloride) (PVC-U) plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 1452-1:2009, *Plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure - Unplasticized poly(vinyl chloride) (PVC-U) - Part 1: General (ISO 1452-1:2009)*

EN ISO 1452-2:2009, *Plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure - Unplasticized poly(vinyl chloride) (PVC-U) - Part 2: Pipes (ISO 1452-2:2009)*

EN ISO 1452-3:2010, *Plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure - Unplasticized poly(vinyl chloride) (PVC-U) - Part 3: Fittings (ISO 1452-3:2009, corrected version 2010-03-01)*

EN ISO 1452-4:2009, *Plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure - Unplasticized poly(vinyl chloride) (PVC-U) - Part 4: Valves (ISO 1452-4:2009)*

EN ISO 1452-5:2010, *Plastics piping systems for water supply and for buried and above-ground drainage and sewerage under pressure - Unplasticized poly(vinyl chloride) (PVC-U) - Part 5: Fitness for purpose of the system (ISO 1452-5:2009, corrected version 2010-03-01)*

3 Terms and definitions

For the purposes of this document, the following terms and definitions given in EN ISO 1452-1:2009, EN ISO 1452-2:2009, EN ISO 1452-3:2010, EN ISO 1452-4:2009 and the following apply.

3.1

certification body

impartial body, governmental or non-governmental, possessing the necessary competence and responsibility to carry out certification of conformity according to given rules of procedure and management

Note 1 to entry: A certification body is preferably compliant with EN ISO/IEC 17065 [5].

3.2

inspection body

body that performs inspection

Note 1 to entry: A body can be an organization or part of an organization.