

Wastewater treatments plants - Part 4: Primary settlement

Wastewater treatments plants - Part 4: Primary
settlement

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>Käesolev Eesti standard EVS-EN 12255-4:2002 sisaldab Euroopa standardi EN 12255-4:2002 ingliskeelset teksti.</p> <p>Käesolev dokument on jõustatud 12.07.2002 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p>	<p>This Estonian standard EVS-EN 12255-4:2002 consists of the English text of the European standard EN 12255-4:2002.</p> <p>This document is endorsed on 12.07.2002 with the notification being published in the official publication of the Estonian national standardisation organisation.</p> <p>The standard is available from Estonian standardisation organisation.</p>
--	---

<p>Käsitlusala: This European Standard specifies requirements for the primary settlement of wastewater at wastewater treatment plants for over 50 PT. The primary application is for wastewater treatment plants designed for the treatment of domestic and municipal wastewater.</p>	<p>Scope: This European Standard specifies requirements for the primary settlement of wastewater at wastewater treatment plants for over 50 PT. The primary application is for wastewater treatment plants designed for the treatment of domestic and municipal wastewater.</p>
--	--

ICS 13.060.30

Võtmesõnad: management, settlement, settling tanks, sewage, sewage clarification, sewage purification, sewage purification plant, sewage treatment, sewage treatment plants, sewage treatment works, shut-off valves, specification (approval), specifications, water practice

ICS 13.060.30

English version

Wastewater treatment plants - Part 4: Primary settlement

Stations d'épuration - Partie 4: Décantation primaire

Kläranlagen - Teil 4: Vorklärung

This European Standard was approved by CEN on 9 November 2001.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

	page
Foreword.....	3
1 Scope	5
2 Normative references	5
3 Terms and definitions.....	5
4 Requirements	5
4.1 General.....	5
4.2 Planning.....	6
4.3 Process	6
4.3.1 General.....	6
4.3.2 Required Capacity	6
4.3.3 Upward Flow Tanks (including Imhoff Tanks)	6
4.3.4 Horizontal Flow Tanks	7
4.3.5 Lamella Separator	7
4.3.6 Sludge Collection and Removal	7
4.3.7 Scum Removal	8
4.4 Maintenance	8
4.5 Health and Safety	8
Bibliography	9

Foreword

This European Standard has been prepared by Technical Committee CEN/TC 165 "Wastewater engineering", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 2002, and conflicting national standards shall be withdrawn at the latest by December 2002.

It is the fourth part prepared by the Working Groups CEN/TC 165/WG 42 and 43 relating to the general requirements and processes for treatment plants for a total number of inhabitants and population equivalents (PT) over 50. The Parts of the series are as follows:

- Part 1: General construction principles
- Part 3: Preliminary treatment
- Part 4: Primary settlement
- Part 5: Lagooning processes
- Part 6: Activated sludge processes
- Part 7: Biological fixed-film reactors
- Part 8: Sludge treatment and storage
- Part 9: Odour control and ventilation
- Part 10: Safety principles
- Part 11: General data required
- Part 12: Control and automation
- Part 13: Chemical treatment – Treatment of wastewater by precipitation/flocculation
- Part 14: Disinfection
- Part 15: Measurement of the oxygen transfer in clean water in aeration tanks of activated sludge plants
- Part 16: Physical (mechanical) filtration¹⁾

NOTE For requirements on pumping installations at wastewater treatment plants, provided initially as part 2 "Pumping installations for wastewater treatment plants", see EN 752-6 "Drain and sewer systems outside buildings — Part 6: Pumping installations".

EN 12255-1, EN 12255-3 to EN 12255-8 and EN 12255-10 and EN 12255-11 were implemented together as a European package (Resolution BT 152/1998).

¹⁾ In preparation.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

This document is a preview generated by EVS

1 Scope

This European Standard specifies the performance requirements for the primary settlement of wastewater at wastewater treatment plants for over 50 PT.

The primary application is for wastewater treatment plants designed for the treatment of domestic and municipal wastewater.

Differences in wastewater treatment throughout Europe have led to a variety of systems being developed. This standard gives fundamental information about the systems; this standard has not attempted to specify all available systems.

Detailed information additional to that contained in this standard may be obtained by referring to the Bibliography.

2 Normative references

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text, and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

EN 1085, *Wastewater treatment — Vocabulary*.

EN 12255-1, *Wastewater treatment plants — Part 1: General construction principles*.

EN 12255-3, *Wastewater treatment plants — Part 3: Preliminary treatment*.

EN 12255-10, *Wastewater treatment plants — Part 10: Safety principles*.

EN 12255-11, *Wastewater treatment plants — Part 11: General data required*.

EN 12566-1, *Small wastewater treatment systems for up to 50 PT — Part 1: Prefabricated septic tanks*.

3 Terms and definitions

For the purposes of this European Standard, the following terms and definitions given in EN 1085 and the following apply.

3.1

lamella separator

system of regularly spaced, inclined plates or tubes, designed to increase the effective settling area in a settlement tank

4 Requirements

4.1 General

Primary settlement serves the purpose of separating settleable solids, which are removed on a regular basis in the form of raw sludge. Grease and other floating materials which can cause malfunction of a wastewater treatment plant can also be separated and removed during this process. Where large quantities of grease are expected a separate grease separation step is recommended prior to primary settlement (see EN 12255-3).

The type and size of unit(s) will depend on the overall system, PT, sludge removal and ground conditions prevailing on the construction site.