

Wastewater treatment plants - Part 7: Biological fixed-film reactors

Wastewater treatment plants - Part 7: Biological
fixed-film reactors

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>Käesolev Eesti standard EVS-EN 12255-7:2002 sisaldab Euroopa standardi EN 12255-7:2002 ingliskeelset teksti.</p> <p>Käesolev dokument on jõustatud 12.07.2002 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p>	<p>This Estonian standard EVS-EN 12255-7:2002 consists of the English text of the European standard EN 12255-7:2002.</p> <p>This document is endorsed on 12.07.2002 with the notification being published in the official publication of the Estonian national standardisation organisation.</p> <p>The standard is available from Estonian standardisation organisation.</p>
--	---

<p>Käsitlusala:</p> <p>This European Standard specifies the design principles and performance requirements for secondary treatment by biological fixed-film reactors at wastewater treatment plants for more than 50 PT. The primary application is for wastewater treatment plants designed for the treatment of domestic and municipal wastewater. Biological fixed film reactors include biological trickling filters, rotating biological contactors, submerged-media reactors and biofilters.</p>	<p>Scope:</p> <p>This European Standard specifies the design principles and performance requirements for secondary treatment by biological fixed-film reactors at wastewater treatment plants for more than 50 PT. The primary application is for wastewater treatment plants designed for the treatment of domestic and municipal wastewater. Biological fixed film reactors include biological trickling filters, rotating biological contactors, submerged-media reactors and biofilters.</p>
---	---

ICS 13.060.30

Võtmesõnad: management, p, reactors, seats, sewage, sewage clarification, sewage purification, sewage purification plant, sewage treatment, sewage treatment plants, sewage treatment works, siting, specification (approval), specifications, trickling filters, water practice

ICS 13.060.30

English version

Wastewater treatment plants - Part 7: Biological fixed-film reactors

Stations d'épuration - Partie 7: Réacteurs biologiques à cultures fixées

Kläranlagen - Teil 7: Biofilmreaktoren

This European Standard was approved by CEN on 9 November 2001.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

	page
Foreword.....	3
1 Scope	5
2 Normative references	5
3 Terms and definitions.....	5
4 Requirements	6
4.1 General.....	6
4.1.1 Biological fixed film processes	6
4.1.2 Trickling filters	6
4.1.3 Rotating biological contactors	6
4.1.4 Submerged bed reactors and biofilters	7
4.2 Planning	7
4.3 Process	7
4.3.1 Design	7
4.3.2 Modes of operation	8
4.3.3 Selection of support media	8
4.3.4 Dimensions.....	9
4.3.5 Flow distribution	10
4.3.6 Oxygen supply	10
4.3.7 Clarification and solid separation	11
4.3.8 Additional considerations.....	11
4.4 Detailed design.....	11
4.4.1 Structures	11
4.4.2 Mechanical and electrical equipment	12
Bibliography	14

Foreword

This European Standard has been prepared by Technical Committee CEN/TC 165 "Wastewater engineering", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 2002, and conflicting national standards shall be withdrawn at the latest by December 2002.

It is the seventh part prepared by the Working Groups CEN/TC 165/WG 42 and 43 relating to the general requirements and processes for treatment plants for a total number of inhabitants and population equivalents (PT) over 50. The Parts of the series are as follows:

- Part 1: General construction principles
- Part 3: Preliminary treatment
- Part 4: Primary settlement
- Part 5: Lagooning processes
- Part 6: Activated sludge processes
- Part 7: Biological fixed-film reactors
- Part 8: Sludge treatment and storage
- Part 9: Odour control and ventilation
- Part 10: Safety principles
- Part 11: General data required
- Part 12: Control and automation
- Part 13: Chemical treatment – Treatment of wastewater by precipitation/flocculation
- Part 14: Disinfection
- Part 15: Measurement of the oxygen transfer in clean water in aeration tanks of activated sludge plants
- Part 16: Physical (mechanical) filtration¹⁾

NOTE For requirements on pumping installations at wastewater treatment plants, provided initially as part 2 "Pumping installations for wastewater treatment plants", see EN 752-6 "Drain and sewer systems outside buildings — Part 6: Pumping installations".

The parts EN 12255-1, EN 12255-3 to EN 12255-8 and EN 12255-10 and EN 12255-11 were implemented together as a European package (Resolution BT 152/1998).

¹⁾ In preparation.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

This document is a preview generated by EVS

1 Scope

This European Standard specifies the design principles and performance requirements for secondary treatment by biological fixed-film reactors at wastewater treatment plants for more than 50 PT.

The primary application is for wastewater treatment plants designed for the treatment of domestic and municipal wastewater.

Biological fixed film reactors include biological trickling filters, rotating biological contactors, submerged bed reactors and biofilters.

Differences in wastewater treatment throughout Europe have led to a variety of systems being developed. This standard gives fundamental informations about the systems; this standard has not attempted to specify all available systems.

Detailed information additional to that contained in this standard may be obtained by referring to the Bibliography.

2 Normative references

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text, and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

EN 752-6, *Drain and sewer systems outside buildings — Part 6: Pumping installations.*

EN 1085, *Wastewater treatment — Vocabulary.*

EN 12255-1, *Wastewater treatment plants — Part 1: General construction principles.*

EN 12255-6, *Wastewater treatment plants — Part 6: Activated sludge processes.*

EN 12255-10, *Wastewater treatment plants — Part 10: Safety principles.*

EN 12255-11, *Wastewater treatment plants — Part 11: General data required.*

3 Terms and definitions

For the purposes of this European Standard, the terms and definitions given in EN 1085 and the following apply.

3.1

wastewater dose

volume of wastewater discharged on to a trickling filter from a single pumping cycle or a single siphoning from a filter dosing chamber

3.2

flushing intensity

surface hydraulic loading rate divided by the number of arms of a rotary distributor and divided by the number of revolutions per hour

NOTE This value gives information on the hydraulic forces to wash excess sludge out of the bed.

3.3

submerged bed reactor

bed of packed or suspended inert media which is typically open structure plastic and is submerged in the flow to allow the active biological film attached to the media to purify the wastewater