

Air intake filter systems for rotary machinery - Test methods - Part 1: Static filter elements (ISO 29461-1:2013)

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN ISO 29461-1:2013 sisaldab Euroopa standardi EN ISO 29461-1:2013 ingliskeelset teksti.	This Estonian standard EVS-EN ISO 29461-1:2013 consists of the English text of the European standard EN ISO 29461-1:2013.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 10.04.2013.	Date of Availability of the European standard is 10.04.2013.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.160.99

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English Version

**Air intake filter systems for rotary machinery - Test methods -
Part 1: Static filter elements (ISO 29461-1:2013)**

Systèmes de filtration d'air d'admission pour machines
tournantes - Méthodes d'essai - Partie 1: Éléments filtrants
pour filtres statiques (ISO 29461-1:2013)

Luftfiltereinlasssysteme von Rotationsmaschinen -
Prüfverfahren - Teil 1: Statische Filterelemente (ISO 29461-
1:2013)

This European Standard was approved by CEN on 1 March 2013.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

This document (EN ISO 29461-1:2012) has been prepared by Technical Committee ISO/TC 142 "Cleaning equipment for air and other gases" in collaboration with Technical Committee CEN/TC 195 "Air filters for general air cleaning" the secretariat of which is held by UNI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2013, and conflicting national standards shall be withdrawn at the latest by October 2013.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Endorsement notice

The text of ISO 29461-1:2013 has been approved by CEN as EN ISO 29461-1:2013 without any modification.

Contents

Page

Foreword	v
0 Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
3.2 Velocity	2
3.3 Efficiency	2
3.5 Pressure drop (differential pressure)	3
3.6 Filter area	3
3.7 Filters	3
3.8 Test aerosol	4
3.9 Test dust	5
3.10 Particle sampling	5
3.11 Particle shedding	5
4 Symbols and abbreviated terms	6
5 General requirements	8
6 Test rig and equipment	8
6.1 Test condition	8
6.2 Test rig	8
6.3 DEHS test aerosol generation	12
6.4 Aerosol sampling system	13
6.5 Flow measurement	14
6.6 Particle counter	14
6.7 Differential pressure measuring equipment	15
6.8 Dust feeder	15
6.9 Diluter equipment	17
7 Qualification of test rig and apparatus	18
7.1 General	18
7.2 Air velocity uniformity in the test duct	18
7.3 Aerosol uniformity in the test duct	19
7.4 Particle counter sizing accuracy	20
7.5 Particle counter zero test	20
7.6 Particle counter overload test	20
7.7 100 % efficiency test	21
7.8 Zero % efficiency test	21
7.9 Aerosol generator response time	21
7.10 Dilution ratio	22
7.11 Correlation ratio	22
7.12 Pressure drop checking	23
7.13 Dust feeder airflow rate	23
7.14 Reference filter check	24
7.15 Summary of qualification requirements	25
7.16 Apparatus maintenance	25
8 Test materials	26
8.1 Test air	26
8.2 Test aerosol	26
8.3 Loading dust	27
8.4 Final filter	27
9 Test procedure	27
9.1 Preparation of filter to be tested	28
9.2 Initial pressure drop	28

9.3	Initial particulate efficiency measurement.....	28
9.4	Conditioning test.....	32
9.5	Dust loading.....	32
10	Uncertainty calculation of the test results.....	33
10.1	Particulate efficiency for medium efficiency filters (initial particulate efficiency: 35 ≤ <i>E</i> ≤ 85 % at 0,4 µm).....	33
10.2	Particulate efficiency for high efficiency filters (initial particulate efficiency >85 % at 0,4 µm).....	34
10.3	Gravimetric efficiency.....	36
11	Reporting.....	36
11.1	General.....	36
11.2	Interpretation of test reports.....	37
11.3	Summary.....	38
11.4	Efficiency.....	40
11.5	Pressure drop and airflow rate.....	40
11.6	Marking.....	40
	Annex A (normative) Conditioning test procedure.....	47
	Annex B (informative) Shedding from filter elements.....	51
	Annex C (informative) Commentary.....	53
	Annex D (normative) Pressure drop calculation.....	57
	Annex E (normative) Net Area Calculation.....	59
	Bibliography.....	66

0 Introduction

0.1 Filters in power generating/compressor applications

In rotating machinery applications, the filtering system, typically a set of filter elements arranged in a suitable manner, are an important part of the whole turbine/compressor system. The development of turbine machinery used for energy production or others has led to more sophisticated equipment and therefore the importance of good protection of these systems has become more important in the recent years. It is known that particulate contamination can deteriorate a turbine power system quite substantially if not taken care of.

This event is often described as “erosion”, “fouling” and “hot corrosion” where salt and other corrosive particles are known as potential problems. Other particulate matters may also cause significant reduction of efficiency of the systems. It is important to understand that air filter devices in such systems are located in various environmental conditions. The range of climate and particulate contamination is very wide, ranging from deserts to humid rain forests to arctic environments. The requirements on these filter systems are obviously different depending on where they will be operating.

ISO 29461 has based the performance of the air intake filter systems not only upon heavy dust collection but also particulate efficiency in a size range that is considered to be the problematic area for these applications. Both ultra-fine and fine particles, as well as larger particles, should be considered when evaluating turbine fouling. In typical outdoor air, ultra-fine and fine particles in the size range from 0,01 μm to 1 μm contribute to >99 % of the number concentration and to >90 % of the surface contamination. The majority of the mass normally comes from larger particles (>1,0 μm).

Turbo-machinery filters comprise a wide range of products from filters for very coarse particles to filters for very fine, sub-micron particles. The range of products varies from self-cleaning to depth and surface loading systems. The filters and the systems have to withstand a wide temperature and humidity range, very low to very high dust concentration and mechanical stress. The shape of products existing today can be of many different types and have different functions such as droplet separators, coalescing products, filter pads, metal filters, inertial filters, filter cells, bag filters, panel-type, self-cleanable and depth loading filter cartridges and pleated media surface filter elements.

ISO 29461 will provide a way to compare these products in a similar way and define what criteria are important for air filter intake systems for rotary machinery performance protection. The performance of products in this broad range must be compared in a good manner. Comparing different filters and filter types must be done with respect to the operating conditions they finally will be used in.

For instance, if a filter or a filter system is meant to operate in an extreme, very dusty environment, the real particulate efficiency of such a filter cannot be predicted because the dust loading of the filter plays an important role. ISO 29461-2 will address the performance of cleanable and surface loading filters.

0.2 Filtration characteristics

Initiatives to address the potential problems of particle re-entrainment, shedding and the in-service charge neutralization characteristics of certain types of media have been included in [Annexes A](#) and [B](#).

Certain types of filter media rely on electrostatic effects to achieve high efficiencies at low resistance to airflow. Exposure to some types of challenge, such as combustion particles or other fine particles, may inhibit such charges with the result that filter performance suffers. The normative test procedure, described in [Annex A](#), provides techniques for identifying this type of behaviour. This procedure is used to determine whether the filter particulate efficiency is dependent on the electrostatic removal mechanism and to provide quantitative information about the importance of the electrostatic removal. The procedure was selected because it is well established, reproducible, relatively fast and easy to perform.

In an ideal filtration process, each particle would be permanently arrested at the first contact with a filter fibre, but incoming particles may impact on a captured particle and dislodge it into the air stream. Fibres or particles from the filter itself could also be released, due to mechanical forces. From the user's point of view it might be important to know this, see [Annex B](#).

Filters with a low initial or conditioned particulate efficiency (<35 %) for sub-micron particles (0,4 µm) that do not increase their efficiency during the operation will typically not provide any major protection for the operating machinery when challenged with typical atmospheric aerosols where the majority of particles are smaller than 1,0 µm. However, in some cases with aerosols having a dominant fraction of coarse particles, filters with low efficiencies at sub-micron particles can serve as a protection for later filter stages and can also have a higher average particulate efficiency (e.g. surface loading filters) at 0,4 µm due to the dust loading. Therefore a gravimetric test can provide some information about capacity and gravimetric efficiency for those aerosols. In general, a lower total filtration level than 35 % at 0,4 µm should not be recommended for an air intake filter system for rotary machinery when the aerosol loading of the filters are not contributing to a significant increase of the efficiency during the operation.

0.3 Organization of ISO 29461

The methods and procedures for determining particulate efficiency, pressure drop and the corresponding reporting formats are the same for all types of static filter element.

The test methods concerning particulate efficiency, pressure drop and reported values are the same for all filters, except for loading characteristics and cleaning procedure, which are different for cleanable surface loading filters. These filters incorporate cleaning procedures and have different loading characteristics; therefore, they require appropriately modified test methods, which will be defined in Part 2.

Part 3 will provide methods for determining the mechanical integrity of filters under conditions that may be encountered in abnormal operating environments.

Part 4 will describe methods of testing installed filters under in-service operating conditions (*in situ* testing).

Part 5 will cover test methods for the specific requirement of offshore and marine application, and specify methods for determining the sea salt removal efficiency of individual filters and/or complete filter systems.

Part 6 will cover test methods for cleanable filter elements, and will not cover the system testing (e.g. cleaning device) as in Part 2.

This part of ISO 29461 describes the test methods for static filter units, typically of the depth loading type (see definitions 3.43 and 3.44). All filters can be tested in the same manner, thus obtaining comparable results. However, for surface loading filters, reverse pulse filters, marine and offshore filter systems, as well as other filter systems that are not regarded as static filter units, the appropriate part shall be used.

For multi-stage systems that use a number of components (e.g. equipment for cleaning, filters), this part of ISO 29461 may be used as long as the qualification requirements of the test rig can be fulfilled. In cases where this is not possible, Part 4 (*in situ* testing) procedures may be applied.

Air intake filter systems for rotary machinery — Test methods —

Part 1: Static filter elements

1 Scope

ISO 29461 specifies methods and procedures for determining the performance of particulate air filters used in air intake filter systems for rotary machinery such as stationary gas turbines, compressors and other stationary internal combustion engines. It applies to air filters having an initial particle efficiency up to 99,9 % with respect to 0,4 μm particles. Filters with higher initial particle efficiencies are tested and classified according to other standards (e.g. EN 1822). These procedures are intended for filters which operating at flow rates within the range 0,25 m^3/s (900 m^3/h) up to 1,67 m^3/s (6000 m^3/h).

This part of ISO 29461 refers to static (barrier) filter systems but can be applied to other filter types and systems in appropriate circumstances.

Two methods of determining the efficiency are used in this part of ISO 29461:

- particulate efficiency (measured with respect to particle number and size);
- gravimetric efficiency (percentage weighted mass removal of loading dust).

Also a flat sheet media sample or media pack sample from an identical filter is conditioned (discharged) to provide information about the intensity of the electrostatic removal mechanism.

After determination of its initial particle efficiency, the untreated filter is loaded with dust in steps until its final test pressure drop is reached. Information on the loaded performance of the filter is then obtained.

The performance results obtained in accordance with this part of ISO 29461 cannot be quantitatively applied (by themselves) to predict performance in service with regard to efficiency and lifetime. Other factors influencing performance to be taken into account are described in the annexes.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 2854, *Statistical interpretation of data — Techniques of estimation and tests relating to means and variances*

ISO 5167 (all parts), *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full*

ISO 12103-1, *Road vehicles — Test dust for filter evaluation — Part 1: Arizona test dust*

ISO 14644-3:2005, *Cleanrooms and associated controlled environments — Part 3: Test methods*

ISO 21501-1, *Determination of particle size distribution — Single particle light interaction methods — Part 1: Light scattering aerosol spectrometer*

ISO 21501-4, *Determination of particle size distribution — Single particle light interaction methods — Part 4: Light scattering airborne particle counter for clean spaces*

ASHRAE 52.2:1999, *Method of testing general ventilation air-cleaning devices for removal efficiency by particle size*

IEST-RP-CC014, *Calibration and Characterization of Optical Airborne Particle Counters*

JIS Z 8901:2006, *Test powders and test particles*

JACA No.37:2001, *Guideline of Substitute Materials for DOP*

3 Terms and definitions

3.1

test airflow rate

volumetric airflow rate used for testing

[Source: ISO 29464:2011; 3.1.106]

3.2 Velocity

3.2.1

filter face velocity

airflow rate divided by the filter face area

[Source: ISO 29464:2011, 3.1.84]

3.2.2

media velocity

airflow rate divided by the effective filtering area

Note 1 to entry: Expressed at an accuracy of three significant figures.

3.3 Efficiency

3.3.1

particulate efficiency

percentage particulate removal efficiency of the filter at specified particle sizes measured with a particle counter in the range of 0,3 μm to 3,0 μm

3.3.2

initial efficiency

particulate efficiency of the clean filter operating at the test airflow rate

Note 1 to entry: A clean filter is a filter not exposed to any test aerosol or substance prior to the efficiency test.

3.3.3

minimum efficiency

lowest particulate efficiency of initial, conditioned or dust loaded efficiencies

3.3.4

conditioned efficiency

efficiency of the conditioned filter media (per [Annex A](#)) operating at an average media velocity corresponding to the test airflow rate in the filter

3.3.5

gravimetric efficiency

A_{50}

weighted (mass) removal of loading dust after 50 g of dust load