

---

---

**Determination of flash/no flash — Closed  
cup equilibrium method**

*Essai de point d'éclair de type passe/ne passe pas — Méthode à l'équilibre  
en vase clos*



**PDF disclaimer**

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

This document is a preview generated by EVS

© ISO 2002

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office  
Case postale 56 • CH-1211 Geneva 20  
Tel. + 41 22 749 01 11  
Fax + 41 22 749 09 47  
E-mail [copyright@iso.ch](mailto:copyright@iso.ch)  
Web [www.iso.ch](http://www.iso.ch)

Printed in Switzerland

# Contents

Page

Foreword.....	iv
Introduction.....	v
1 Scope .....	1
2 Normative references .....	1
3 Term and definition .....	2
4 Principle.....	2
5 Chemicals and materials.....	2
6 Apparatus .....	2
7 Apparatus preparation .....	3
8 Sampling.....	4
9 Sample handling .....	4
10 Test temperature.....	5
11 Procedure .....	5
12 Expression of results .....	7
13 Precision.....	7
14 Test report .....	7
Annex A (informative) Precision data from ISO 1523 .....	8
Bibliography.....	9

## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 3.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 1516 was prepared jointly by Technical Committees ISO/TC 28, *Petroleum products and lubricants* and ISO/TC 35, *Paints and varnishes*.

This third edition cancels and replaces the second edition (ISO 1516:1981), which has been technically revised.

Annex A of this International Standard is for information only.

## Introduction

This International Standard describes one of two closed cup equilibrium methods for carrying out a flash/no flash test for paints, varnishes, petroleum and related products, and it should be read in conjunction with the second equilibrium method, ISO 3680 ([2] in the bibliography), when selecting a method.

The determination of the flash point using the same equipment is described in ISO 1523.

This test method does not determine the flash point of the product under test, but merely its behaviour at the selected equilibrium temperature as may be required to comply with laws or regulations relating to the storage, transport and use of flammable products. For this purpose, it is unnecessary to determine the exact flash point, but it is necessary to determine whether or not flashing occurs at a given temperature. By the procedure specified, differences between test apparatus of various standard designs are minimized by ensuring that the test is carried out only when the product under test and the air/vapour mixture above it in the test vessel are considered to be in temperature equilibrium.

This document is a preview generated by EVS

This document is a preview generated by EVS

# Determination of flash/no flash — Closed cup equilibrium method

**WARNING —** The use of this International Standard may involve hazardous materials, operations and equipment. This International Standard does not purport to address all of the safety problems associated with its use. It is the responsibility of the user of this International Standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.

## 1 Scope

This International Standard specifies a method to determine if paints, varnishes, paint binders, solvents, petroleum or related products, when maintained at a selected equilibrium temperature and under the conditions of the test, give off sufficient flammable vapour to cause ignition on application of an external source of flame applied in a standard manner.

This International Standard is not applicable to water-borne paints which may, however, be tested using ISO 3680 ([2] in the bibliography).

The method is suitable for use over the temperature range  $-30\text{ }^{\circ}\text{C}$  to  $110\text{ }^{\circ}\text{C}$ , depending on the use of different apparatus listed in Table 1.

The interpretation of results obtained from solvent mixtures containing halogenated hydrocarbons should be considered with caution, as these mixtures can give anomalous results.

## 2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this International Standard. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references, the latest edition of the normative document referred to applies. Members of ISO and IEC maintain registers of currently valid International Standards.

ISO 1513:1992, *Paints and varnishes — Examination and preparation of samples for testing*

ISO 1523:2002, *Determination of flash point — Closed cup equilibrium method*

ISO 2719:—<sup>1)</sup>, *Determination of flash point — Pensky-Martens closed cup method*

ISO 3170:1988, *Petroleum liquids — Manual sampling*

ISO 3171:1988, *Petroleum liquids — Automatic pipeline sampling*

ISO 13736:1997, *Petroleum products and other liquids — Determination of flash point — Abel closed cup method*

ISO 15528:2000, *Paints, varnishes and raw materials for paints and varnishes — Sampling*

---

1) To be published. (Revision of ISO 2719:1988)

ASTM D56-00, *Standard Test Method for Flash Point by Tag Closed Tester*

DIN 51755:1974, *Testing of mineral oils and other combustible liquids; determination of flash point by the closed tester according to Abel-Pensky*

### 3 Term and definition

For the purposes of this International Standard, wherein ignition source is recognized as being a flame, the following term and definition applies.

#### 3.1 flash point

lowest temperature of the test portion, corrected to a barometric pressure of 101,3 kPa, at which application of an ignition source causes the vapour of the test portion to ignite and the flame to propagate across the surface of the liquid under the specified conditions of test

### 4 Principle

The test portion is placed in a suitably designed closed cup mounted in a thermostatically controlled bath. After the test portion has been maintained at the selected equilibrium temperature conditions for at least 10 min, an ignition trial is carried out by directing a small flame into the test cup. Whether or not the test flame causes the vapour above the test portion to ignite, is recorded.

### 5 Chemicals and materials

**5.1 Cleaning solvent**, for removal of traces of the previous test portion from the test cup and cover.

**NOTE** The choice of solvent will depend upon the previous material tested, and the tenacity of the residue. Low volatility aromatic (benzene-free) solvents may be used to remove traces of oil, and mixed solvents such as toluene-acetone-methanol may be effective for the removal of gum-type deposits.

**5.2 Verification liquids**, see ISO 1523.

### 6 Apparatus

**6.1 Test cup and lid**: a closed cup with, where specified, an internal level indicator, and lid, as specified in the standards listed in Table 1.

The test cup shall be fitted with a tightly fitting cover which carries an opening slide and an ignition device capable, when the slide is open, of positioning an ignition flame, with a diameter of between 3 mm and 4 mm, at the approximate centre of the opening in the lid. When positioned, the tip of the ignition device shall be between the planes of the lower and upper surfaces of the lid at a point on a radius passing through the centre of the opening. The apparatus shall be designed such that an ignition trial can be performed by opening the slide, positioning and removing the nozzle of the ignition device, and closing the slide again in a period of between 2 s and 3 s. A mechanically driven device for carrying out this operation is permitted provided that it can be shown that it meets the specification.

**NOTE** The source of flame in the ignition device may be any suitable flammable gas.

**6.2 Test cup thermometer**, as specified for use with the test cup in the standards listed in Table 1.

**NOTE** Other types of temperature measuring devices may be used, provided that they meet the requirements for accuracy and have the same response as the thermometers specified in the standards listed in Table 1.