

INTERNATIONAL STANDARD

ISO
15783

First edition
2002-02-01

Seal-less rotodynamic pumps — Class II — Specification

*Pompes rotodynamiques sans dispositif d'étanchéité d'arbre — Classe II —
Spécifications*



Reference number
ISO 15783:2002(E)

© ISO 2002

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

This document is a preview generated by EVS

© ISO 2002

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.ch
Web www.iso.ch

Printed in Switzerland

Contents

Page

Foreword.....	v
Introduction.....	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Design	7
4.1 General.....	7
4.2 Prime movers	7
4.3 Critical speed, balancing and vibrations.....	9
4.4 Pressure-containing parts.....	10
4.5 Branches, nozzles and miscellaneous connections.....	13
4.6 External forces and moments on flanges (inlet and outlet)	14
4.7 Branch (nozzle) flanges	14
4.8 Impellers	14
4.9 Wear rings or equivalent components.....	14
4.10 Running clearance.....	14
4.11 Shafts.....	15
4.12 Bearings	15
4.13 Circulation flow.....	16
4.14 Nameplates.....	17
4.15 Direction of rotation	17
4.16 Couplings for magnetic drive pumps	17
4.17 Baseplate	18
4.18 Monitoring	18
5 Materials	19
5.1 Selection of materials.....	19
5.2 Material composition and quality.....	19
5.3 Repairs.....	19
6 Testing	19
6.1 General.....	19
6.2 Material tests	20
6.3 Pump test and inspection	20
7 Preparation for despatch	23
7.1 Surface protection	23
7.2 Securing of rotating parts for transport	23
7.3 Openings	23
7.4 Pipes and auxiliaries	23
7.5 Identification	23
8 Information for use	24
Annex A (normative) Data sheet for magnetic drive pumps and canned motor pumps	25
Annex B (informative) External forces and moments on flanges	30
Annex C (informative) Enquiry, proposal and purchase order.....	31
Annex D (informative) Documentation after purchase order.....	32
Annex E (informative) Typical circulation piping plans and characteristics for canned motor pumps and magnetic drive pumps	33

Annex F (informative) **Internationally accepted materials for pump parts**39

Annex G (informative) **Checklist**42

Bibliography44

This document is a preview generated by EVS

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 3.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 15783 was prepared by Technical Committee ISO/TC 115, *Pumps*, Subcommittee SC 1, *Dimensions and technical specifications of pumps*.

Annex A forms a normative part of this International Standard. Annexes B, C, D, E, F and G are for information only.

Introduction

This International Standard is the first of a series dealing with technical specifications for seal-less pumps; they correspond to two classes of technical specifications, Classes I and II, of which Class I is the more severe requirements.

Where a decision may be required by the purchaser, or agreement is required between the purchaser and manufacturer/supplier, the relevant text is highlighted with • and is listed in annex G.

This document is a preview generated by EVS

Seal-less rotodynamic pumps — Class II — Specification

1 Scope

1.1 This International Standard specifies the requirements for seal-less rotodynamic pumps that are driven with permanent magnet coupling (magnet drive pumps) or with canned motor, and which are mainly used in chemical processes, water treatment and petrochemical industries. Their use can be dictated by space, noise, environment or safety regulations.

Seal-less pumps are pumps where an inner rotor is completely contained in a pressure vessel holding the pumped fluid. The pressure vessel or primary containment device is sealed by static seals such as gaskets or O-rings.

1.2 Pumps will normally conform to recognized standard specifications (e.g. ISO 5199, explosion protection, electromagnetic compatibility), except where special requirements are specified herein.

1.3 This International Standard includes design features concerned with installation, maintenance and operational safety of the pumps, and defines those items to be agreed upon between the purchaser and manufacturer/supplier.

1.4 Where conformity to this International Standard has been requested and calls for a specific design feature, alternative designs may be offered providing that they satisfy the intent of this International Standard and they are described in detail. Pumps which do not conform with all requirements of this International Standard may also be offered providing that the deviations are fully identified and described.

Whenever documents include contradictory requirements, they should be applied in the following sequence of priority:

- a) purchase order (or inquiry, if no order placed), see annexes D and E;
- b) data sheet (see annex A) or technical sheet or specification;
- c) this International Standard;
- d) other standards.

2 Normative references

The following normative documents contain provisions which, through reference in this text, constitute provisions of this International Standard. For dated references, subsequent amendments to, or revisions of, any of these publications do not apply. However, parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. For undated references, the latest edition of the normative document referred to applies. Members of ISO and IEC maintain registers of currently valid International Standards.

ISO 76, *Rolling bearings — Static load ratings*

ISO 281, *Rolling bearings — Dynamic load ratings and rating life*

ISO 3274, *Geometrical Product Specifications (GPS) — Surface texture: Profile method — Nominal characteristics of contact (stylus) instruments*

ISO 3744, *Acoustics — Determination of sound power levels of noise sources using sound pressure — Engineering method in an essentially free field over a reflecting plane*

ISO 3746, *Acoustics — Determination of sound power levels of noise sources using sound pressure — Survey method using an enveloping measurement surface over a reflecting plane*

ISO 5199, *Technical specifications for centrifugal pumps — Class II*

ISO 7005-1, *Metallic flanges — Part 1: Steel flanges*

ISO 7005-2, *Metallic flanges — Part 2: Cast iron flanges*

ISO 7005-3, *Metallic flanges — Part 3: Copper alloy and composite flanges*

ISO 9906, *Rotodynamic pumps — Hydraulic performance acceptance tests — Grades 1 and 2*

IEC 60034-1, *Rotating electrical machines — Part 1: Rating and performance*

EN 12162, *Liquid pumps — Safety requirements — Procedure for hydrostatic testing*

3 Terms and definitions

For the purposes of this International Standard, the following terms and definitions apply.

3.1

magnetic drive pump

MDP

pump in which the shaft power of the drive is transferred to the impeller of the pump by means of a permanent magnetic field, which passes through a containment barrier (shell) to an inner rotor having permanent magnets or an induction device

3.2

canned motor pump

CMP

pump in which the stator of an electric motor is separated from the rotor by a sealed containment barrier (liner)

NOTE 1 The rotor runs in the liquid being pumped or in another liquid.

NOTE 2 The shaft power is transmitted by means of an electromagnetic field.

3.3

seal-less rotodynamic pump

(general) pump design in which the impeller shaft also carries the rotor of either a canned induction motor or a synchronous or an asynchronous magnetic drive

NOTE The design does not use a dynamic shaft seal as a primary containment device. Static seals are the means used for containing the fluid.

3.3.1

hydraulic end

that end of the pump which transfers mechanical energy into the liquid being pumped

3.3.2

power drive end

that end of the pump containing the magnetic coupling (MDP) or the motor (CMP) which provides the mechanical energy necessary for the operation of the hydraulic end