

SUITSU JA KUUMUSE KONTROLLSÜSTEEMID. OSA 2:
LOOMULIKUL TEEL SUITSU JA KUUMUST EEMALDAVAD
LUUGID

Smoke and heat control systems - Part 2: Natural smoke
and heat exhaust ventilators

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 12101-2:2017 sisaldab Euroopa standardi EN 12101-2:2017 ingliskeelset teksti.	This Estonian standard EVS-EN 12101-2:2017 consists of the English text of the European standard EN 12101-2:2017.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 29.03.2017.	Date of Availability of the European standard is 29.03.2017.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 13.220.99

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD

EN 12101-2

NORME EUROPÉENNE

EUROPÄISCHE NORM

March 2017

ICS 13.220.99

Supersedes EN 12101-2:2003

English Version

Smoke and heat control systems - Part 2: Natural smoke and heat exhaust ventilators

Systèmes pour le contrôle des fumées et de la chaleur -
Partie 2 : Dispositifs d'évacuation naturelle de fumées
et de chaleur

Rauch- und Wärmefreihaltung - Teil 2: Natürliche
Rauch- und Wärmeabzugsgeräte

This European Standard was approved by CEN on 11 January 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

European foreword.....	5
Introduction	6
1 Scope.....	7
2 Normative references.....	7
3 Terms, definitions, symbols and abbreviations.....	7
3.1 Terms and definitions.....	7
3.2 Symbols and abbreviations	11
4 Requirements.....	13
4.1 Nominal activation conditions/sensitivity.....	13
4.1.1 Initiation device.....	13
4.1.2 Opening mechanism.....	14
4.1.3 Inputs and outputs.....	14
4.2 Response delay (response time)	14
4.2.1 Reliability.....	14
4.2.2 Opening under (snow/wind) load	14
4.2.3 Low ambient temperature.....	15
4.2.4 Opening under heat.....	15
4.3 Operational reliability.....	15
4.4 Effectiveness of smoke/hot gas extraction (aerodynamic free area)	15
4.5 Performance parameters under fire conditions.....	15
4.5.1 Resistance to heat.....	15
4.5.2 Mechanical stability	16
4.5.3 Reaction to fire.....	16
4.6 Performance under environmental conditions	16
4.6.1 Opening under load.....	16
4.6.2 Low ambient temperature.....	16
4.6.3 Stability under wind load.....	16
4.6.4 Resistance to wind-induced vibration.....	16
4.6.5 Resistance to heat	16
4.7 Durability.....	17
4.7.1 Response delay (response time)	17
4.7.2 Operational reliability.....	17
4.7.3 Performance parameters under fire conditions.....	17
5 Testing, assessment and sampling methods	17
6 Assessment and verification of constancy of performance - AVCP	19
6.1 General.....	19
6.2 Type Testing.....	19
6.2.1 General.....	19
6.2.2 Test samples, testing and compliance criteria	20
6.2.3 Test sequence	21
6.2.4 Test reports.....	22
6.2.5 Cascading determination of the product type results	22
6.3 Factory production control	23
6.3.1 General.....	23

6.3.2	Requirements.....	23
6.3.3	NSHEV specific requirements.....	25
6.3.4	Initial inspection of factory and FPC.....	26
6.3.5	Continuous surveillance of FPC.....	26
6.3.6	Procedure for modifications.....	27
6.3.7	Pre-production prototypes.....	27
7	Marking, labelling and packaging.....	28
Annex A (normative) Classification		29
A.1	Nominal activation condition/sensitivity.....	29
A.2	Response delay.....	29
A.3	Operational Reliability.....	29
A.4	Effectiveness of smoke/hot gas extraction (aerodynamic free area).....	29
A.5	Performance parameters under fire conditions.....	29
A.6	Performance under environmental conditions.....	30
A.7	Durability.....	31
A.7.1	Response delay (response time).....	31
A.7.2	Operational reliability.....	31
A.7.3	Performance parameters under fire conditions.....	31
Annex B (normative) Effectiveness of smoke/hot gas extraction (aerodynamic free area).....		32
B.1	Determination of the aerodynamic free area.....	32
B.2	Simple assessment procedure.....	32
B.2.1	General.....	32
B.2.2	Roof mounted NSHEV.....	32
B.2.3	Wall mounted NSHEV.....	32
B.3	Experimental procedure.....	33
B.3.1	General.....	33
B.3.2	Test apparatus.....	33
B.3.3	Test specimen.....	34
B.3.4	Test procedure.....	35
B.3.5	Evaluation of test results.....	36
B.3.6	Calculation of the coefficient of discharge for a family of NSHEV.....	37
B.4	Test to check the aerodynamic test installations.....	38
B.4.1	General.....	38
B.4.2	Reference test without side wind.....	39
B.4.3	Reference tests with side wind.....	39
B.4.4	Evaluation of test results.....	39
Annex C (normative) Test method for operational reliability and response time.....		54
C.1	Objective of test.....	54
C.2	Test conditions.....	54
C.3	Test apparatus.....	54
C.4	Test specimen.....	54
C.5	Test procedure.....	54
Annex D (normative) Test method for opening under load.....		56
D.1	Objective of test.....	56
D.2	Test conditions.....	56
D.3	Test apparatus.....	56
D.4	Test specimen.....	57
D.5	Test procedure.....	57
Annex E (normative) Test method for low ambient temperature.....		58
E.1	Objective of test.....	58

E.2	Test apparatus.....	58
E.3	Test specimen.....	58
E.4	Test procedure.....	58
Annex F (normative) Test method for stability under wind load.....		59
F.1	Objective of test.....	59
F.2	Test conditions.....	59
F.3	Test apparatus.....	59
F.4	Test specimen.....	59
F.5	Test procedure.....	60
F.5.1	Wind load.....	60
F.5.2	Vibration.....	60
Annex G (normative) Test method for resistance to heat.....		61
G.1	Objective of the test.....	61
G.2	Test apparatus.....	61
G.2.1	Test furnace.....	61
G.2.2	Temperature measurement.....	61
G.2.3	NSHEV mount.....	61
G.3	Test specimen.....	62
G.3.1	General.....	62
G.3.2	NSHEV mounted to a glazed partition construction.....	62
G.3.3	Roof mounted NSHEV as part of a continuous rooflight.....	62
G.3.4	Wall mounted NSHEV.....	63
G.3.5	Roof mounted NSHEV.....	63
G.4	Test procedure.....	64
Annex H (normative) Mounting and fixing conditions for the SBI or small flame tests.....		72
H.1	General.....	72
H.2	Class E.....	73
H.2.1	General.....	73
H.2.2	Small flame test in accordance to EN ISO 11925-2.....	73
H.3	Class A2 to class D.....	73
H.3.1	General.....	73
H.3.2	Single Burning Item test (SBI).....	74
H.4	Heat of combustion test.....	74
Annex I (normative) Handling changes affecting declared performances for NSHEV.....		75
I.1	General.....	75
I.2	Effectiveness of smoke/hot gas extraction.....	75
I.3	Reliability.....	75
I.4	Opening under load.....	76
I.5	Opening at low ambient temperatures.....	76
I.6	Wind load.....	77
I.7	Resistance to heat.....	77
Annex J (informative) Installation and maintenance information.....		78
J.1	Installation information.....	78
J.2	Maintenance information.....	78
Bibliography.....		88

European foreword

This document (EN 12101-2:2017) has been prepared by Technical Committee CEN/TC 191 “Fixed firefighting systems”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2017, and conflicting national standards shall be withdrawn at the latest by December 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 12101-2:2003.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this standard.

This European Standard is one of the parts of the European Standard EN 12101 covering smoke and heat control systems.

This European Standard has the general title *Smoke and heat control systems* and currently consists of the following parts:

- *Part 1: Specification for smoke barriers;*
- *Part 2: Natural smoke and heat exhaust ventilators* [the present document];
- *Part 3: Specification for powered smoke and heat exhaust ventilators;*
- *Part 4: Installed SHEVS systems for smoke and heat ventilation* [Technical Report CEN/TR 12101-4];
- *Part 5: Guidelines on functional recommendations and calculation methods for smoke and heat exhaust ventilation systems* [Technical Report CEN/TR 12101-5];
- *Part 6: Specification for pressure differential systems – Kits;*
- *Part 7: Smoke control sections;*
- *Part 8: Smoke control dampers;*
- *Part 10: Power supplies.*

According to the CEN/CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

In a fire situation, smoke and heat exhaust ventilation systems create and maintain a smoke free layer above the floor by removing smoke. They also serve simultaneously to exhaust hot gases released by a fire in the developing stages. The use of such systems to create smoke-free areas beneath a buoyant layer has become widespread. Their value in assisting in the evacuation of people from buildings and other construction works, reducing fire damage and financial loss by preventing smoke damage, facilitating access for firefighting by improving visibility, reducing roof temperatures and retarding the lateral spread of fire is firmly established. For these benefits to be obtained it is essential that natural smoke and heat exhaust ventilators (referred to in this standard as NSHEV) operate fully and reliably whenever called upon to do so during their installed life. A smoke and heat exhaust ventilation system (referred to in this standard as a SHEVS) is a system of safety equipment intended to perform a positive role in a fire emergency.

1 Scope

This European Standard applies to natural smoke and heat exhaust ventilators (NSHEV) operating as part of smoke and heat exhaust systems (SHEVS), placed on the market. This standard specifies requirements and gives test methods for natural smoke and heat exhaust ventilators which are intended to be installed in smoke and heat control systems in buildings.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54-5:2017, *Fire detection and fire alarm systems - Part 5: Heat detectors - Point detectors*

EN 54-7, *Fire detection and fire alarm systems - Part 7: Smoke detectors - Point detectors using scattered light, transmitted light or ionization*

EN 1363-1, *Fire resistance tests - Part 1: General Requirements*

EN 12101-10, *Smoke and heat control systems - Part 10: Power supplies*

EN 13501-1, *Fire classification of construction products and building elements — Part 1: Classification using test data from reaction to fire tests*

EN 13823, *Reaction to fire tests for building products — Building products excluding floorings exposed to the thermal attack by a single burning item*

EN 60584-1, *Thermocouples — Part 1: EMF specifications and tolerances (IEC 60584-1)*

EN ISO 1182, *Reaction to fire tests for products - Non-combustibility test (ISO 1182)*

EN ISO 1716, *Reaction to fire tests for products - Determination of the gross heat of combustion (calorific value) (ISO 1716)*

EN ISO 11925-2, *Reaction to fire tests - Ignitability of products subjected to direct impingement of flame - Part 2: Single-flame source test (ISO 11925-2)*

3 Terms, definitions, symbols and abbreviations

3.1 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1.1

aerodynamic free area

geometric area multiplied by the coefficient of discharge

3.1.2

ambient

word used to describe properties of the surroundings