

Industrial-process measurement and control - Data structures and elements in process equipment catalogues - Part 21: List of Properties (LOP) of automated valves for electronic data exchange - Generic structures

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 61987-21:2016 sisaldab Euroopa standardi EN 61987-21:2016 ingliskeelset teksti.	This Estonian standard EVS-EN 61987-21:2016 consists of the English text of the European standard EN 61987-21:2016.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 15.01.2016.	Date of Availability of the European standard is 15.01.2016.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 01.110, 25.040.40, 35.240.50

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:

Aru 10, 10317 Tallinn, Eesti; koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Aru 10, 10317 Tallinn, Estonia; homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

ICS 01.110; 25.040.40; 35.240.50

English Version

**Industrial-process measurement and control - Data structures
and elements in process equipment catalogues - Part 21: List of
Properties (LOP) of automated valves for electronic data
exchange - Generic structures
(IEC 61987-21:2015)**

Mesure et commande dans les processus industriels -
Structures de données et éléments dans les catalogues
d'équipements de processus - Partie 21: Liste de propriétés
(LOP) des vannes automatisées pour l'échange électronique
de données - Structures génériques
(IEC 61987-21:2015)

Industrielle Leittechnik - Datenstrukturen und -elemente in
Katalogen der Prozessleittechnik - Teil 21: Merkmalleisten
(ML) für Stellventile für den elektronischen Datenaustausch -
Allgemeine Strukturen
(IEC 61987-21:2015)

This European Standard was approved by CENELEC on 2015-10-20. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

European foreword

The text of document 65B/996/FDIS, future edition 1 of IEC 61987-21, prepared by SC 65B "Measurement and control devices", of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61987-21:2016.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2016-07-20
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2018-10-20

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 61987-21:2015 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60534-7	NOTE	Harmonized as EN 60534-7.
IEC 60770-1	NOTE	Harmonized as EN 60770-1.
IEC 61360-1	NOTE	Harmonized as EN 61360-1.
IEC 61360-2	NOTE	Harmonized as EN 61360-2.
IEC 62424	NOTE	Harmonized as EN 62424.

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60534-1	-	Industrial-process control valves - Part 1: Control valve terminology and general considerations	EN 60534-1	-
IEC 61069-5	-	Industrial-process measurement and control - Evaluation of system properties for the purpose of system assessment - Part 5: Assessment of system dependability	EN 61069-5	-
IEC 61508-6	-	Functional safety of electrical/electronic/programmable electronic safety-related systems - Part 6: Guidelines on the application of IEC 61508-2 and IEC 61508-3	EN 61508-6	-
IEC 61987-1	2006	Industrial-process measurement and control - Data structures and elements in process equipment catalogues - Part 1: Measuring equipment with analogue and digital output	EN 61987-1	2007
IEC 61987-10	-	Industrial-process measurement and control - Data structures and elements in process equipment catalogues - Part 10: Lists of Properties (LOPs) for Industrial-Process Measurement and Control for Electronic Data Exchange - Fundamentals	EN 61987-10	-
IEC 61987-11	-	Industrial-process measurement and control - Data structures and elements in process equipment catalogues - Part 11: List of Properties (LOP) of measuring equipment for electronic data exchange - Generic structures	EN 61987-11	-

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
General.....	7
Device type dictionary.....	7
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	9
4 General	9
4.1 Characterization scheme.....	9
4.2 OLOP and DLOP	10
4.3 Cardinality and polymorphism	11
5 Operating List of Properties (OLOP)	11
5.1 Generic block structure.....	11
5.2 Base conditions	12
5.3 Process case	12
5.3.1 General	12
5.3.2 Process conditions for final control elements	13
5.3.3 Other process case variable	13
5.4 Operating conditions for device design.....	13
5.4.1 General	13
5.4.2 Installation design conditions.....	14
5.4.3 Environmental design conditions.....	14
5.4.4 Process design conditions	15
5.4.5 Design conditions for valve body assembly.....	15
5.4.6 Pressure-temperature design conditions	15
5.5 Process equipment	15
5.5.1 General	15
5.5.2 Line or nozzle	16
5.6 Physical location	16
5.6.1 General	16
5.6.2 Available power supply	16
5.6.3 Process criticality classification	16
5.6.4 Area classification	16
6 Device List of Properties (DLOP)	17
6.1 Basic structure.....	17
6.1.1 General	17
6.1.2 Generic block structure.....	17
6.1.3 Relationship to IEC 61987-1	19
6.2 Identification	19
6.3 Application	19
6.4 Parameters of <device group>	19
6.5 Function and system design.....	19
6.5.1 General	19
6.5.2 Dependability.....	19

6.6	Input	19
6.6.1	General	19
6.6.2	Control input	20
6.6.3	Type of auxiliary input	20
6.7	Output	21
6.7.1	General	21
6.7.2	Type of output	21
6.8	Digital communication	22
6.8.1	General	22
6.8.2	Digital communication interface	22
6.9	Performance	23
6.9.1	General	23
6.9.2	Reference conditions for the device	23
6.9.3	Performance variable	23
6.10	Rated operating conditions	24
6.10.1	General	24
6.10.2	Installation conditions	24
6.10.3	Environmental design ratings	25
6.10.4	Process design ratings	25
6.10.5	Pressure-temperature design ratings	26
6.11	Mechanical and electrical construction	26
6.11.1	General	26
6.11.2	Overall dimensions and weight	26
6.11.3	Structural design	26
6.11.4	Explosion protection design approval	26
6.11.5	Codes and standards approval	26
6.12	Operability	27
6.12.1	General	27
6.12.2	Basic configuration	27
6.12.3	Parametrization	27
6.12.4	Adjustment	27
6.12.5	Operation	27
6.12.6	Diagnosis	27
6.13	Power supply	27
6.14	Certificates and approvals	27
6.15	Component part identifications	28
7	Composite devices	28
8	Additional aspects	28
Annex A (informative) Device type dictionary – Classification of final control elements		29
Bibliography		33
Figure 1 – Characterization of final control elements on the basis of IEC 60534-1		9
Figure 2 – Characterization of actuators		10
Figure 3 – Assignment of OLOP and DLOPs for valve body assembly		10
Figure 4 – Assignment of OLOP and DLOPs for actuators		11
Table 1 – Generic block structure of an OLOP		12

Table 2 – Generic block structure of a DLOP	18
Table A.1 – Classification scheme for final control elements	29

This document is a preview generated by EVS

INTRODUCTION

General

The exchange of product data between companies, business systems, engineering tools, data systems within companies and, in the future, control systems (electrical, measuring and control technology) can run smoothly only when both the information to be exchanged and the use of this information have been clearly defined.

Prior to this standard, requirements on process control devices and systems were specified by customers in various ways when suppliers or manufacturers were asked to quote for suitable equipment. The suppliers in their turn described the devices according to their own documentation schemes, often using different terms, structures and media (paper, databases, CDs, e-catalogues, etc.). The situation was similar in the planning and development process, with device information frequently being duplicated in a number of different information technology (IT) systems.

Any method that is capable of recording all existing information only once during the planning and ordering process and making it available for further processing, gives all parties involved an opportunity to concentrate on the essentials. A precondition for this is the standardization of both the descriptions of the objects and the exchange of information.

The IEC 61987 series proposes a method for standardization which will help both suppliers and users of process control equipment to optimize workflows both within their own companies and in their exchanges with other companies. Depending on their role in the process, engineering firms may be considered here to be either users or suppliers.

The method specifies process control equipment by means of blocks of properties. These blocks are compiled into Lists of Properties (LOPs), each of which describes a specific equipment (device) type. The IEC 61987 series covers both properties that may be used in an inquiry or a proposal and detailed properties required for integration of the equipment in computer systems for other tasks.

IEC 61987-10 defines structure elements for constructing lists of properties for electrical and process control equipment in order to facilitate automatic data exchange between any two computer systems in any possible workflow, for example engineering, maintenance or purchasing workflow and to allow both the customers and the suppliers of the equipment to optimize their processes and workflows. IEC 61987-10 also provides the data model for assembling the LOPs.

IEC 61987-11, while specifying a generic structure for measuring equipment, provides several important detail descriptions, such as the handling of composite devices that are also required for LOPs describing automated industrial valves. This part of IEC 61987 specifies the generic structure for Operating and Device Lists of Properties (OLOPs and DLOPs) for automated industrial valves. Automated industrial valves are so-called final control elements and include control valves, automated on/off-valves, and process regulators. It lays down the framework for further parts of IEC 61987 in which complete LOPs for final control elements of different construction and functional principle will be specified. The generic structure may also serve as a basis for the specification of LOPs for other industrial-process control instrument types.

Device type dictionary

Annex A contains a characterisation of final control elements. This is a tree of relationships between different device types. Starting at the root "equipment for industrial-process automation", it introduces the final control elements. In addition to control valves, actuators as well as accessories such as positioners belong to this group. This characterisation is used in the Process Automation domain of the IEC Common Data Dictionary (CDD).