

Fans - Performance testing using standardized airways  
(ISO 5801:2017)

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-EN ISO 5801:2017 sisaldab Euroopa standardi EN ISO 5801:2017 ingliskeelset teksti.	This Estonian standard EVS-EN ISO 5801:2017 consists of the English text of the European standard EN ISO 5801:2017.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 25.10.2017.	Date of Availability of the European standard is 25.10.2017.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 23.120

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:  
Koduleht [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage [www.evs.ee](http://www.evs.ee); phone +372 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

English Version

**Fans - Performance testing using standardized airways  
(ISO 5801:2017)**

Ventilateurs - Essais aérauliques sur circuits  
normalisés (ISO 5801:2017)

Ventilatoren - Leistungsmessung auf genormten  
Prüfständen (ISO 5801:2017)

This European Standard was approved by CEN on 18 May 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

**CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels**

## European foreword

This document (EN ISO 5801:2017) has been prepared by Technical Committee ISO/TC 117 “Fans” in collaboration with Technical Committee CEN/TC 156 “Ventilation for buildings” the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2018, and conflicting national standards shall be withdrawn at the latest by April 2018.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN ISO 5801:2008.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

### Endorsement notice

The text of ISO 5801:2017 has been approved by CEN as EN ISO 5801:2017 without any modification.

# Contents

	Page
<b>Foreword</b> .....	<b>vii</b>
<b>Introduction</b> .....	<b>viii</b>
<b>1 Scope</b> .....	<b>1</b>
<b>2 Normative references</b> .....	<b>1</b>
<b>3 Terms and definitions</b> .....	<b>1</b>
<b>4 Symbols, abbreviated terms and subscripts</b> .....	<b>10</b>
4.1 Symbols and abbreviated terms.....	10
4.2 Subscripts.....	12
<b>5 General</b> .....	<b>13</b>
<b>6 Test configurations</b> .....	<b>14</b>
6.1 General.....	14
6.2 Category A configuration.....	15
6.3 Category B configuration.....	15
6.4 Category C configuration.....	15
6.5 Category D configuration.....	15
6.6 Inlets and outlets.....	15
6.7 Fans with significant swirl.....	15
6.8 Airways.....	15
6.9 Test space.....	16
6.10 Leakage.....	16
6.11 Test report.....	16
<b>7 Carrying out the test</b> .....	<b>16</b>
7.1 Working fluid.....	16
7.2 Rotational speed.....	16
7.3 Steady operation.....	16
7.4 Ambient conditions.....	16
7.5 Pressure readings.....	17
7.6 Test for a specified duty.....	17
7.7 Test for a fan characteristic curve.....	17
7.8 Operating range.....	17
<b>8 Airways for duct simulations</b> .....	<b>17</b>
8.1 General.....	17
8.2 Common segments at fan inlet (iCS).....	17
8.3 Inlet duct simulation (iDS).....	19
8.4 Common segment at fan outlet (oCS).....	20
8.5 Outlet duct simulation (oDS).....	21
8.6 Long duct (LD).....	22
8.7 Loss allowances for standardized airways.....	23
8.7.1 Loss allowances for an inlet common segment (iCS).....	23
8.7.2 Loss allowances for inlet duct simulation (iDS).....	24
8.7.3 Loss allowances for outlet common segments (oCS).....	24
8.7.4 Loss allowances for duct simulation at outlet (oDS).....	25
8.7.5 Loss allowances for long duct (LD).....	25
<b>9 Standardized test chambers</b> .....	<b>25</b>
9.1 General.....	25
9.2 Pressure tappings.....	25
9.3 Flow-settling means.....	25
9.3.1 General.....	25
9.3.2 Piezometer ring check.....	26
9.3.3 Blow through verification test.....	26
9.3.4 Outlet chamber reverse flow verification test.....	26

9.4	Standardized inlet test chambers (iTC)	26
9.4.1	Test chambers	26
9.4.2	Fan under test	29
9.5	Standardized outlet test chambers (oTC)	30
9.5.1	Test chambers	30
9.5.2	Fan under test	30
<b>10</b>	<b>Various component parts for a laboratory setup</b>	<b>31</b>
10.1	General	31
10.2	Variable supply system	31
10.2.1	General	31
10.2.2	Throttling device	31
10.2.3	Auxiliary fan	31
10.3	Straightener	31
10.3.1	General	31
10.3.2	Cell straightener	31
10.3.3	Star straightener	32
10.4	Transition parts	33
10.4.1	General	33
10.4.2	Rectangular/circular transition	34
10.4.3	Circular/circular transition	34
10.4.4	Connection for double-inlet fans	35
<b>11</b>	<b>Standard test configurations</b>	<b>35</b>
11.1	Units	35
11.2	Measuring flow rate	40
11.3	Standard test configurations A	41
11.4	Standard test configurations B	42
11.5	Standard test configurations C	42
11.6	Standard test configurations D	42
<b>12</b>	<b>Measurements</b>	<b>43</b>
12.1	Calibration	43
12.2	Dimensions and cross-sectional areas	43
12.2.1	Tolerance on dimensions	43
12.2.2	Cross-sectional area	43
12.3	Rotational speed	44
12.4	Power input	44
12.4.1	General	44
12.4.2	Motor input power	44
12.4.3	Fan shaft power	45
12.4.4	Impeller power	46
12.4.5	Transmission systems	46
12.5	Mass flow rate	46
12.6	Temperature	47
12.6.1	General	47
12.6.2	Accuracy of temperature measurement	47
12.6.3	Correction for high velocities	47
12.7	Humidity	48
12.8	Pressure	48
12.8.1	Barometers	48
12.8.2	Manometers	49
12.8.3	Damping of manometers	49
12.8.4	Checking of manometers	49
12.8.5	Position of manometers	49
12.8.6	Average pressure in an airway	50
12.8.7	Construction of tappings	50
12.8.8	Position and connections	51
12.8.9	Methods of measurement	51
12.8.10	Checks for compliance	51

12.8.11	Use of Pitot-static tube.....	51
12.9	Air properties.....	52
12.9.1	General.....	52
12.9.2	Density of air at section x.....	52
12.9.3	Air viscosity.....	53
12.9.4	Standard air.....	53
<b>13</b>	<b>Reference conditions.....</b>	<b>53</b>
<b>14</b>	<b>General rules for conversion of test results.....</b>	<b>54</b>
14.1	General.....	54
14.2	Laws on fan similarity.....	54
14.2.1	General.....	54
14.2.2	Geometrical similarity.....	54
14.2.3	Reynolds number similarity.....	55
14.2.4	Mach number and similarity of the velocity triangles.....	55
<b>15</b>	<b>Calculations.....</b>	<b>55</b>
15.1	Test results.....	55
15.1.1	General.....	55
15.1.2	Temperature.....	56
15.1.3	Pressure.....	58
15.1.4	Set of formulae.....	58
15.1.5	Simplified sets of formulae, which can be used for $v_{2,ref} \leq 65\text{m/s}$ .....	60
15.1.6	Fan pressure.....	61
15.1.7	Fan static pressure.....	62
15.1.8	Volume flow rate of the fan.....	62
15.1.9	Fan air power and efficiency.....	62
15.2	Efficiencies.....	65
15.2.1	General.....	65
15.2.2	Fan static air power and static efficiency.....	66
15.3	Conversion rules.....	66
15.3.1	General.....	66
15.3.2	Shaft power and impeller power.....	66
<b>16</b>	<b>Fan characteristic curves.....</b>	<b>67</b>
16.1	Methods of plotting.....	67
16.2	Characteristic curves at constant speed.....	67
16.3	Characteristic curves at inherent speed.....	68
16.4	Complete fan characteristic curve.....	68
16.5	Test for a specified duty.....	69
16.6	Specific fan types.....	69
<b>17</b>	<b>Uncertainty analysis.....</b>	<b>70</b>
17.1	Principle.....	70
17.2	Pre-test and post-test analysis.....	70
17.3	Analysis procedure.....	70
17.4	Propagation of uncertainties.....	70
17.5	Reporting uncertainties.....	71
17.6	Maximum allowable uncertainties for measurements.....	71
17.7	Maximum allowable uncertainty of results.....	72
<b>Annex A</b>	<b>(normative) Determination of air flow rate.....</b>	<b>73</b>
<b>Annex B</b>	<b>(informative) Fan-powered roof exhaust ventilators.....</b>	<b>90</b>
<b>Annex C</b>	<b>(informative) Chamber leakage test procedure.....</b>	<b>91</b>
<b>Annex D</b>	<b>(informative) Fan outlet elbow in the case of a non-horizontal discharge axis.....</b>	<b>97</b>
<b>Annex E</b>	<b>(informative) Input power calculation for driven fans at design point.....</b>	<b>100</b>
<b>Annex F</b>	<b>(informative) Motor fed from a variable frequency speed device.....</b>	<b>109</b>

<b>Annex G</b> (informative) <b>Axial fans without outlet guide vanes</b> .....	<b>110</b>
<b>Annex H</b> (informative) <b>Vapour pressure, <math>p_v</math></b> .....	<b>112</b>
<b>Annex I</b> (informative) <b>Clearances</b> .....	<b>113</b>
<b>Annex J</b> (normative) <b>Polytropic approach for the calculation of <math>p_{fC}</math> from <math>p_{fTe}</math></b> .....	<b>115</b>
<b>Annex K</b> (informative) <b>Examples for test setups</b> .....	<b>117</b>
<b>Annex L</b> (informative) <b>Measurement of plenum fans and plug fans</b> .....	<b>125</b>
<b>Annex M</b> (informative) <b>Comparison of NEMA methodology for calculation motor efficiency with IEC</b> .....	<b>127</b>
<b>Annex N</b> (informative) <b>Report and results of test</b> .....	<b>128</b>
<b>Bibliography</b> .....	<b>136</b>



## Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see [www.iso.org/directives](http://www.iso.org/directives)).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see [www.iso.org/patents](http://www.iso.org/patents)).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: [www.iso.org/iso/foreword.html](http://www.iso.org/iso/foreword.html).

This document was prepared by Technical Committee ISO/TC 117, *Fans*.

This third edition cancels and replaces the second edition (ISO 5801:2007), which has been technically revised. It also incorporates the Technical Corrigendum ISO 5801:2007/Cor.1:2008.

## Introduction

This document is the result of almost 50 years of discussion, comparative testing and detailed analyses by leading specialists from the fan industry and research organizations throughout the world.

It was demonstrated many years ago that the codes for fan performance testing established in different countries do not always lead to the same results.

The need for an International Standard has been evident for some time and Technical Committee ISO/TC 117 started its work in 1963. Important progress has been achieved over the years and, although the International Standard itself was not yet published, the successive revisions of various national standards led to much better agreement among them.

It has become possible since 1997 to complete this document by agreement on certain essential points. It is to be borne in mind that the test equipment, especially for large fans, is very expensive and it was necessary to include in this document many setups from various national codes in order to authorize their future use. This explains the sheer volume of the first edition (ISO 5801:1997).

The second edition (ISO 5801:2007) of this document was the result of a survey of ISO members, deleting those methods that were the least frequently used. A significant reduction in the number of pages had been achieved.

For the third edition, the contents were reorganized to define and allow all possible configurations of defined component parts as standardized test setups. A further significant reduction of volume has been achieved by streamlining the content.

Essential features of this document are as follows.

- **Installation categories and test configurations** (see [Clause 5](#) and [Clause 6](#)).

Since the connections of a duct to a fan inlet and/or outlet affect the fan's performance, a number of installation categories and test configurations need to be recognized.

- **Common segments** (see [Clause 8](#)).

It is essential that all standardized test airways to be used with fans need to have portions in common adjacent to the fan inlet and/or outlet sufficient to ensure consistent determination of fan pressure.

Geometric variations of these common segments are strictly limited.

- **Flow rate measurement** (see [12.5](#) and [Annex A](#)).

Determination of flow rate has been separated from the determination of fan pressure. A number of standardized methods may be used.

- **Test results** (see [Clause 15](#)).

Methods of measurement and calculation for the flow rate, for the fan pressure and for the fan efficiencies are established taking into account all compressibility effects of the air. For fan pressure less than 2 000 Pa, the change of density between fan inlet and fan outlet is allowed to be neglected. Other compressibility effects are allowed to be neglected for reference velocity values not higher than 65 m/s (see [Clause 13](#)).

# Fans — Performance testing using standardized airways

## 1 Scope

This document specifies procedures for the determination of the performance of fans of all types except those designed solely for air circulation, e.g. ceiling fans and table fans. Testing of jet fans is described in ISO 13350.

This document provides estimates of uncertainty of measurement and rules for the conversion, within specified limits, of test results for changes in speed, gas handled and, in the case of model tests, size are given.

## 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5136, *Acoustics — Determination of sound power radiated into a duct by fans and other air-moving devices — In-duct method*

ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 1: General principles and requirements*

ISO 5802, *Industrial fans — Performance testing in situ*

ISO 13347 (all parts), *Industrial fans — Determination of fan sound power levels under standardized laboratory conditions*

ISO 13348, *Industrial fans — Tolerances, methods of conversion and technical data presentation*

ISO 13349, *Fans — Vocabulary and definitions of categories*

ISO 13350, *Fans — Performance testing of jet fans*

IEC 60034-1:2010, *Rotating electrical machines — Part 1: Rating and performance*

IEC 60034-2-1:2014, *Rotating electrical machines — Part 2-1: Standard methods for determining losses and efficiency from tests (excluding machines for traction vehicles)*

IEC 60051-2, *Direct acting indicating analogue electrical measuring instruments and their accessories — Part 2: Special requirements for ammeters and voltmeters*

IEC 60051-3, *Direct acting indicating analogue electrical measuring instruments and their accessories — Part 3: Special requirements for wattmeters and varmeters*

## 3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 13349 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <http://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>