

**Industrial communication networks - Fieldbus
specifications - Part 3-3: Data-link layer service definition
- Type 3 elements**

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 61158-3-3:2014 sisaldab Euroopa standardi EN 61158-3-3:2014 inglisekeelset teksti.	This Estonian standard EVS-EN 61158-3-3:2014 consists of the English text of the European standard EN 61158-3-3:2014.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 17.10.2014.	Date of Availability of the European standard is 17.10.2014.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 25.040.40, 35.100.20, 35.110

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

English Version

**Industrial communication networks - Fieldbus specifications -
Part 3-3: Data-link layer service definition - Type 3 elements
(IEC 61158-3-3:2014)**

Réseaux de communication industriels - Spécifications des
bus de terrain - Partie 3-3: Définition des services de la
couche liaison de données - Éléments de type 3
(CEI 61158-3-3:2014)

Industrielle Kommunikationsnetze - Feldbusse - Teil 3-3:
Dienstfestlegungen des Data Link Layer
(Sicherheitsschicht) - Typ 3-Elemente
(IEC 61158-3-3:2014)

This European Standard was approved by CENELEC on 2014-09-17. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65C/759/FDIS, future edition 2 of IEC 61158-3-3, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-3-3:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-06-17
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-09-17

This document supersedes EN 61158-3-3:2008.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Endorsement notice

The text of the International Standard IEC 61158-3-3:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61158-2	NOTE	Harmonized as EN 61158-2.
IEC 61158-4-3	NOTE	Harmonized as EN 61158-4-3.
IEC 61158-5-3	NOTE	Harmonized as EN 61158-5-3.
IEC 61158-6-3	NOTE	Harmonized as EN 61158-6-3.

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158-1	-	Industrial communication networks - Fieldbus specifications - Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series	EN 61158-1	-
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic Reference Model: The Basic Model	-	-
ISO/IEC 7498-3	-	Information technology - Open Systems Interconnection - Basic Reference Model: Naming and addressing	-	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
1.1 General.....	8
1.2 Specifications.....	8
1.3 Conformance.....	9
2 Normative references.....	9
3 Terms, definitions, symbols, abbreviations and conventions.....	9
3.1 Reference model terms and definitions.....	9
3.2 Service convention terms and definitions.....	11
3.3 Common data-link service terms and definitions.....	12
3.4 Additional Type 3 data-link specific definitions.....	13
3.5 Common symbols and abbreviations.....	15
3.6 Additional Type 3 symbols and abbreviations.....	16
3.7 Common conventions.....	18
3.8 Additional Type 3 conventions.....	19
4 Connectionless-mode data-link service.....	20
4.1 General.....	20
4.2 Model of the connectionless-mode data-link service.....	20
4.3 Sequence of primitives.....	22
4.4 Detailed description of DL services.....	25
5 DL-management Service.....	44
5.1 General.....	44
5.2 Facilities of the DLMS.....	44
5.3 Services of the DL-management.....	45
5.4 Overview of interactions.....	46
5.5 Detailed specification of services and interactions.....	48
Bibliography.....	68
Figure 1 – Relationships of DLSAPs, DLSAP-addresses and group DL-addresses.....	12
Figure 2 – SDA service.....	23
Figure 3 – SDN service.....	23
Figure 4 – SRD service.....	23
Figure 5 – MSRD service.....	24
Figure 6 – CS service.....	24
Figure 7 – Reset, Set value, Get value, Ident (local), DLSAP status, DLSAP activate, DLSAP activate responder, DLSAP activate subscriber and DLSAP deactivate services.....	47
Figure 8 – Event service.....	47
Figure 9 – Ident (remote) service.....	48
Table 1 – Summary of DL services and primitives.....	22
Table 2 – SDA data ack primitives and parameters.....	26
Table 3 – Values of DL_status for the SDA data ack service.....	28
Table 4 – SDN data primitives and parameters.....	29

Table 5 – Values of DL_status for the SDN data service	31
Table 6 – SRD data reply primitives and parameters	32
Table 7 – Values of Update_status for the SRD data reply service	33
Table 8 – Additional values of DL_status for the SRD data reply service	34
Table 9 – SRD reply-update primitives and parameters	34
Table 10 – Values of DL_status for the SRD reply-update service	36
Table 11 – MSRD MCT data reply primitives and parameters	37
Table 12 – MSRD DXM data reply primitive and parameters	39
Table 13 – CS time event primitives and parameters	41
Table 14 – Values of DL_status for the CS time event service	42
Table 15 – CS clock value primitives and parameters	42
Table 16 – Values of CS_status for the CS clock value service	44
Table 17 – Values of DL_status for the CS clock value service	44
Table 18 – Summary of DL-management services and primitives	47
Table 19 – Reset primitives and parameters	48
Table 20 – Values of DLM_status for the reset service	48
Table 21 – Set value primitives and parameters	49
Table 22 – Mandatory DLE-variables	50
Table 23 – Optional DLE-variables	50
Table 24 – Permissible values of mandatory DLE-variables	51
Table 25 – Permissible values of optional DLE-variables	51
Table 26 – Meaning of the values for the parameter isochronous_mode	52
Table 27 – Default reaction times and operating parameters for a master station for asynchronous transmission	52
Table 28 – Default reaction times and operating parameters for a slave station with asynchronous transmission	52
Table 29 – Default reaction times and operating parameters for master stations for coupling of synchronous and asynchronous transmission segments	53
Table 30 – Default reaction times and operating parameter for slave stations for coupling of synchronous and asynchronous transmission segments	53
Table 31 – Values of DLM_status for the set value service	53
Table 32 – Get value primitives and parameters	54
Table 33 – Additional mandatory DLE-variables in master stations	54
Table 34 – Permissible values of the additional DLE-variables in master stations	55
Table 35 – Values of DLM_status for the get value service	55
Table 36 – Event primitive and parameters	55
Table 37 – Mandatory DLL events and fault types	56
Table 38 – Permissible values of TSH	56
Table 39 – Ident primitives and parameters	57
Table 40 – Ident_list for the ident service	57
Table 41 – Values of DLM_status for the ident service (local)	58
Table 42 – Values of DLM_status for the ident service (remote)	58
Table 43 – DLSAP status primitives and parameters	58
Table 44 – Values of DLM_status for the DLSAP status service	59

Table 45 – DLSAP activate primitives and parameters	60
Table 46 – DLSAP activate service_list.....	60
Table 47 – DLSAP activate DLSDU_length_list (SDA, SDN, SRD, MSRD and CS).....	61
Table 48 – DLSDU lengths of SDA and SDN as used in the DLSAP activate service.....	62
Table 49 – DLSDU lengths of SRD and MSRD as used in the (master station) DLSAP activate service.....	62
Table 50 – DLSDU lengths of CS as used in the DLSAP activate service	62
Table 51 – Values of DLM_status for the DLSAP activate service	62
Table 52 – DLSAP activate responder primitives and parameters	63
Table 53 – DLSDU_length_list for the DLSAP activate responder service	63
Table 54 – DLSDU length of SRD and MSRD as used in the DLSAP activate responder service.....	64
Table 55 – Values of DLM_status for the DLSAP activate responder service	65
Table 56 – DLSAP activate subscriber primitives and parameters	65
Table 57 – DLSDU_length_list for the DLSAP activate subscriber service.....	66
Table 58 – DLSDU lengths of MSRD as used in the DLSAP activate subscriber service (master and slave stations).....	66
Table 59 – Values of DLM_status for the DLSAP activate subscriber service	66
Table 60 – DLSAP deactivate primitives and parameters	67
Table 61 – Values of DLM_status for the DLSAP deactivate service	67

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the data-link layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 3-3: Data-link layer service definition – Type 3 elements

1 Scope

1.1 General

This part of IEC 61158 provides common elements for basic time-critical messaging communications between devices in an automation environment. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the Type 3 fieldbus data-link layer in terms of

- a) the primitive actions and events of the service;
- b) the parameters associated with each primitive action and event, and the form which they take; and
- c) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

- the Type 3 fieldbus application layer at the boundary between the application and data-link layers of the fieldbus reference model, and
- systems management at the boundary between the data-link layer and systems management of the fieldbus reference model.

1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual data-link layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of data-link protocols for time-critical communications. A secondary objective is to provide migration paths from previously existing industrial communications protocols.

This specification may be used as the basis for formal DL-Programming-Interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.