

**Industrial communication networks
Fieldbus specifications
Part 5-3: Application layer service definition
Type 3 elements**

EVS

EESTI STANDARDI EESSÖNA**NATIONAL FOREWORD**

S E EVS-EN 61158-5-3:2014 E EN 61158-5-3:2014	E EVS-EN 61158-5-3:2014 E EN 61158-5-3:2014
S EVS	S E
E E 10 10 2014	10 10 2014 E
S E S	S E

EVS-

S 25.040.40; 35.100.70; 35.110

Standardite reproduutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

E S
10 1031 E _____ 605 5050 - _____ E S :
N

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

E S
10 1031 E 605 5050 - S :
N

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 61158-5-3

October 2014

ICS 25.040.40; 35.100.70; 35.110

Supersedes EN 61158-5-3:2012

English Version

**Industrial communication networks - Fieldbus specifications -
Part 5-3: Application layer service definition - Type 3 elements
(IEC 61158-5-3:2014)**

Réseaux de communication industriels - Spécifications des
bus de terrain - Partie 5-3: Définition des services de la
couche application - Éléments de type 3
(CEI 61158-5-3:2014)

Industrielle Kommunikationsnetze - Feldbusse -
Teil 5-3: Dienstfestlegungen des Application Layer
(Anwendungsschicht) - Typ 3-Elemente
(IEC 61158-5-3:2014)

This European Standard was approved by CENELEC on 2014-09-22. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65C/763/FDIS, future edition 3 of IEC 61158-5-3, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-5-3:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-06-22
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-09-22

This document supersedes EN 61158-5-3:2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Endorsement notice

The text of the International Standard IEC 61158-5-3:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

- | | | |
|---------------------|------|---|
| IEC 61158-6-10:2014 | NOTE | Harmonized as EN 61158-6-10 ¹⁾ (not modified). |
| IEC 61784-1:2014 | NOTE | Harmonized as EN 61784-1:2014 (not modified). |
| IEC 61784-2:2014 | NOTE | Harmonized as EN 61784-2 ¹⁾ (not modified). |

¹⁾ To be published.

EVS

Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here:
www.cenelec.eu

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61131-1	-	Programmable controllers - Part 1: General information	EN 61131-1	-
IEC 61158-1	2014	Industrial communication networks - Fieldbus specifications - Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series	EN 61158-1	2014
IEC 61158-3-3	2014	Industrial communication networks - Fieldbus specifications - Part 3-3: Data-link layer service definition - Type 3 elements	EN 61158-3-3 ²⁾	-
IEC 61158-4-3	2014	Industrial communication networks - Fieldbus specifications - Part 4-3: Data-link layer protocol specification - Type 3 elements	EN 61158-4-3 ²⁾	-
IEC 61158-5-10	2014	Industrial communication networks - Fieldbus specifications - Part 5-10: Application layer service definition - Type 10 elements	EN 61158-5-10 ²⁾	-
IEC 61158-6-3	2014	Industrial communication networks - Fieldbus specifications - Part 6-3: Application layer protocol specification - Type 3 elements	EN 61158-6-3 ²⁾	-
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic reference model: The basic model	-	-
ISO/IEC 7498-3	-	Information technology - Open Systems Interconnection - Basic reference model: Naming and addressing	-	-
ISO/IEC 8822	-	Information technology - Open Systems Interconnection - Presentation service definition	-	

²⁾ To be published.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC 8824-1	-	Information technology - Abstract Syntax Notation One (ASN.1): Specification of basic notation	-	-
ISO/IEC 9545	-	Information technology - Open Systems Interconnection - Application layer structure	-	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-

EVS

CONTENTS

FOREWORD.....	11
INTRODUCTION.....	13
1 Scope.....	14
1.1 General	14
1.2 Specifications	15
1.3 Conformance.....	15
2 Normative references	15
3 Terms, definitions, abbreviations, symbols and conventions	16
3.1 Referenced terms and definitions	16
3.2 Fieldbus Application Layer Type 3 – specific terms and definitions	18
3.3 Abbreviations and symbols	25
3.4 Conventions	26
4 Concepts	31
5 Data type ASE.....	32
6 Communication model specification.....	32
6.1 DP concepts	32
6.2 ASEs.....	51
6.3 Summary of FAL classes	430
6.4 Permitted FAL services by AREP role.....	431
6.5 Conformance classes	435
6.6 Application characteristics.....	436
Bibliography.....	438
 Figure 1 – Example of DP communication with a single controlling device	34
Figure 2 – Example of DP communication with several controlling devices	34
Figure 3 – Example of DP communication between field devices	35
Figure 4 – DP-slave model (modular DP-slave).....	37
Figure 5 – DP-slave model (compact DP-slave)	38
Figure 6 – Overview of application processes	39
Figure 7 – DP-slave model (modular DP-slave).....	40
Figure 8 – Application Service Elements (ASEs)	42
Figure 9 – Application Process with application Objects (APOs)	43
Figure 10 – Access to a remote APO	44
Figure 11 – Access to a remote APO for publisher/subscriber association	45
Figure 12 – Example of one AR with two AREPs	46
Figure 13 – Relation of a simple process data object to the real object	52
Figure 14 – Relation of a combined process data object to the real objects.....	54
Figure 15 – Sequence of an isochronous DP cycle with one DP-master (class 1).....	85
Figure 16 – Additional time relationships in a DP system operating in isochronous mode	86
Figure 17 – DP system with optimized isochronous DP cycle	88
Figure 18 – Buffered synchronized isochronous mode at the DP-master (class 1).....	89

Figure 19 – Enhanced synchronized isochronous mode at the DP-master (class 1)	90
Figure 20 – Input, output and PLL state machine interaction	91
Figure 21 – PLL state diagram	96
Figure 22 – OUTPUT state diagram	100
Figure 23 – INPUT state diagram.....	104
Figure 24 – Treatment of an alarm in the DP system.....	137
Figure 25 – Load Region state diagram for erasable memory.....	236
Figure 26 – Load region state diagram for non-erasable memory	237
Figure 27 – Function invocation state diagram	269
Figure 28 – System architecture	283
Figure 29 – Assignment of communication relationship to application relationship	290
Figure 30 – MS0 application relationship	296
Figure 31 – Output buffer model of a DP-slave without sync functionality.....	297
Figure 32 – Output buffer model of a DP-slave with sync functionality	297
Figure 33 – Input buffer model of a DP-slave without freeze functionality.....	298
Figure 34 – Input buffer model of a DP-slave with freeze functionality.....	298
Figure 35 – MS1 application relationship	299
Figure 36 – MS2 application relationship	299
Figure 37 – Example of inter-network communication	300
Figure 38 – Example without inter-network addressing.....	301
Figure 39 – First example with inter-network addressing.....	301
Figure 40 – Second example with inter-network addressing	302
Figure 41 – MS3 application relationship	304
Figure 42 – MM1 application relationship	304
Figure 43 – MM2 application relationship	305
Figure 44 – Cycle time of the DP system	437
 Table 1 – Requirements and features of fieldbus DP.....	33
Table 2 – Status values of the service primitives.....	50
Table 3 – Access Rights MS1	53
Table 4 – Access Rights MS2	53
Table 5 – Access Rights MS1	56
Table 6 – Access Rights MS2	56
Table 7 – SCL matching rules	57
Table 8 – Read	57
Table 9 – Write	59
Table 10 – Data transport	60
Table 11 – Format (simple input data description).....	64
Table 12 – Consistency (simple input data description).....	64
Table 13 – Format (simple output data).....	66
Table 14 – Consistency (simple output data).....	66
Table 15 – Format (extended input data)	67
Table 16 – Consistency (extended input data)	68

Table 17 – Format (extended output data)	69
Table 18 – Consistency (extended output data)	70
Table 19 – Set Input	71
Table 20 – Read Input	71
Table 21 – Get Input	73
Table 22 – New Input.....	74
Table 23 – Set Output.....	75
Table 24 – Final.....	76
Table 25 – Read Output.....	76
Table 26 – Get Output	77
Table 27 – Clear Flag	77
Table 28 – New Flag	78
Table 29 – New Output	78
Table 30 – Clear Flag	78
Table 31 – Global Control	79
Table 32 – Clear Command	79
Table 33 – Sync Command	79
Table 34 – Freeze Command	80
Table 35 – New publisher data.....	80
Table 36 – Get publisher data.....	81
Table 37 – New Flag	81
Table 38 – SYNCH	82
Table 39 – SYNCH Delayed.....	82
Table 40 – DX Finished	83
Table 41 – SYNCH Event.....	83
Table 42 – Status	83
Table 43 – Primitives issued by the AL to the PLL state machine	92
Table 44 – Primitives issued by the user to the PLL state machine	92
Table 45 – Allowed values of Status	93
Table 46 – Primitives issued by the user to the input state machine	93
Table 47 – Primitives issued by the user to the output state machine.....	93
Table 48 – Primitives issued by the PLL to the output state machine	93
Table 49 – Primitives issued by the output to the PLL state machine	93
Table 50 – Primitives issued by the PLL to the input state machine	94
Table 51 – Primitives issued by the output to the input state machine	94
Table 52 – Primitives issued by the output state machine to the AL	94
Table 53 – Primitives issued by the AL to the output state machine	94
Table 54 – Primitives issued by the input state machine to the AL	94
Table 55 – Primitives issued by the AL to the input state machine	95
Table 56 – PLL state table	97
Table 57 – OUTPUT state table	101
Table 58 – INPUT state table	105
Table 59 – Identifier status	107

Table 60 – Channel type	108
Table 61 – IO type	109
Table 62 – Status type	109
Table 63 – Status specifier	110
Table 64 – Status specifier	111
Table 65 – Module status.....	111
Table 66 – Status specifier	112
Table 67 – Link status.....	112
Table 68 – Link error.....	113
Table 69 – Set Slave Diag	114
Table 70 – Ext Diag Flag	115
Table 71 – Get Slave Diag	117
Table 72 – Read Slave Diag	126
Table 73 – New Slave Diag.....	136
Table 74 – Alarm type.....	138
Table 75 – Add Ack.....	139
Table 76 – Alarm specifier	139
Table 77 – Alarm notification	140
Table 78 – Alarm Ack.....	141
Table 79 – Prm data type.....	146
Table 80 – Supported feature	156
Table 81 – Supported profile feature.....	156
Table 82 – Role	157
Table 83 – Check user Prm.....	159
Table 84 – Prm structure	160
Table 85 – MS1 Command.....	162
Table 86 – Check user Prm result	164
Table 87 – Status values	165
Table 88 – Check Ext user Prm.....	166
Table 89 – Check Ext user Prm result	169
Table 90 – Status values	170
Table 91 – Check Cfg	170
Table 92 – Check Cfg result.....	171
Table 93 – Status values	172
Table 94 – Set Cfg.....	172
Table 95 – Get Cfg	173
Table 96 – Set Slave Add	174
Table 97 – Initiate	175
Table 98 – Abort	178
Table 99 – Instance	178
Table 100 – MS0 init DP-slave	179
Table 101 – MS1 init DP-slave	179
Table 102 – MS2 init DP-slave	180

Table 103 – DP-slave started.....	180
Table 104 – Alarm limit	181
Table 105 – DP-slave stopped	181
Table 106 – Reset DP-slave	182
Table 107 – DP-slave fault.....	182
Table 108 – Application ready DP-slave.....	182
Table 109 – Start subscriber.....	183
Table 110 – Stop subscriber	183
Table 111 – Publisher active.....	184
Table 112 – Status.....	185
Table 113 – Init DP-master CI1	185
Table 114 – DP-master CI1 started	186
Table 115 – Alarm limit	187
Table 116 – DP-master CI1 stopped	187
Table 117 – Reset DP-master CI1	187
Table 118 – DP-master CI1 fault	188
Table 119 – DP-master CI1 reject	188
Table 120 – Set mode DP-master CI1	189
Table 121 – DP-master CI1 mode changed	190
Table 122 – Load bus Par DP-master CI1	191
Table 123 – Mark DP-master CI1	192
Table 124 – Abort DP-master CI1	192
Table 125 – Read value DP-master CI1	193
Table 126 – Delete SC DP-master CI1	193
Table 127 – DP-master CI1 event	194
Table 128 – Init DP-master CI2	195
Table 129 – Reset DP-master CI2.....	196
Table 130 – DP-master CI2 fault	196
Table 131 – DP-master CI2 reject	196
Table 132 – DP-master CI2 closed.....	197
Table 133 – DP-master CI2 event	197
Table 134 – USIF state	198
Table 135 – Data rate	202
Table 136 – USIF state	203
Table 137 – Isochronous mode	203
Table 138 – Slave type	206
Table 139 – Alarm mode	207
Table 140 – Get Master Diag	210
Table 141 – MDiag identifier	210
Table 142 – Start Seq.....	211
Table 143 – Area code (start seq).....	212
Table 144 – Download	213
Table 145 – Upload.....	214

Table 146 – End Seq	215
Table 147 – Act Para Brct.....	216
Table 148 – Area code (Act Para Brct).....	216
Table 149 – Act param.....	217
Table 150 – Area code (Act param)	218
Table 151 – Activate	218
Table 152 – Access rights MS1.....	220
Table 153 – Access rights MS2.....	221
Table 154 – Load region state	221
Table 155 – Initiate load	223
Table 156 – Default values for the parameter Intersegment Request Timeout.....	224
Table 157 – Push segment	225
Table 158 – Pull segment	227
Table 159 – Terminate load	229
Table 160 – Primitives issued by the user to the Load Region state machine.....	231
Table 161 – Primitives issued by the Load Region state machine to the user	232
Table 162 – Primitives issued by the Function Invocation to the Load Region state machine.....	232
Table 163 – Primitives issued by the Load Region to the Function Invocation state machine.....	233
Table 164 – Load Region state definitions	233
Table 165 – Load Region function table	234
Table 166 – Load Region state table for erasable memory.....	237
Table 167 – Load Region state table for non-erasable memory.....	249
Table 168 – Access rights MS1.....	254
Table 169 – Access rights MS2.....	254
Table 170 – Function Invocation state.....	255
Table 171 – Load Region object in use	255
Table 172 – Access rights MS1.....	256
Table 173 – Access rights MS2.....	257
Table 174 – Load Region object in use	257
Table 175 – Start	258
Table 176 – Stop	259
Table 177 – Resume	260
Table 178 – Reset	261
Table 179 – Get FI state	262
Table 180 – Call	263
Table 181 – Primitives issued by the user to the Function Invocation state machine	265
Table 182 – Primitives issued by the Function Invocation state machine to the user	266
Table 183 – Primitives issued by the Load Region to the Function Invocation state machine.....	266
Table 184 – Primitives issued by the Function Invocation to the Load Region state machine.....	267
Table 185 – Function Invocation state definitions.....	267

Table 186 – Function definitions	268
Table 187 – Function Invocation state table	269
Table 188 – CS status	285
Table 189 – Summertime	285
Table 190 – Synchronization active.....	286
Table 191 – Announcement hour	286
Table 192 – Summertime	287
Table 193 – Accuracy	287
Table 194 – Set time.....	288
Table 195 – Sync interval violation	289
Table 196 – Parameter of Initiate service without inter-network addressing.....	301
Table 197 – Parameter of Initiate service with inter-network addressing (first example)	302
Table 198 – Parameter of Initiate service with inter-network addressing (second example).....	303
Table 199 – AR type	309
Table 200 – Sync supported	310
Table 201 – Freeze supported	311
Table 202 – Group identifier	313
Table 203 – DPV1 enabled	313
Table 204 – Fail safe	314
Table 205 – WD Base	314
Table 206 – No Add change.....	316
Table 207 – Alarm mode supported	319
Table 208 – Isochronous mode supp.....	323
Table 209 – Isochronous mode	323
Table 210 – Alarm mode.....	324
Table 211 – Time device type	325
Table 212 – S_SAP_index	328
Table 213 – D_addr	329
Table 214 – Service_activate.....	330
Table 215 – Role_in_service.....	331
Table 216 – Indication_mode	331
Table 217 – Max_DLSDU_length_req_low	332
Table 218 – Max_DLSDU_length_req_high.....	333
Table 219 – Max_DLSDU_length_ind_low	333
Table 220 – Max_DLSDU_length_ind_high	334
Table 221 – S_SAP_index	339
Table 222 – D_SAP_index	339
Table 223 – D_addr	340
Table 224 – Service_activate.....	340
Table 225 – Role_in_service.....	341
Table 226 – Indication_mode	341
Table 227 – Max_DLSDU_length_req_low	342

Table 228 – Max_DLSDU_length_req_high	342
Table 229 – Max_DLSDU_length_ind_low	343
Table 230 – Max_DLSDU_length_ind_high	343
Table 231 – Sync	344
Table 232 – Freeze	345
Table 233 – DPV1 enabled	346
Table 234 – Fail safe	346
Table 235 – Enable publisher	347
Table 236 – WD Base	347
Table 237 – Alarm mode	348
Table 238 – Fail safe	358
Table 239 – S_SAP_index	365
Table 240 – D_SAP_index	366
Table 241 – D_addr	366
Table 242 – Service_activate	366
Table 243 – Role_in_service	367
Table 244 – Max_DLSDU_length_req_low	367
Table 245 – Max_DLSDU_length_req_high	367
Table 246 – Max_DLSDU_length_ind_low	368
Table 247 – Max_DLSDU_length_ind_high	368
Table 248 – DLL init DP-slave	369
Table 249 – Load ARL DP-slave	370
Table 250 – Get ARL DP-slave	376
Table 251 – Set ARL isochronous mode	382
Table 252 – Load ARL DP-master CI1	383
Table 253 – Get ARL DP-master CI1	386
Table 254 – ARL Slave update DP-master CI1	388
Table 255 – Load ARL DP-master CI2	390
Table 256 – Get ARL DP-master CI2	391
Table 257 – Load CRL DP-slave	392
Table 258 – Load CRL DXB link entries	394
Table 259 – Get CRL DP-slave	395
Table 260 – Load CRL DP-master CI1	397
Table 261 – Get CRL DP-master CI1	410
Table 262 – CRL Slave activate	423
Table 263 – CRL Slave new Prm	424
Table 264 – CRL Slave new Prm data	425
Table 265 – Load CRL DP-master CI2	427
Table 266 – Get CRL DP-master CI2	429
Table 267 – Fieldbus AL class summary	430
Table 268 – Assignment of the services to DP-masters and DP-slaves	432
Table 269 – Support of AR types in the different DP-device types	433
Table 270 – Support of services at the different AREPs respectively CREPs	434

Table 271 – Conformance classes DP-master (class 1)	436
Table 272 – Conformance classes DP-master (class 2)	436

EVS

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1:2013.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This standard defines the application service characteristics that fieldbus applications and/or system management exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

EVS

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-3: Application layer service definition – Type 3 elements

1 Scope

1.1 General

This standard is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

This sub-part contains material specific to Type 3 fieldbus.

The fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 3 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the different Types of fieldbus Application Layer in terms of

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service;
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

- a) the FAL user at the boundary between the user and the Application Layer of the Fieldbus Reference Model; and
- b) Systems Management at the boundary between the Application Layer and Systems Management of the Fieldbus Reference Model.

This standard specifies the structure and services of the IEC fieldbus Application Layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI Application Layer Structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented Application Service Elements (ASEs) and a Layer Management Entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process