

Plastics piping systems for non-pressure underground drainage and sewerage - Structured-wall piping systems of unplasticized poly(vinyl chloride) (PVC-U), polypropylene (PP) and polyethylene (PE) - Part 1: General requirements and performance characteristics

Plastics piping systems for non-pressure underground drainage and sewerage - Structured-wall piping systems of unplasticized poly(vinyl chloride) (PVC-U), polypropylene (PP) and polyethylene (PE) - Part 1: General requirements and performance characteristics

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

<p>Käesolev Eesti standard EVS-EN 13476-1:2007 sisaldab Euroopa standardi EN 13476-1:2007 ingliskeelset teksti.</p> <p>Käesolev dokument on jõustatud 21.06.2007 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p>	<p>This Estonian standard EVS-EN 13476-1:2007 consists of the English text of the European standard EN 13476-1:2007.</p> <p>This document is endorsed on 21.06.2007 with the notification being published in the official publication of the Estonian national standardisation organisation.</p> <p>The standard is available from Estonian standardisation organisation.</p>
--	---

<p>Käsitlusala:</p> <p>This European Standard, together with EN 13476-2 and EN 13476-3, specifies the definitions and general requirements for pipes, fittings and the system based on unplasticized poly(vinyl chloride) (PVC-U), polypropylene (PP) and polyethylene (PE) structured-wall piping systems that are to be used for non-pressure underground drainage and sewerage systems.</p>	<p>Scope:</p> <p>This European Standard, together with EN 13476-2 and EN 13476-3, specifies the definitions and general requirements for pipes, fittings and the system based on unplasticized poly(vinyl chloride) (PVC-U), polypropylene (PP) and polyethylene (PE) structured-wall piping systems that are to be used for non-pressure underground drainage and sewerage systems.</p>
---	---

ICS 93.030

Võtmesõnad: non-pressure pipes, specifications, structured-wall piping, thermoplastics piping systems

English Version

Plastics piping systems for non-pressure underground drainage
and sewerage - Structured-wall piping systems of unplasticized
poly(vinyl chloride) (PVC-U), polypropylene (PP) and
polyethylene (PE) - Part 1: General requirements and
performance characteristics

Systèmes de canalisations en plastique pour les
branchements et les collecteurs d'assainissements sans
pression enterrés - Systèmes de canalisation à parois
structurées en poly(chlorure de vinyle) non plastifié (PVC-
U), polypropylène (PP) et polyéthylène (PE) - Partie 1:
Exigences générales et caractéristiques de performance

Kunststoff-Rohrleitungssysteme für erdverlegte drucklose
Abwasserkanäle und -leitungen - Rohrleitungssysteme mit
profilierter Wandung aus weichmacherfreiem
Polyvinylchlorid (PVC-U), Polypropylen (PP) und
Polyethylen (PE) - Teil 1: Allgemeine Anforderungen und
Leistungsmerkmale

This European Standard was approved by CEN on 5 March 2007.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents	Page
Foreword	4
Introduction	5
1 Scope	6
2 Normative references	6
3 Terms and definitions, symbols and abbreviations	7
3.1 Definitions	7
3.1.1 General definitions	7
3.1.2 Geometrical definitions	8
3.2 Symbols and abbreviations	9
4 Material	10
4.1 General	10
4.2 Utilisation of non-virgin material	10
4.3 Sealing ring retaining components	10
4.4 Sealing rings	10
4.5 Fused or welded joints	10
5 Designation of wall construction	10
6 Appearance and colour	10
6.1 Appearance	10
6.2 Colour	11
7 Geometrical characteristics	11
8 Types of fittings	11
8.1 General	11
8.2 Design length of fittings	14
9 System performance related test methods and characteristics	14
10 Marking, general	16
10.1 Presentation	16
10.2 Marking process	16
10.3 Size	16
Annex A (informative) Characteristics of PVC-U, PP and PE pipes and fittings	17
A.1 General	17
A.2 Material characteristics	17
A.3 Chemical resistance	17
A.4 Abrasion resistance	18
A.5 Hydraulic roughness	18
Annex B (informative) Structural design	19
B.1 General	19
B.2 Structural design based on practical experience	19
B.3 Structural design based on a design calculations	21
B.4 Selection of fitting stiffness or class	21
Annex C (informative) Designation of pipes and corresponding fittings	23
Annex D (informative) Guidance in cleaning plastics pipes	24
D.1 Introduction	24
D.2 Cleaning and unblocking	24

D.2.1	Choosing the right equipment	24
D.2.2	Comparing techniques	24
D.3	Conclusions from independent jetting tests	25
D.3.1	Assessing efficiency and impact	25
D.3.2	Testing of plastic pipes	25
D.3.3	Clearing tests	25
D.4	Supplementary cleaning techniques	26
D.5	Recommended practice principles for jetting	26
Bibliography		28

Foreword

This document (EN 13476-1:2007) has been prepared by Technical Committee CEN/TC 155 “Plastics piping systems and ducting systems”, the secretariat of which is held by NEN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2007, and conflicting national standards shall be withdrawn at the latest by November 2007.

This standard is a part of a System Standard for plastics piping systems of particular materials for specified applications. There are a number of such System Standards.

System Standards are based on the results of the work being undertaken in ISO/TC 138 “Plastics pipes, fittings and valves for the transport of fluids”, which is a Technical Committee of the International Organization for Standardization (ISO).

They are supported by separate standards on test methods to which references are made throughout the System Standard.

The System Standards are consistent with general standards on functional requirements and on recommended practice for installation.

EN 13476 consists of the following Parts under the general title Plastics piping systems for non-pressure underground drainage and sewerage — Structured-wall piping systems of unplasticized poly(vinyl chloride) (PVC-U), polypropylene (PP) and polyethylene (PE):

- *Part 1: General requirements and performance characteristics (this standard);*
- *Part 2: Specifications for pipes and fittings with smooth internal and external surface and the system, Type A;*
- *Part 3: Specifications for pipes and fittings with smooth internal and profiled external surface and the system, Type B;*
- *Part 4: Assessment of conformity (CEN/TS);*
- *Part 5: Guidance for installation (CEN/TS).¹*

For pipes and fittings which have conformed to the relevant national standard before May 2007, as shown by the manufacturer or by a certification body, the national standard may continue to be applied until May 2009.

National standards specifically for pipes and fittings for the transport of surface water are not considered to be conflicting with this standard and may thus be allowed to coexist.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

¹ The feasibility of this project is under study.

Introduction

Due to the variety in materials, pipe constructions, application areas and classes, several combinations are possible.

The purchaser or specifier may select between these possibilities by designating the pipe and fitting he or she prefers to use for each case, as described in Annex C, Designation of pipes and corresponding fittings, taking into account any particular requirements and relevant national regulations and installation practices or codes.

1 Scope

This European Standard, together with EN 13476-2 and EN 13476-3, specifies the definitions and general requirements for pipes, fittings and the system based on unplasticized poly(vinyl chloride) (PVC-U), polypropylene (PP) and polyethylene (PE) structured-wall piping systems that are to be used for non-pressure underground drainage and sewerage systems.

This standard is applicable to:

- a) structured-wall pipes and fittings, which are to be used buried in the ground outside a building structure only; reflected by the marking of products by "U";
- b) structured-wall pipes and fittings, which are to be used buried in ground both outside (application area code "U") and within a building structure (application area code "D"); reflected in the marking of products by "UD".

In conjunction with EN 13476-2 and EN 13476-3 it is applicable to structured-wall pipes and fittings with or without an integral socket with elastomeric ring seal joints, as well as welded and fused joints.

This part specifies general aspects and gives guidance concerning a national selection of requirement levels and classes where part 2 and part 3 of this standard provide options.

EN 13476-2 and EN 13476-3 specify material characteristics, dimensions and tolerances, test methods, test parameters and requirements for pipes with smooth internal and external surfaces, Type A, and pipes with smooth internal and profiled external surfaces, Type B.

This standard, together with EN 13476-2 and EN 13476-3, covers a range of pipe and fitting sizes, materials, pipe constructions, stiffness classes and tolerance classes and offers recommendations concerning colours.

NOTE 1 It is the responsibility of the purchaser or specifier to make the appropriate selections from these aspects, taking into account their particular requirements and any relevant national regulations and installation practices or codes.

NOTE 2 Pipes, fittings and other components conforming to any plastic product standards referred to in clause 2 can be used with pipes and fittings conforming to this standard, when they conform to the requirements for joint dimensions given in part 2 and part 3 of this standard and to the performance requirements given in Clause 9.

NOTE 3 For dimensions larger than DN 1200 OD/ID this document may serve as general guideline regarding appearance, colour, physical and mechanical characteristics as well as performance requirements.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 681-1, *Elastomeric seals — Materials requirements for pipe joint seals used in water and drainage applications — Part 1: Vulcanized rubber*

EN 681-2, *Elastomeric seals — Materials requirements for pipe joint seals used in water and drainage applications — Part 2: Thermoplastic elastomers*

EN 681-4, *Elastomeric seals — Materials requirements for pipe joint seals used in water and drainage applications — Part 4: Cast polyurethane sealing elements*

EN 13476-2:2007, *Plastics piping systems for non-pressure underground drainage and sewerage - Structured-wall piping systems of unplasticized poly(vinyl chloride) (PVC-U), polypropylene (PP) and polyethylene (PE) - Part 2: Specifications for pipes and fittings with smooth internal and external surface and the system, Type A*

EN 13476-3:2007, *Plastics piping systems for non-pressure underground drainage and sewerage - Structured-wall piping systems of unplasticized poly(vinyl chloride) (PVC-U), polypropylene (PP) and polyethylene (PE) - Part 3: Specifications for pipes and fittings with smooth internal and profiled external surface and the system, Type B*

EN ISO 472:2001, *Plastics — Vocabulary (ISO 472:1999)*

EN ISO 1043-1:2001, *Plastics - Symbols and abbreviated terms - Part 1: Basic polymers and their special characteristics (ISO 1043-1:2001)*

EN ISO 9969, *Thermoplastics pipes — Determination of ring stiffness (ISO 9969:1994)*

ISO 11922-1:1997, *Thermoplastics pipes for the conveyance of fluids — Dimensions and tolerances — Part 1: Metric series*

ISO 13967, *Thermoplastics fittings — Determination of ring stiffness*

3 Terms and definitions, symbols and abbreviations

For the purposes of this standard, the terms and definitions given in EN ISO 472:2001, EN ISO 1043-1:2001, ISO 11922-1:1997 and the following apply.

3.1 Definitions

3.1.1 General definitions

3.1.1.1

application area code

code used to mark pipes and fittings to indicate the permitted application area(s) for which they are intended, as follows:

U: code for the area more than 1 m from the building to which the buried piping system is connected;

D: code for the area under and within 1 m from the building where the pipes and fittings are buried underground and are connected to the soil and waste discharge system of the building

NOTE In the “D” application area, the existence of hot water discharge in addition to external forces from the surroundings is usual.

3.1.1.2

structured-wall pipes and fittings

products which have an optimised design with regard to material usage to achieve the physical, mechanical and performance requirements of this standard

NOTE For a description of the particular designs covered by this standard, see clause 5 in EN 13476-2:2007 and EN 13476-3:2007.

3.1.1.3

fabricated fitting

fitting manufactured by heat forming and/or joining more than one piece of pipe and/or moulded component

NOTE Sealed ring retaining components are not considered as a piece.