

Energy performance of buildings - Heating systems and
DHW in buildings - Part 1: Inspection of boilers, heating
systems and DHW, Module M3-11, M8-11

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 15378-1:2017 sisaldab Euroopa standardi EN 15378-1:2017 ingliskeelset teksti.	This Estonian standard EVS-EN 15378-1:2017 consists of the English text of the European standard EN 15378-1:2017.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 03.05.2017.	Date of Availability of the European standard is 03.05.2017.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 91.140.10

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:

Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

**Energy performance of buildings - Heating systems and
DHW in buildings - Part 1: Inspection of boilers, heating
systems and DHW, Module M3-11, M8-11**

Performance énergétique des bâtiments - Systèmes de
chauffage et production d'eau chaude sanitaire dans les
bâtiments - Partie 1 : Inspection des chaudières et des
systèmes de chauffage, Module M3-11, M8-11

Energetische Bewertung von Gebäuden -
Heizungsanlagen und Trinkwassererwärmung in
Gebäuden - Teil 1: Inspektion von Kesseln und
Heizungssystemen, Modul M3-1, M8-11

This European Standard was approved by CEN on 27 February 2017.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

European foreword.....	4
Introduction	5
1 Scope.....	8
2 Normative references.....	11
3 Terms and definitions	11
4 Symbols and subscripts	13
4.1 Symbols.....	13
4.2 Subscripts.....	13
5 Description of the method	13
5.1 Heat generator inspection.....	13
5.2 Heating system inspection.....	13
5.3 Inspection levels.....	14
5.4 Advice	14
5.5 Inspection report	14
6 Heat generator inspection procedure	15
6.1 Heat generator inspection level identification.....	15
6.2 Heat generator identification	15
6.3 Document identification.....	15
6.4 Heat generator visual inspection	15
6.5 Heat generator functionality check.....	15
6.6 Heat generator maintenance status	15
6.7 Heat generator controls, sensors and indicators	16
6.8 Meter readings	16
6.9 Heat generator performance evaluation.....	16
6.10 Heat generator inspection report and advice.....	17
6.10.1 Inspection report	17
6.10.2 Heat generator performance advice	17
7 Heating system inspection procedure.....	18
7.1 Heating system inspection level identification	18
7.2 Heating system inspection preparation.....	18
7.3 Heating system and inspection identification	18
7.4 Document collection and system identification.....	19
7.5 Heating system functionality check.....	19
7.6 Heating system maintenance status.....	19
7.7 Heating system central controls, sensors and indicators.....	19
7.8 Meter readings	20
7.9 Energyware consumption	20
7.9.1 General.....	20
7.9.2 Energyware consumption estimation.....	20
7.9.3 Reference values	20
7.9.4 Advice criteria on energyware consumption.....	21
7.10 Space heating emission subsystem.....	21
7.11 Space heating emission control subsystem	22
7.12 Space heating distribution subsystem.....	22

7.13	Generation subsystem	23
7.13.1	General	23
7.13.2	Heat generators identification.....	23
7.13.3	Heat generators inspection.....	23
7.13.4	Generation subsystem control inspection.....	27
7.14	Storage subsystem.....	27
7.15	Generation subsystem sizing.....	27
7.15.1	General	27
7.15.2	Heat power requirement	27
7.15.3	Boiler oversizing.....	28
7.15.4	Other generators sizing.....	28
7.15.5	Advice.....	28
7.16	Heating system global efficiency or rating	29
7.17	Domestic hot water systems.....	29
7.18	Heating system inspection report and advice.....	30
7.18.1	General	30
7.18.2	Inspection report layout	30
7.18.3	Heating system advice	30
Annex A (normative)	Template for the definition of inspection levels, choices, input data and references	32
Annex B (informative)	Default inspection levels definition, choices, input data and references.....	38
Annex C (informative)	Sample inspection report	64
Annex D (informative)	Heating system inspection flowchart	75
Annex E (informative)	List of possible improvement actions	77
Bibliography		81

European foreword

This document (EN 15378-1:2017) has been prepared by Technical Committee CEN/TC 228 “Heating systems and water based cooling systems in buildings”, the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2017, and conflicting national standards shall be withdrawn at the latest by November 2017.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 15378:2007.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

This European Standard is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings, called "set of EPB standards".

All EPB standards follow specific rules to ensure overall consistency, unambiguity and transparency.

All EPB standards provide a certain flexibility with regard to the methods, the required input data and references to other EPB standards, by the introduction of a normative template in Annex A and Annex B with informative default choices.

For the correct use of this standard, a normative template is given in Annex A to specify these choices. Informative default choices are provided in Annex B.

The main target group of this standard are all the users of the set of EPB standards (e.g. architects, engineers, regulators).

Use by or for regulators: In case the standard is used in the context of national or regional legal requirements, mandatory choices may be given at national or regional level for such specific applications. These choices (either the informative default choices from Annex B or choices adapted to national / regional needs, but in any case following the template of this Annex A) can be made available as national annex or as separate (e.g. legal) document (national data sheet).

NOTE So in this case:

- the regulators will specify the choices;
- the individual user will apply the standard to assess the energy performance of a building, and thereby use the choices made by the regulators.

Topics addressed in this standard can be subject to public regulation. Public regulation on the same topics can override the default values in Annex B of this standard. Public regulation on the same topics can even, for certain applications, override the use of this standard. Legal requirements and choices are in general not published in standards but in legal documents. In order to avoid double publications and difficult updating of double documents, a national annex may refer to the legal texts where national choices have been made by public authorities. Different national annexes or national data sheets are possible, for different applications.

It is expected, if the default values, choices and references to other EPB standards in Annex B are not followed due to national regulations, policy or traditions, that:

- national or regional authorities prepare data sheets containing the choices and national or regional values, according to the model in Annex A. In this case the national annex (e.g. NA) refers to this text;
- or, by default, the national standards body will consider the possibility to add or include a national annex in agreement with the template of Annex A, in accordance to the legal documents that give national or regional values and choices.

Further target groups are users of the voluntary common European Union certification scheme for the energy performance of non-residential buildings (EPBD art.11.9) and any other Pan EU parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock

More information is provided in the Technical Report accompanying this standard (CEN/TR 15378-2).

This document specifies procedures to be used for the inspection and assessment of energy performance and sizing of heat generators and accessible parts of heating systems to provide advice to

users on the replacement of heat generators, other modifications to the heating system and on alternative solutions as required by article 14 of Directive 2010/31/EU of the European Parliament and of the Council of 19 May 2010 on the energy performance of buildings (recast).

This standard includes, either in the normative text or in the informative annexes:

- inspection procedures;
- calculation procedures;
- sample reports;
- advice criteria.

Procedures and methodologies defined in this standard are not intended to provide a full energy audit of the heating system. They are intended to:

- support identification of areas of possible improvements;
- define criteria to produce reliable advice on possible improvements of the energy performance of heat generators and heating systems through replacement of components or other measures;
- support advice on the sizing of the boiler and heating system.

Any replacement of appliances or modification of the heating system following advice should be designed according to appropriate methodologies. This may require additional input and investigation for detailed design and final check of economical effectiveness.

Clauses 6 and 7 describe separately the inspection procedures related to:

- inspection of the heat generators;
- inspection of the entire heating systems

Clause 7 should be applied to comply with requirements of article 14 of Directive 2010/31/EU of the European Parliament.

This standard introduces inspection levels by which different levels of inspection accuracy and detailed inspection requirements can be determined, because:

- the same inspection procedure and level of details cannot reasonably be required for any kind and/or any size of heat generators and heating systems;
- there are currently significant differences among EU Member States with respect to:
 - heating systems typologies;
 - legal and/or standard requirements;
 - maintenance and inspection practices.

Alternative and/or optional partial inspection procedures and measurement methods for heat generators and heating system parts are described in the accompanying Technical Report.

Inclusion/omission/alternatives of individual inspection items as well as border lines between levels are specified through tables compiled according to the template given in normative Annex A. If no specific national specification is available, a default specification of inspection levels is given in informative Annex B. Specifications given nationally may refer either to methodologies given in the

accompanying technical report to this standard or to suitable existing national standards and procedures.

This standard has been drafted to support inspection required by Directive 2010/31/EU of the European Parliament and of the council of 19 May 2010 on the energy performance of buildings (recast) that is *“a regular inspection of the accessible parts of systems used for heating buildings, such as the heat generator, control system and circulation pump(s), with boilers of an effective rated output for space heating purposes of more than 20 kW”*.

This does not exclude the possibility to use this standard for other types of generation devices (e.g. warm air heaters, heat pumps, thermal solar, CHP, etc.) and to domestic hot water systems if appropriate additional levels are defined.

Detailed information on each clause of this standard, the rationale of the default and suggested choices and all other supporting information (such as examples) are included in CEN/TR 15378-2.

Default references to EPB standards other than EN ISO 52000-1 are identified by the EPB module code number and given in Annex A (normative template) and Annex B (informative default choice).

NOTE Example of EPB module code number: M5-5, or M5-5.1 (if module M5-5 is subdivided), or M5-5/1 (if reference to a specific clause of the standard covering M5-5).

1 Scope

This document specifies inspection procedures for the assessment of energy performance of existing boilers and heating systems.

Heat generators types covered by this standard are:

- boilers for heating, domestic hot water or both;
- gas, liquid, solid fuel fired combustion boilers;
- electrically driven and gas driven heat pumps;
- thermal solar systems for domestic hot water, heating or both;
- other heat generators types, such as cogeneration units.

Parts of heating systems covered by this standard are:

- heat generators, including generation control;
- heating distribution network, including associated components and controls;
- heating emitters, including components and controls;
- space heating control system;
- heat storage and associated components;
- domestic hot water production system.

This standard covers issues related to energy conservation and environmental performance.

Table 1 shows the relative position of this standard within the set of EPB standards in the context of the modular structure as set out in EN ISO 52000-1.

NOTE 1 In prCEN ISO/TR 52000-2 the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying technical reports that are published or in preparation.

NOTE 2 The modules represent EPB standards, although one EPB standard may cover more than one module and one module may be covered by more than one EPB standard, for instance a simplified and a detailed method respectively. See also Clause 2 and Tables A.1 and B.1.

Table 1 — Position of this standard within the modular structure of EPB standards

	Overarching		Building (as such)		Technical Building Systems									
Submodule	Descriptions		Descriptions		Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Domestic Hot water	Lighting	Building automation and control	Electricity production
sub1		M1		M2		M3	M4	M5	M6	M7	M8	M9	M10	M11
1	General		General		General	EN 15316-1					EN 15316-1			
2	Common terms and definitions; symbols, units and subscripts		Building Energy Needs		Needs						EN 12831-3			
3	Applications		(Free) Indoor Conditions without Systems		Maximum Load and Power	EN 12831-1					EN 12831-3			
4	Ways to Express Energy Performance		Ways to Express Energy Performance		Ways to Express Energy Performance	EN 15316-1					15316-1			
5	Building categories and Building Boundaries		Heat Transfer by Transmission		Emission and control	EN 15316-2	EN 15316-2							
6	Building Occupancy and Operating Conditions		Heat Transfer by Infiltration and Ventilation		Distribution and control	EN 15316-3	EN 15316-3				EN 15316-3			
7	Aggregation of Energy Services and Energy Carriers		Internal Heat Gains		Storage and control	EN 15316-5					EN 15316-5 EN 15316-4-3			
8	Building zoning		Solar Heat Gains		Generation									
8-1					Combustion boilers	EN 15316-4-1					EN 15316-4-1			
8-2					Heat pumps	EN 15316-4-2	EN 15316-4-2				EN 15316-4-2			
8-3					Thermal solar Photovoltaics	EN 15316-4-3					EN 15316-4-3			EN 15316-4-3
8-4					On-site cogeneration	EN 15316-4-4					EN 15316-4-4			EN 15316-4-4

8-5				District heating and cooling	EN 15316-4-5	EN 15316-4-5							EN 15316-4-5
8-6				Direct electrical heater	EN 15316-4-8					EN 15316-4-8			
8-7				Wind turbines									EN 15316-4-10
8-8				Radiant heating, stoves	EN 15316-4-8								
9	Calculated Energy Performance		Building Dynamics (thermal mass)	Load dispatching and operating conditions									
10	Measured Energy Performance		Measured Energy Performance	Measured Energy Performance	EN 15378-3					EN 15378-3			
11	Inspection		Inspection	Inspection	EN 15378-1					EN 15378-1			
12	Ways to Express Indoor Comfort			BMS									
13	External Environment Conditions												
14	Economic Calculation	EN 15459-1											
NOTE The shaded modules are not applicable													

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN ISO 7345:1995, *Thermal insulation - Physical quantities and definitions (ISO 7345:1987)*

EN ISO 52000-1:2017, *Energy performance of buildings — Overarching EPB assessment – Part 1: General framework and procedures*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN ISO 7345:1995, EN ISO 52000-1:2017 and the following definitions apply.

NOTE The terms of EN ISO 52000-1 that are indispensable for the understanding of the underlying standard are repeated here.

3.1

boiler

gas, liquid or solid fuelled appliance designed to provide hot water for space heating

Note 1 to entry: A boiler may (but need not) be used to provide heat for domestic hot water heating as well.

3.2

thermal input

product of the fuel flow rate and the net calorific value of the fuel

3.3

condensing boiler

boiler that, under normal operating conditions and at certain operating water temperatures, partially condenses the water vapour in the combustion products in order to make use of the latent heat of water vapour for heating purposes

Note 1 to entry: Boilers not so designed, or without the means to remove the condensate in liquid form are called 'non-condensing'.

[SOURCE: EN 15502-1 and EN 15034, modified]

3.4

multistage boiler

boiler with the capability to vary the fuel burning rate stepwise whilst maintaining continuous burner firing

3.5

modulating boiler

boiler with the capability to vary continuously (from a set minimum to a set maximum) the fuel burning rate whilst maintaining continuous burner firing