Coil coated metals - Test methods - Part 2: Specular gloss

Coil coated metals - Test methods - Part 2: Specular gloss



EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 13523-2:2001 sisaldab Euroopa standardi EN 13523-2:2001 ingliskeelset teksti.

Käesolev dokument on jõustatud 18.06.2001 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 13523-2:2001 consists of the English text of the European standard EN 13523-2:2001.

This document is endorsed on 18.06.2001 with the notification being published in the official publication of the Estonian national standardisation organisation.

The standard is available from Estonian standardisation organisation.

Käsitlusala:

This Part of EN 13523specifies the procedure for determining the specular gloss of an organic coating on a metallic substrate. Gloss is a characteristic of fundamental importance to the appearance of the coil coated product.

Scope:

This Part of EN 13523 specifies the procedure for determining the specular gloss of an organic coating on a metallic substrate. Gloss is a characteristic of fundamental importance to the appearance of the coil coated product.

ICS 17.180.20, 25.220.60

Võtmesõnad: coating materials, coatings, definitions, general section, gloss, gloss (of surface), metal coating, paints, reflectometer reading, specification (approval), specifications, testing

EUROPEAN STANDARD NORME EUROPÉENNE EUROPÄISCHE NORM

EN 13523-2

January 2001

ICS 17.180.20; 25.220.60

English version

Coil coated metals - Test methods

Part 2: Specular gloss

Partie 2: Brillant spéculaire

Tôles prélaquées - Méthodes d'essai - Bandbeschichtete Metalle - Prüfverfahren - Teil 2: Glanz

This European Standard was approved by CEN on 2000-12-30.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

The European Standards exist in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, the Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, the Netherlands, Norway, Portugal, Spain, Sweden, Switzerland, and the United Kingdom.

European Committee for Standardization Comité Européen de Normalisation Europäisches Komitee für Normung

Management Centre: rue de Stassart 36, B-1050 Brussels

EN 13523-2:2001

Foreword

This European Standard has been prepared by Technical Committee CEN/TC 139 "Paints and varnishes", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by July 2001, and conflicting national standards shall be withdrawn at the latest by July 2001.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This Part of EN 13523 specifies the procedure for determining the specular gloss of an organic coating on a metallic substrate. Gloss is a characteristic of fundamental importance to the appearance of the coil coated product.

The apparatus requires a flat specimen of size greater than the aperture, thus, uneven surfaces cannot be measured.

This method is applicable to all pigmented and unpigmented coatings including metallic/pearlescent coatings. However, for textured coatings it is only indicative.

2 Normative references

This European Standard incorporates, by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

EN 13523-0:2001

Coil coated metals - Test methods - Part 0: General introduction and list of test methods

EN 23270:1991

Paints and varnishes and their raw materials - Temperatures and humidities for conditioning and testing (ISO 3270:1984)

EN ISO 2813

Paints and varnishes - Determination of specular gloss of non-metallic paint films at 20°, 60° and 85° (ISO 2813:1994, including Technical Corrigendum 1:1997)

3 Terms and definitions

For the purposes of EN 13523-2:2001 the terms and definitions given in EN 13523-0:2001 as well as the following terms and definitions apply:

3.1 gloss

optical property of a surface, characterized by its ability to reflect light specularly. [EN 971-1: 1996]

3.2

specular gloss

ratio of the luminous flux reflected from an object in the specular direction for a specified source and receptor angle to the luminous flux reflected from glass with a refractive index of 1,567 in the specular direction.

NOTE: To define the specular-gloss scale, polished black glass with a refractive index of 1,567 is assigned the value of 100 for geometries 20°, 60° and 85°. [EN ISO 2813]

4 Principle

The gloss of the organic coating is determined by measuring the specular reflectance. The angle of incident light is usually 60°, but angles of 20° or 85° can be used for more accurate measurement of high or low gloss values.

5 Apparatus

Ordinary laboratory apparatus, together with the following: