

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Mobile and fixed offshore units – Electrical installations –
Part 7: Hazardous areas**

**Unités mobiles et fixes en mer – Installations électriques –
Partie 7: Emplacements dangereux**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2014 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 14 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 55 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 14 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 55 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Mobile and fixed offshore units – Electrical installations –
Part 7: Hazardous areas**

**Unités mobiles et fixes en mer – Installations électriques –
Partie 7: Emplacements dangereux**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

ICS 47.020.60

ISBN 978-2-8322-1986-7

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	8
INTRODUCTION.....	10
1 Scope.....	11
2 Normative references	11
3 Terms and definitions	13
4 Area classification	20
4.1 General.....	20
4.2 Safety principles	20
4.3 Sources of release	21
4.4 Type of zone.....	22
4.5 Relative density of the gas or vapour when it is released	22
4.6 Mobile drilling units.....	22
4.6.1 General	22
4.6.2 Zone 0	23
4.6.3 Zone 1	23
4.6.4 Zone 2	23
4.6.5 Well test facilities	23
4.7 Fixed units	24
4.7.1 General	24
4.7.2 Zone 0	24
4.7.3 Zone 1	24
4.7.4 Zone 2	24
4.7.5 Drilling facilities	24
4.8 Floating production units.....	24
4.9 Provisions regarding all types of offshore units (floating, mobile and fixed units)	25
4.10 Openings, access and ventilation conditions affecting the extent of hazardous areas	25
4.10.1 General	25
4.10.2 Enclosed space with direct access to any zone 1 location.....	25
4.10.3 Enclosed space with direct access to any zone 2 location.....	25
4.10.4 Warning notices.....	26
5 Electrical systems.....	26
5.1 Sources of electrical power	26
5.2 Distribution systems.....	26
5.2.1 General	26
5.2.2 Earth fault detection	26
5.3 Electrical protection	26
5.4 Emergency conditions due to drilling operations – Mobile drilling units.....	27
5.5 Emergency switch-off – Ignition source control –Production units	28
5.5.1 General	28
5.5.2 Low gas alarm	28
5.5.3 High gas alarm	29
5.5.4 Manual disconnection	29
6 Protection from dangerous (incendive) sparking	29
6.1 General.....	29
6.2 Light metal as construction materials	29

6.3	Dangers from live parts	29
6.4	Dangers from exposed and extraneous conductive parts	29
6.4.1	General	29
6.4.2	System with earthed neutral	30
6.4.3	System with isolated or impedance earthed neutral	30
6.4.4	Systems in zone 0	30
6.4.5	SELV and PELV systems	30
6.4.6	Electrical separation	30
6.4.7	Non Ex electrical equipment above hazardous areas	30
6.5	Potential equalization	31
6.5.1	General	31
6.5.2	Temporary bonding	31
6.6	Static electricity	32
6.7	Cathodically protected metallic parts	32
6.8	Electromagnetic radiation	32
6.9	Danger from mechanical parts	32
7	Assurance of conformity of equipment	33
7.1	Equipment with certificates according to IEC standards	33
7.1.1	General	33
7.1.2	IEC standards	33
7.1.3	Equipment without certificates according to IEC standards	33
7.2	Selection of repaired, second hand or existing equipment	33
7.3	Qualifications of personnel	33
8	Selection of equipment (excluding cables and conduits)	34
8.1	General	34
8.2	Information requirements	34
8.3	Zones	34
8.4	Relationship between equipment protection levels (EPLs) and zones	34
8.5	Selection of equipment according to EPLs	34
8.5.1	General	34
8.5.2	Relationship between EPLs and types of protection	35
8.5.3	Equipment for use in locations requiring EPL 'Ga'	35
8.5.4	Equipment for use in locations requiring EPL 'Gb'	35
8.5.5	Equipment for use in locations requiring EPL 'Gc'	36
8.6	Selection according to equipment grouping	36
8.7	Selection according to the ignition temperature of the gas or vapour and ambient temperature	36
8.7.1	General	36
8.7.2	Gas or vapour	37
8.8	Selection of radiating equipment	37
8.9	Selection of ultrasonic equipment	37
8.10	Selection to cover external influences	37
8.11	Selection of transportable, portable and personal equipment	38
8.11.1	Transportable and portable equipment	38
8.11.2	Personal equipment	38
8.12	RFID tags	39
9	Cable system – General	39
9.1	Cables	39
9.2	Connections	39

9.3	Jointing	40
9.4	Cable system	40
9.4.1	Construction	40
9.4.2	Earthing of metallic covering	40
9.5	Conduit systems	40
9.6	Cable and conduit systems	41
9.6.1	Zone 0, EPL 'Ga'	41
9.6.2	Cable and conduit systems for zone 1 and 2, EPL, 'Gb' and 'Gc'	41
9.7	Installation requirements	42
9.7.1	Circuits traversing a hazardous area	42
9.7.2	Terminations	42
9.7.3	Unused cores	42
10	Cable entry systems and blanking elements	42
10.1	General	42
10.2	Connections of cables to equipment	42
10.3	Selection of cable glands	43
10.4	Additional entries other than Ex 'd' or Ex 'nR'	44
10.5	Unused openings	44
10.6	Additional requirements for type of protection 'd' – Flameproof enclosures	44
10.6.1	General	44
10.6.2	Selection of cable glands	45
10.7	Additional requirements for type of protection 'nR' – Restricted breathing enclosure	45
11	Rotating electrical machines	45
11.1	Type of protection 'd' – Flameproof enclosures	45
11.2	Type of protection 'e' – Increased safety	45
11.3	Type of protection 'p' – Pressurized enclosures	45
11.4	Type of protection 'nA' – Non-sparking	45
11.5	Ex protected permanent magnet motor	46
12	Electric heating systems	46
12.1	General	46
12.2	Temperature monitoring	46
12.3	Limiting temperature	46
12.4	Safety device	46
12.5	Electrical trace heating systems	47
13	Additional requirements for type of protection 'd' – Flameproof enclosures	47
13.1	General	47
13.2	Solid obstacles	48
13.3	Protection of flameproof joints	48
13.4	Conduit systems	49
14	Additional requirements for type of protection 'e' – Increased safety	49
14.1	General	49
14.2	Maximum dissipated power of terminal box enclosures	49
14.3	Conductor terminations	50
14.4	Maximum number of conductors in relation to the cross-section and the permissible continuous current	50
15	Additional requirements for type of protection 'i' – Intrinsic safety	50
15.1	Introductory remark	50
15.2	Earthing of intrinsically safe circuits	51

15.3	Earthing of conducting screens	52
15.4	Cable braid bonding.....	52
15.5	Verification of intrinsically safe circuits.....	52
15.6	Simple apparatus	52
16	Additional requirements for pressurized enclosures	53
16.1	General.....	53
16.2	Type of protection 'p'.....	53
16.2.1	General	53
16.2.2	Ducting	54
16.2.3	Action to be taken on failure of pressurization	54
16.2.4	Multiple pressurized enclosures with a common safety device	56
16.2.5	Purging.....	57
16.2.6	Protective gas.....	57
17	Pressurized rooms.....	57
17.1	General.....	57
17.2	Doors.....	58
17.3	Inlets and outlets	58
17.4	Clean air supply	58
17.4.1	Source of clean air	58
17.4.2	Minimum flow rate	58
17.5	Purging.....	58
17.5.1	General	58
17.5.2	Sequence of operations of the purging safety devices	59
17.5.3	Enclosures within the room.....	59
17.6	Safety devices	59
17.6.1	General	59
17.6.2	Safety devices based on type of protection	60
17.7	Failure of the pressurization system.....	60
17.8	Pressurized room in a hazardous area	60
17.8.1	General	60
17.8.2	Preventing the explosive atmosphere from entering an open door	60
17.9	Gas detection	61
17.10	Action when pressurization system fails	61
17.10.1	Type of protection 'px'.....	61
17.10.2	Type of protection 'py'.....	61
17.10.3	Re-energizing the room	62
17.11	Marking.....	62
18	Analyser houses	62
19	Additional requirements for type of protection 'n'	62
20	Additional requirements for type of protection 'o' – Oil immersion	63
21	Additional requirements for type of protection 'q' – Powder filling.....	63
22	Additional requirements for type of protection 'm' – Encapsulation.....	63
23	Additional requirements for type of protection 'op' – Optical radiation	63
24	Ventilation	63
24.1	General.....	63
24.2	Ventilation of spaces containing electrical apparatus	64
24.3	Ventilation of other hazardous spaces.....	64
25	Ventilation requirements for battery compartments	64

25.1	General.....	64
25.2	Ventilation requirements	64
25.3	Natural ventilation	66
25.4	Forced ventilation	67
25.5	Fans and ducts	67
26	Inspection, maintenance, repair and overhaul.....	67
26.1	Initial inspection.....	67
26.2	In-service inspection	67
26.3	Isolation of apparatus	68
26.4	Precautions concerning the use of ignition sources	68
26.5	Repair and overhaul.....	68
26.6	Personnel qualifications	68
27	Documentation	68
Annex A (informative)	Examples of sources of release – Process plant.....	71
A.1	General.....	71
A.2	Sources giving a continuous grade of release	71
A.3	Sources giving a primary grade of release	71
A.4	Sources giving a secondary grade of release	71
Annex B (informative)	Schematic approach to the classification of hazardous areas	72
Annex C (informative)	Hazardous area data sheets and symbols	74
C.1	Hazardous area classification data sheet	74
C.2	Symbols for hazardous area classification drawings.....	74
Annex D (informative)	Introduction of an alternative risk assessment method encompassing equipment protection levels for Ex equipment	78
D.1	General.....	78
D.2	Historical background	78
D.3	Risk assessment.....	79
D.3.1	Gases (Group II).....	79
D.3.2	EPL 'Ga'	79
D.3.3	EPL 'Gb'	79
D.3.4	EPL 'Gc'	79
D.4	Risk of ignition protection afforded.....	79
Annex E (informative)	Electrical installations in extremely low ambient temperature	81
E.1	General.....	81
E.2	Cables	81
E.3	Electrical trace heating systems.....	81
E.4	Lighting systems	81
E.4.1	General	81
E.4.2	Emergency lights	81
E.5	Electrical rotating machines	81
E.6	Explosion protected equipment	81
Annex F (informative)	Installation in explosive atmospheres – Safety signs and plates for hazardous areas	83
F.1	Objectives.....	83
F.2	General.....	83
Bibliography		85

Figure B.1 – Schematic approach to the classification of hazardous areas	73
--	----

Figure C.1 – Preferred symbols for hazardous area zones	77
Figure F.1 – Examples of an “Ex” safety warning sign for hazardous area installation	84
Table 1 – Electrical protection.....	26
Table 2 – Equipment protection levels (EPLs) where only zones are assigned	34
Table 3 – Relationship between types of protection and EPLs	35
Table 4 – Relationship between gas/vapour subdivision and equipment group	36
Table 5 – Relationship between gas or vapour ignition temperature and temperature class of equipment.....	37
Table 6 – Selection of glands, adapters and blanking elements type of protection according to the enclosure type of protection	43
Table 7 – Minimum distance of obstruction from the flameproof flange joints related to the gas group of the hazardous area.....	48
Table 8 – Determination of type of protection (with no flammable release within the enclosure).....	53
Table 9 – Use of spark and particle barriers.....	54
Table 10 – Summary of protection requirements for enclosures without an internal source of release	55
Table 11 – Required safety devices for each type of protection.....	60
Table 12 – Values for current I when charging with IU or U charging profiles	65
Table C.1 – Hazardous area classification data sheet – Part I: Flammable material list and characteristics – Sheet: 1/1	75
Table C.2 – Hazardous area classification data sheet – Part II: List of sources of release – Sheet: 1/1.....	76
Table D.1 – Traditional relationship of EPLs to zones (no additional risk assessment)	79
Table D.2 – Description of ignition protection provided	80

generated by EVS

INTERNATIONAL ELECTROTECHNICAL COMMISSION

MOBILE AND FIXED OFFSHORE UNITS – ELECTRICAL INSTALLATIONS –

Part 7: Hazardous areas

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61892-7 has been prepared by IEC technical committee 18: Electrical installations of ships and of mobile and fixed offshore units.

This third edition cancels and replaces the second edition published in 2007. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition.

- a) The EPL (Explosion Protection Level) concept has been introduced.
- b) The requirements to installations in hazardous area has been rewritten, based on the requirements of IEC 60079-14:2013.

The text of this standard is based on the following documents:

FDIS	Report on voting
18/1432/FDIS	18/1446/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61892 series, under the general title *Mobile and fixed offshore units – Electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 61892 forms a series of International Standards intended to ensure safety in the design, selection, installation, maintenance and use of electrical equipment for the generation, storage, distribution and utilization of electrical energy for all purposes in offshore units which are used for the exploration or production of petroleum resources.

This part of IEC 61892 also incorporates and co-ordinates, as far as possible, existing rules. It forms a code of interpretation, where applicable, of the requirements laid down by the International Maritime Organization, and constitutes a guide for future regulations which may be prepared and a statement of practice for offshore unit owners, constructors and appropriate organizations.

IEC 60079-14 has been used as reference document. Clauses related to gas, vapour and liquid have been used, where suitable, for offshore purposes. Additional text is added to meet offshore requirements.

This standard is based on equipment and practices which are in current use, but it is not intended in any way to impede development of new or improved techniques.

The ultimate aim has been to produce a set of International Standards exclusively for the offshore petroleum industry.

MOBILE AND FIXED OFFSHORE UNITS – ELECTRICAL INSTALLATIONS –

Part 7: Hazardous areas

1 Scope

This part of IEC 61892 contains provisions for hazardous areas classification and choice of electrical installation in hazardous areas in mobile and fixed offshore units, including pipelines, pumping or 'pigging' stations, compressor stations and exposed location single buoy moorings, used in the offshore petroleum industry for drilling, processing and for storage purposes.

It applies to all installations, whether permanent, temporary, transportable or hand-held, to AC installations up to and including 35 000 V and DC installations up to and including 1 500 V. (AC and DC voltages are nominal values).

This standard does not apply to electrical installations in rooms used for medical purposes, or in tankers.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0:2011, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-1, *Explosive atmospheres – Part 1: Equipment protection by flameproof enclosures “d”*

IEC 60079-2, *Explosive atmospheres – Part 2: Equipment protection by pressurized enclosure “p”*

IEC 60079-5, *Explosive atmospheres – Part 5: Equipment protection by powder filling “q”*

IEC 60079-6, *Explosive atmospheres – Part 6: Equipment protection by oil immersion “o”*

IEC 60079-7, *Explosive atmospheres – Part 7: Equipment protection by increased safety “e”*

IEC 60079-10-1, *Explosive atmospheres – Part 10-1: Classification of areas – Explosive gas atmospheres*

IEC 60079-11, *Explosive atmospheres – Part 11: Equipment protection by intrinsic safety “i”*

IEC 60079-13, *Explosive atmospheres – Part 13: Equipment protection by pressurized room “p”*

IEC 60079-14:2013, *Explosive atmospheres – Part 14: Electrical installations design, selection and erection*

IEC 60079-15, *Explosive atmospheres – Part 15: Equipment protection by type of protection "n"*

IEC TR 60079-16, *Electrical apparatus for explosive gas atmospheres – Part 16: Artificial ventilation for the protection of analyser(s) houses*

IEC 60079-17, *Explosive atmospheres – Part 17: Electrical installations inspection and maintenance*

IEC 60079-18, *Explosive atmospheres – Part 18: Equipment protection by encapsulation "m"*

IEC 60079-19, *Explosive atmospheres – Part 19: Equipment repair, overhaul and reclamation*

IEC 60079-25, *Explosive atmospheres – Part 25: Intrinsically safe electrical systems*

IEC 60079-26, *Explosive atmospheres – Part 26: Equipment with equipment protection level (EPL) Ga*

IEC 60079-28, *Explosive atmospheres – Part 28: Protection of equipment and transmission systems using optical radiation*

IEC 60079-29 (all parts), *Explosive atmospheres – Part 29: Gas detectors*

IEC 60079-30-2, *Explosive atmospheres – Part 30-2: Electrical resistance trace heating – Application guide for design, installation and maintenance*

IEC 60079-33, *Explosive atmospheres – Part 33: Equipment protection by special protection "s"*

IEC 60364-4-41:2005, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

IEC 61008-1, *Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs) – Part 1: General rules*

IEC 61285, *Industrial-process control – Safety of analyser houses*

IEC 61558-2-6, *Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers*

IEC 61892-2, *Mobile and fixed offshore units – Electrical installations – Part 2: System design*

IEC 61892-3, *Mobile and fixed offshore units – Electrical installations – Part 3: Equipment*

IEC 61892-4, *Mobile and fixed offshore units – Electrical installations – Part 4: Cables*

IEC 61892-6, *Mobile and fixed offshore units – Electrical installations – Part 6: Installation*

IEC 62485-2:2010, *Safety requirements for secondary batteries and battery installations – Part 2: Stationary batteries*

IEC/ISO 80079 (all parts), *Explosive atmospheres*

IMO MODU code, *Code for the construction and equipment of mobile offshore drilling units*