

Fire resistance tests for service installations - Part 4: Linear joint seals

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 1366-4:2006+A1:2010 sisaldab Euroopa standardi EN 1366-4:2006+A1:2010 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 30.06.2010 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 14.04.2010.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 1366-4:2006+A1:2010 consists of the English text of the European standard EN 1366-4:2006+A1:2010.

This standard is ratified with the order of Estonian Centre for Standardisation dated 30.06.2010 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 14.04.2010.

The standard is available from Estonian standardisation organisation.

ICS 13.220.50

Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:
Aru 10 Tallinn 10317 Eesti; www.evs.ee; Telefon: 605 5050; E-post: info@evs.ee

Right to reproduce and distribute Estonian Standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:
Aru str 10 Tallinn 10317 Estonia; www.evs.ee; Phone: +372 605 5050; E-mail: info@evs.ee

English Version

**Fire resistance tests for service installations - Part 4: Linear joint
seals**

Essai de résistance au feu des installations de service -
Partie 4: Calfeutrements de joints linéaires

Feuerwiderstandsprüfungen für Installationen - Teil 4:
Abdichtungssysteme für Bauteilfugen

This European Standard was approved by CEN on 17 April 2006 and includes Amendment 1 approved by CEN on 4 March 2010.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

Foreword.....	4
Introduction	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	7
4 Test equipment	8
5 Test conditions	8
5.1 Heating conditions.....	8
5.2 Pressure conditions	8
6 Test specimen	8
6.1 General.....	8
6.2 Size	9
6.3 Number of test specimens	9
7 Installation of test specimen	9
7.1 General.....	9
7.2 Supporting construction	9
7.2.1 General.....	9
7.2.2 Standard supporting construction.....	9
7.3 Test construction.....	10
7.4 Splice locations.....	10
7.5 Induced movement	11
8 Conditioning.....	11
9 Application of instrumentation.....	11
9.1 General.....	11
9.2 Thermocouples	11
9.2.1 Furnace thermocouples	11
9.2.2 Unexposed face thermocouples	11
9.2.3 Roving thermocouple.....	12
9.3 Deformation and deflection	12
9.4 Integrity measurement	12
10 Test procedure	12
10.1 General.....	12
10.2 Installation of test construction	12
10.3 Mechanically induced movement of the test specimen.....	12
10.4 Measurements and observations.....	12
11 Performance criteria	13
11.1 Insulation	13
11.2 Integrity	13
11.3 Expression of results	13
12 Test report	13
13 Field of direct application of test results	13
13.1 Orientation	13
13.2 Supporting construction	14
13.3 Seal position.....	15
13.4 Mechanically induced movement.....	15

Annex A (normative) Standard condition for linear joint seals with no mechanically induced movement of the joint faces	28
A.1 Standard condition	28
A.2 Test procedure	28
Annex B (normative) Standard condition for linear joint seals with mechanically induced movement of the joint faces	29
B.1 General	29
B.2 Standard condition(s)	29
B.2.1 Standard conditions for lateral movement	29
B.2.2 Standard condition for shear movement	30
B.3 Conditions for other movements	30
Annex C (informative) Guidance on the use of this European Standard	33
C.1 General	33
C.2 Application of the test	33
C.3 Test conditions	33
C.4 Specimen preparation	34
C.5 Notes on general performance criteria	34
C.6 Notes on validity of test results	34
C.7 Notes on Annex B	34

Foreword

This European Standard (EN 1366-4:2006+A1:2010) has been prepared by Technical Committee CEN/TC 127 "Fire safety in buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by October 2010, and conflicting national standards shall be withdrawn at the latest by October 2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1366-4:2006.

This document includes Amendment 1, approved by CEN on 2010-03-04.

The start and finish of text introduced or altered by amendment is indicated in the text by tags **A1** **A1**.

This European Standard has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of the Construction Products Directive.

EN 1366 'Fire resistance tests for service installations' consists of the following Parts:

- Part 1: Ducts
- Part 2: Fire dampers
- Part 3: Penetration seals
- Part 4: Linear joint seals
- Part 5: Service ducts and shafts
- Part 6: Raised access and hollow core floors
- Part 7: Conveyor systems and their closures
- Part 8: Smoke extraction ducts
- Part 9: Single compartment smoke extraction ducts
- Part 10: Smoke control dampers
- Part 11: Fire protection system for essential services (in course of preparation)¹⁾

¹⁾ To be published.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

This document is a preview generated by EVS

Introduction

Linear joint seals are positioned in joints, voids, gaps or other discontinuities within one or between two or more construction elements.

Normally such openings are denoted as linear because their length is greater than their width - defined by a typical ratio of at least 10:1 in practice.

Joints are present in buildings due to the following:

- a) acceptable dimensional tolerances between two or more building elements, e.g. between non-load bearing walls and floors;
- b) by design to accommodate various movements induced by thermal differentials, seismicity and movement induced by wind loads;
- c) as a result of inadequate design, inaccurate assembly, repairs or damage to the building.

The purpose of the tests in this European Standard is to assess:

- d) the effect of a linear joint seal on the integrity and insulation of the construction;
- e) the integrity and insulation performance of the linear joint seal;
- f) the effect of movement within the supporting construction on the fire performance of linear joint seals (see Annex B).

The results of these tests are one factor in assessing the fire performance of joint seals.

Annex A describes the principles of standard conditions for linear joint seals where no mechanically induced relative movement occurs between the joint faces.

Annex B provides standard conditions for joints with mechanically induced movement of opposing joint faces during the fire resistance test.

CAUTION The attention of all persons concerned with managing and carrying out this fire resistance test is drawn to the fact that fire testing may be hazardous and that there is a possibility that toxic and/or harmful smoke and gases may be evolved during the test. Mechanical and operational hazards may also arise during the construction of the test elements or structures, during their testing and during the disposal of test residues.

An assessment of all potential hazards and risks to health should be made and safety precautions should be identified and provided. Written safety instructions should be issued. Appropriate training should be given to relevant personnel. Laboratory personnel should ensure that they follow written safety instructions at all times.

1 Scope

This European Standard specifies a method for determining the fire resistance of linear joint seals based on their intended end use. This European Standard is used in conjunction with EN 1363-1.

The following tests are included in this European Standard:

- no mechanically induced movement;
- mechanically induced movement, either prior to or during fire exposure.

This European Standard does not provide quantitative information on the rate of leakage of smoke and/or hot gases, or on the transmission or generation of fumes.

The load-bearing capacity of a linear joint seal is not addressed in this European Standard.

2 Normative references

The following referenced documents are indispensable for the application of this European Standard. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1:1999, *Fire resistance tests — Part 1: General requirements*

EN 1363-2, *Fire resistance tests — Part 2: Alternative and additional procedures*

EN ISO 13943:2000, *Fire safety — Vocabulary (ISO 13943:2000)*

3 Terms and definitions

For the purposes of this European Standard, the terms and definitions given in EN 1363-1:1999 and EN ISO 13943:2000 and the following apply.

3.1

linear joint

linear void having a length to width ratio of at least 10:1 within one or between two or more juxtaposed construction elements

NOTE Typical locations of linear joints include floors, the perimeter of floors, walls, ceilings and roofs.

3.2

linear joint seal

system designed to maintain the fire separating function and, if relevant, to accommodate a specified degree of movement within the linear joint

3.3

movement capability

maximum amount of movement the joint seal is able to tolerate as stated by the manufacturer or the sponsor, expressed as a percentage of the nominal width

NOTE The movement capability is usually the same over the entire range of the nominal widths.

3.4

nominal joint width

specified width of a joint seal, to be selected by the manufacturer or test sponsor