

**Fire resistance tests for service installations - Part 5:  
Service ducts and shafts**

This document is a preview generated by EVS

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 1366-5:2010 sisaldab Euroopa standardi EN 1366-5:2010 ingliskeelset teksti.

Standard on kinnitatud Eesti Standardikeskuse 31.03.2010 käskkirjaga ja jõustub sellekohase teate avaldamisel EVS Teatajas.

Euroopa standardimisorganisatsioonide poolt rahvuslikele liikmetele Euroopa standardi teksti kättesaadavaks tegemise kuupäev on 03.03.2010.

Standard on kättesaadav Eesti standardiorganisatsioonist.

This Estonian standard EVS-EN 1366-5:2010 consists of the English text of the European standard EN 1366-5:2010.

This standard is ratified with the order of Estonian Centre for Standardisation dated 31.03.2010 and is endorsed with the notification published in the official bulletin of the Estonian national standardisation organisation.

Date of Availability of the European standard text 03.03.2010.

The standard is available from Estonian standardisation organisation.

ICS 13.220.50, 91.060.40

### Standardite reprodutseerimis- ja levitamiseõigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonilisse süsteemi või edastamine ükskõik millises vormis või millisel teel on keelatud ilma Eesti Standardikeskuse poolt antud kirjaliku loata.

Kui Teil on küsimusi standardite autorikaitse kohta, palun võtke ühendust Eesti Standardikeskusega:  
Aru 10 Tallinn 10317 Eesti; [www.evs.ee](http://www.evs.ee); Telefon: 605 5050; E-post: [info@evs.ee](mailto:info@evs.ee)

### Right to reproduce and distribute Estonian Standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without permission in writing from Estonian Centre for Standardisation.

If you have any questions about standards copyright, please contact Estonian Centre for Standardisation:  
Aru str 10 Tallinn 10317 Estonia; [www.evs.ee](http://www.evs.ee); Phone: +372 605 5050; E-mail: [info@evs.ee](mailto:info@evs.ee)

English Version

## Fire resistance tests for service installations - Part 5: Service ducts and shafts

Essais de résistance au feu des installations de service -  
Partie 5: Gaines pour installation technique

Feuerwiderstandsprüfungen für Installationen - Teil 5:  
Installationskanäle und -schächte

This European Standard was approved by CEN on 23 January 2010.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION  
COMITÉ EUROPÉEN DE NORMALISATION  
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

# Contents

Page

Foreword.....	4
Introduction .....	5
1 Scope .....	6
2 Normative references .....	6
3 Terms and definitions .....	6
4 Test equipment .....	7
4.1 General.....	7
4.2 Furnace.....	7
4.3 Loading equipment.....	7
4.4 Gas extraction equipment (optional) .....	7
5 Test conditions .....	7
5.1 Furnace .....	7
5.2 Loading .....	7
6 Test specimen .....	8
6.1 Size .....	8
6.1.1 General.....	8
6.1.2 Length .....	8
6.1.3 Cross-section .....	8
6.2 Number .....	8
6.3 Design .....	8
6.3.1 General.....	8
6.3.2 Duct and shaft arrangement.....	9
7 Installation of test specimen .....	10
7.1 General.....	10
7.2 Standard supporting construction.....	10
7.3 Non-standard supporting constructions.....	10
8 Conditioning.....	11
8.1 General.....	11
8.2 Sealing materials prepared with moisture .....	11
9 Application of instrumentation.....	11
9.1 Thermocouples .....	11
9.1.1 Furnace thermocouples (plate thermometers).....	11
9.1.2 Thermocouple locations .....	11
9.2 Pressure.....	12
10 Test procedure .....	12
10.1 General.....	12
10.2 Test measurements and observations .....	12
10.2.1 General.....	12
10.2.2 Integrity .....	12
10.2.3 Insulation (temperature of the surfaces outside the furnace – for both exposure at the inside and exposure at the outside) .....	13
10.2.4 Additional observations.....	13
10.3 Termination of the test .....	13
11 Performance criteria.....	13
11.1 Integrity .....	13
11.2 Insulation .....	13

<b>12</b>	<b>Test report.....</b>	<b>13</b>
<b>13</b>	<b>Field of direct application of test results .....</b>	<b>14</b>
<b>13.1</b>	<b>Walls or floors through which the ducts or shafts lead .....</b>	<b>14</b>
<b>13.2</b>	<b>Sizes of ducts or shafts .....</b>	<b>14</b>
<b>13.2.1</b>	<b>Fire exposure from outside .....</b>	<b>14</b>
<b>13.2.2</b>	<b>Fire exposure from inside .....</b>	<b>15</b>
<b>13.3</b>	<b>Admissible services .....</b>	<b>15</b>
<b>13.4</b>	<b>Suspension devices for ducts .....</b>	<b>15</b>
<b>13.4.1</b>	<b>Material and sizing .....</b>	<b>15</b>
<b>13.4.2</b>	<b>Elongation .....</b>	<b>15</b>
<b>13.4.3</b>	<b>Dimensions in millimetres .....</b>	<b>16</b>
	<b>Bibliography.....</b>	<b>24</b>

## Foreword

This document (EN 1366-5:2010) has been prepared by Technical Committee CEN/TC 127 “Fire safety in buildings”, the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by September 2010, and conflicting national standards shall be withdrawn at the latest by September 2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 1366-5:2003.

This document includes a bibliography.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

## Introduction

The purpose of this test is to measure the ability of a service duct or shaft to resist the spread of fire from one fire compartment to another with fire attack from inside or outside the duct or shaft. The test specimens incorporate joints and access openings as intended in practice and are suspended as they would be in practice. Test specimens of service ducts are not loaded as in practice but a standard load is included to represent a typical service load. Test specimens of service shafts are not loaded as in practice, but a standard load is included to represent a typical service load.

**CAUTION —** The attention of all persons concerned with managing and carrying out this fire resistance test is drawn to the fact that fire testing may be hazardous and that there is a possibility that toxic and/or harmful smoke and gases may be evolved during the test. Mechanical and operational hazards may also arise during the construction of the test elements or structures, their testing and disposal of test residues.

An assessment of all potential hazards and risks to health should be made and safety precautions should be identified and provided. Written safety instructions should be issued. Appropriate training should be given to relevant personnel. Laboratory personnel should ensure that they follow written safety instructions at all times.

## 1 Scope

This European Standard specifies a method for determining the fire resistance of horizontal service ducts and vertical service shafts, which pass through walls or floors and enclose pipes and cables. The test examines the behaviour of ducts and shafts exposed to fire from outside and from inside the duct. This European Standard is intended to be read in conjunction with EN 1363-1.

This European Standard does not examine the risk of fire spread as a result of thermal conduction along the piping installed in service ducts or shafts, or thermal conduction through the media these pipes carry. It does not cover the risk of damage produced by thermal elongation or shortening of tubes and cables as a result of fire, or damaged pipe suspensions. This European Standard does not give guidance on how to test one, two or three sided service ducts or shafts.

**NOTE** Guidance on testing service ducts and shafts of less than four sides will be covered in the extended field of application rules being developed by CEN/TC 127.

This test is unsuitable for evaluating service ducts with internal barriers at walls and floors.

Whilst the walls of service ducts or shafts tested to this method may provide specified levels of integrity or insulation, testing to this European Standard does not replace the testing of the functional endurance of small electrical cables which is covered in EN 50200.

Fire resistance testing of ducts for air distribution systems is covered in EN 1366-1.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1363-1:1999, *Fire resistance tests — Part 1: General requirements*

EN 1366-3, *Fire resistance tests for service installations — Part 3: Penetration seals*

EN ISO 898-1:2009, *Mechanical properties of fasteners made of carbon steel and alloy steel — Part 1: Bolts, screws and studs with specified property classes – Coarse thread and fine pitch thread (ISO 898-1:2009)*

EN ISO 13943:2000, *Fire safety — Vocabulary (ISO 13943:2000)*

## 3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 1363-1:1999, EN ISO 13943:2000 and the following apply.

### 3.1

#### **service duct**

horizontal duct enclosing combustible or non-combustible services, such as pipes or cables

### 3.2

#### **service shaft**

vertical shaft enclosing combustible or non-combustible services, such as pipes or cables