

**Tsiviilkäibes olevad lõhkeained.
Detonaatorid ja releed. Osa 11:
Detonaatorite ja releede
kukkumiskindluse määramine**

Explosives for civil uses - Detonators and relays -
Part 11: Determination of resistance to damage by
dropping of detonators and relays

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

Käesolev Eesti standard EVS-EN 13763-11:2004 sisaldab Euroopa standardi EN 13763-11:2003 ingliskeelset teksti. Käesolev dokument on jõustatud 27.04.2004 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes. Standard on kättesaadav Eesti standardiorganisatsioonist.	This Estonian standard EVS-EN 13763-11:2004 consists of the English text of the European standard EN 13763-11:2003. This document is endorsed on 27.04.2004 with the notification being published in the official publication of the Estonian national standardisation organisation. The standard is available from Estonian standardisation organisation.
--	---

Käsitlusala: This European Standard specifies methods for checking that a detonator, relay or surface connector will not explode when accidentally dropped onto a hard surface.	Scope: This European Standard specifies methods for checking that a detonator, relay or surface connector will not explode when accidentally dropped onto a hard surface.
---	---

ICS 71.100.30

Võtmesõnad:

ICS 71.100.30

English version

**Explosives for civil uses - Detonators and relays - Part 11:
Determination of resistance to damage by dropping of
detonators and relays**

Explosifs à usage civil - Détonateurs et relais - Partie 11:
Détermination de la résistance des détonateurs et relais à
la chute

Explosivstoffe für zivile Zwecke - Zünder und
Verzögerungselemente - Teil 11: Bestimmung der
Widerstandsfähigkeit von Zündern und
Verzögerungselementen gegen Fall

This European Standard was approved by CEN on 1 September 2003.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

page

Foreword	3
Introduction	5
1 Scope	5
2 Normative references	5
3 Terms and definitions	5
4 Apparatus	5
5 Test pieces	6
6 Procedure	6
7 Test report	7
Annex A (informative) Range of applicability of the test method	8
Annex ZA (informative) Clauses of this European Standard addressing essential requirements or other provisions of EU Directives	9

Foreword

This document (EN 13763-11:2003) has been prepared by Technical Committee CEN/TC 321 "Explosives for civil uses", the secretariat of which is held by AENOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by May 2004, and conflicting national standards shall be withdrawn at the latest by May 2004.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For the relationship with EU Directive(s), see informative annex ZA, which is an integral part of this standard.

This European Standard is one of a series of standards with the generic title *Explosives for civil uses – Detonators and relays*. The other parts of this series are listed below:

prEN 13763-1	Part 1: Requirements
EN 13763-2	Part 2: Determination of thermal stability
EN 13763-3	Part 3: Determination of sensitiveness to impact
EN 13763-4	Part 4: Determination of resistance to abrasion of leading wires and shock tubes
EN 13763-5	Part 5: Determination of resistance to cutting damage of leading wires and shock tubes
EN 13763-6	Part 6: Determination of resistance to cracking at low temperatures of leading wires
EN 13763-7	Part 7: Determination of the mechanical strength of leading wires, shock tubes, connections, crimps and closures
EN 13763-8	Part 8: Determination of resistance to vibration of plain detonators
EN 13763-9	Part 9: Determination of resistance to bending of detonators
EN 13763-12	Part 12: Determination of resistance to hydrostatic pressure
prEN 13763-13	Part 13: Determination of resistance of electric detonators against electrostatic discharge
prEN 13763-15	Part 15: Determination of equivalent initiating capability
prEN 13763-16	Part 16: Determination of delay accuracy
prEN 13763-17	Part 17: Determination of no-fire current of electric detonators
prEN 13763-18	Part 18: Determination of series firing current of electric detonators
prEN 13763-19	Part 19: Determination of firing impulse of electric detonators
EN 13763-20	Part 20: Determination of total electrical resistance of electric detonators
prEN 13763-21	Part 21: Determination of flash-over voltage of electric detonators
prEN 13763-22	Part 22: Determination of capacitance, insulation resistance and insulation breakdown of leading wires

EN 13763-23 Part 23: Determination of the shockwave velocity of shock tubes

EN 13763-24 Part 24: Determination of the electrical non-conductivity of shock tubes

prEN 13763-25 Part 25: Determination of transfer capability of surface connectors and coupling accessories

prEN 13763-26 Part 26: Definitions, methods and requirements for devices and accessories for reliable and safe function of detonators and relays

CEN/TS 13763-27 Part 27: Definitions, methods and requirements for electronic initiation systems

Annex A is informative.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland and the United Kingdom.

Introduction

Detonators, relays and surface connectors might be accidentally dropped from a loading basket, from the edge of a bench, or down an unloaded borehole. This test assesses the ability of detonators, relays and surface connectors to withstand being dropped without detonating.

1 Scope

This European Standard specifies methods for checking that a detonator, relay or surface connector will not explode when accidentally dropped onto a hard surface.

2 Normative references

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text, and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

EN 13857-1:2003; *Explosives for civil uses — Part 1: Terminology*.

EN ISO/IEC 17025; *General requirements for the competence of testing and calibration laboratories (ISO/IEC 17025:1999)*.

3 Terms and definitions

For the purposes of this European Standard, the terms and definitions given in EN 13857-1:2003 apply.

4 Apparatus

4.1 Free-fall drop test

4.1.1 Clamp, with release mechanism.

4.2 Guided drop test

4.2.1 Metal tube ($5 \pm 0,05$) m long with an inner diameter of between 1,5 times to 2,0 times the diameter of the assembly being tested.

4.2.2 Steel plate, measuring 100 mm x 100 mm x 10 mm.