

High-voltage switchgear and controlgear - Gas-filled
cast aluminium alloy enclosures

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 50052:2016 sisaldab Euroopa standardi EN 50052:2016 ingliskeelset teksti.	This Estonian standard EVS-EN 50052:2016 consists of the English text of the European standard EN 50052:2016.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 16.12.2016.	Date of Availability of the European standard is 16.12.2016.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 29.130.10

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Koduleht www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:

Homepage www.evs.ee; phone +372 605 5050; e-mail info@evs.ee

English Version

**High-voltage switchgear and controlgear - Gas-filled cast
aluminium alloy enclosures**

Enveloppes moulées en alliage d'aluminium pour les
appareillages à haute tension sous pression de gaz

Hochspannungs-Schaltgeräte und -Schaltanlagen -
Gasgefüllte Kapselungen aus Leichtmetallguss

This European Standard was approved by CENELEC on 2016-09-12. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

European foreword.....	4
Introduction.....	5
1 General	6
1.1 Scope	6
1.2 Normative references	6
1.3 Quality assurance.....	7
2 Normal and special service conditions	7
3 Terms and definitions	7
4 Materials	10
4.1 Selection of material.....	10
4.2 Chemical analysis.....	11
5 Design	11
5.1 General	11
5.2 Calculation Methods.....	12
5.2.1 General	12
5.2.2 Evaluation of mechanical strength using “Design by Formula”	12
5.2.3 Evaluation of mechanical strength using “Design by Analysis”	12
5.2.4 Flanges	13
5.2.5 Bolted connections	14
5.3 Inspection and access openings	14
6 Manufacture and workmanship.....	14
6.1 Manufacture	14
6.2 Consultation between manufacturer and founder	14
6.3 Foundry technique	14
6.4 Geometry and dimensions	15
6.5 Chemical composition and mechanical properties	15
6.5.1 Sampling.....	15
6.5.2 Chemical composition	15
6.5.3 Mechanical properties.....	15
6.6 Workmanship	15
6.6.1 Surface finish	15
6.6.2 Soundness	15
7 Repair of casting defects.....	16
7.1 General	16
7.2 Repair by welding	16
7.2.1 Welding performance test	16
7.2.2 Weld procedure.....	16
7.2.3 Weld procedure test	16
7.2.4 Application to castings	17
7.2.5 Preparation of castings for weld repairs.....	17
7.2.6 Inspection of weld repair areas.....	18
7.3 Impregnation of castings.....	18
8 Thermal treatment	18
8.1 Thermal treatment procedure.....	18
8.2 Methods of heating.....	18
8.3 Quenching	18
8.4 Calibration of furnace temperature.....	18
8.5 Thermal treatment charts	18

9	Inspection, testing and certification	19
9.1	Type tests	19
9.1.1	General	19
9.1.2	Burst test procedure	19
9.1.3	Strain measurement test.....	19
9.2	Inspection and routine tests.....	20
9.2.1	General	20
9.2.2	Visual inspection	20
9.2.3	Dye penetrant examination.....	20
9.2.4	Radiographic examination.....	20
9.2.5	Ultrasonic examination	20
9.2.6	Reporting of non-destructive test examinations.....	21
9.2.7	Routine pressure test.....	21
9.2.8	Tightness test	21
9.3	Certification.....	21
9.3.1	Design specification, drawings and data sheets	21
9.3.2	Certificate	21
9.3.3	Stamping	21
9.3.4	Final inspection of castings	21
10	Pressure relief devices	21
10.1	General	21
10.2	Bursting discs.....	22
10.3	Self-closing pressure relief valves	22
10.4	Non-self-closing pressure relief devices	22
Annex A (informative)	A-deviations.....	24
Bibliography	26

European foreword

This document (EN 50052:2016) has been prepared by CLC/TC 17AC “High-voltage switchgear and controlgear”.

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2017-09-12
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2019-09-12

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 50052:1986.

This European Standard supplements the relevant product standards on gas-insulated switchgear and controlgear in that it provides specific requirements for pressurized high-voltage switchgear and controlgear.

This European Standard has been written to get a European specification for the design, construction, testing, inspection and certification of pressurized enclosures used in high-voltage switchgear and controlgear.

In this respect, this European Standard constitutes the exclusion of HV switchgear from the scope of the Directive 2014/68/EU (superseding 97/23/EC) concerning pressure equipment. Article 1, 2. (l) excludes “enclosures for high-voltage electrical equipment such as switchgear, controlgear, transformers, and rotating machines” from the scope of the Directive.

This European Standard deals with gas-insulated switchgear enclosures of cast aluminium alloy. For different enclosure materials other European Standards are available.

Introduction

This standard covers the requirements for the design, construction, testing, inspection and certification of gas-filled enclosures for use specifically in high-voltage switchgear and controlgear, or for associated gas-filled equipment.

Special consideration is given to these enclosures for the following reasons.

- (a) The enclosures usually form the containment of electrical equipment, thus their shape is determined by electrical rather than mechanical requirements.
- (b) The enclosures are installed in restricted access areas and the equipment is operated by instructed, authorized persons only.
- (c) As the thorough drying of the inert, non-corrosive gas medium is fundamental to the satisfactory operation of the electrical equipment, the gas is periodically checked. For this reason, no internal corrosion allowance is required on the wall thickness of these enclosures.
- (d) The enclosures are subjected to only small fluctuations of pressure as the gas-filling density shall be maintained within close limits to ensure satisfactory insulating and arc-quenching properties. Therefore the enclosures are not liable to fatigue due to pressure cycling.
- (e) The operating pressure is relatively low.

Due to the foregoing reasons and to ensure maximum service continuity as well as to reduce the risk of moisture and dust entering the enclosures which may endanger safe electrical operation of the switchgear, no pressure tests should be carried out after installation and before placing in service and no periodic inspection of the enclosure interiors or pressure tests should be carried out after the equipment is placed in service.

1 General

1.1 Scope

This European Standard applies to cast aluminium alloy enclosures pressurized with dry air, inert gases, for example sulphur hexafluoride or nitrogen or a mixture of such gases, used in indoor or outdoor installations of high-voltage switchgear and controlgear above 1 kV, where the gas is used principally for its dielectric and/or arc-quenching properties with rated voltages

- above 1 kV and up to and including 52 kV and with gas-filled enclosures with design pressure higher than 300 kPa relative pressure (gauge);
- and with rated voltage above 52 kV.

The enclosures comprise parts of electrical equipment not necessarily limited to the following examples:

- Circuit-breakers
- Switch-disconnectors
- Disconnectors
- Earthing switches
- Current transformers
- Voltage transformers
- Surge arrestors
- Busbars and connections
- etc.

The scope also covers enclosures of pressurized components such as the centre chamber of live tank switchgear, gas-insulated current transformers, etc.

1.2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 10204, *Metallic products — Types of inspection documents*

EN 12258-1:2012, *Aluminium and aluminium alloys — Terms and definitions — Part 1: General terms*

EN 50064, *Wrought aluminium and aluminium alloy enclosures for gas-filled high-voltage switchgear and controlgear*

EN 62271-1:2008, *High-voltage switchgear and controlgear — Part 1 Common specifications (IEC 62271-1:2007)*

EN 62271-203:2012, *High-voltage switchgear and controlgear — Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV (IEC 62271-203:2011)*

EN ISO 898 (series), *Mechanical properties of fasteners made of carbon steel and alloy steel*

EN ISO 6520-1:2007, *Welding and allied processes — Classification of geometric imperfections in metallic materials — Part 1: Fusion welding (ISO 6520-1:2007)*

EN ISO 9712, *Non-destructive testing — Qualification and certification of NDT personnel (ISO 9712)*

EN ISO 15614-4, *Specification and qualification of welding procedures for metallic materials — Welding procedure test — Part 4: Finishing welding of aluminium castings (ISO 15614-4)*

1.3 Quality assurance

It is the intention of this standard that the switchgear manufacturer shall be responsible for achieving and maintaining a consistent and adequate quality of the product.

Sufficient examinations shall be made by the founder to ensure that the materials, production and testing comply in all respects with the requirements of this standard.

Inspection by the user inspectors shall not absolve the manufacturer or the founder from their responsibility to exercise such quality assurance procedures as to ensure that the requirements of this standard are satisfied.

2 Normal and special service conditions

Clause 2 of EN 62271-1:2008 is applicable.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

enclosure

part of gas-insulated metal-enclosed switchgear retaining the insulating gas under the prescribed conditions necessary to maintain safely the rated insulation level, protecting the equipment against external influences and providing a high degree of protection to personnel

3.2

manufacturer

organisation that is responsible for the design of the enclosure and the production of the gas-insulated switchgear. In this standard this is the switchgear manufacturer

3.3

founder

organisation that produces the raw casting of the enclosure

3.4

design pressure

pressure, expressed in relative terms (gauge), used to determine the thickness of the enclosure

Note 1 to entry: It is at least equal to the maximum pressure in the enclosure at the highest temperature that the gas used for insulation can reach under specified maximum service conditions.

3.5

design temperature (of an enclosure)

maximum temperature that the enclosures can reach under specified maximum service conditions

[SOURCE: 3.112, EN 62271-203:2012]

Note 1 to entry: This is generally the upper limit of ambient air temperature increased by the temperature rise due to the flow of rated normal current.

Note 2 to entry: Solar radiation should be taken into account when it has a significant effect on the temperature of the gas and on the mechanical properties of materials. Similarly, the effects of low temperatures on the properties of materials should be considered.