

**Cables of rated voltages up to and including 450/750 V and having thermoplastic insulation -- Part 15: Single core cables, insulated with halogen-free thermoplastic compound, for fixed wiring**

Cables of rated voltages up to and including 450/750 V and having thermoplastic insulation -- Part 15: Single core cables, insulated with halogen-free thermoplastic compound, for fixed wiring

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

<p>Käesolev Eesti standard EVS-HD 21.15 S1:2006 sisaldab Euroopa standardi HD 21.15 S1:2006 ingliskeelset teksti.</p> <p>Käesolev dokument on jõustatud 20.10.2006 ja selle kohta on avaldatud teade Eesti standardiorganisatsiooni ametlikus väljaandes.</p> <p>Standard on kättesaadav Eesti standardiorganisatsioonist.</p>	<p>This Estonian standard EVS-HD 21.15 S1:2006 consists of the English text of the European standard HD 21.15 S1:2006.</p> <p>This document is endorsed on 20.10.2006 with the notification being published in the official publication of the Estonian national standardisation organisation.</p> <p>The standard is available from Estonian standardisation organisation.</p>
--	---

<p><b>Käsitlusala:</b></p> <p>This Part 15 details the particular specifications for single-core non-sheathed cables for fixed wiring at rated voltages up to and including 450/750 V, insulated with halogen-free thermoplastic compound and having low emission of smoke and corrosive gases when exposed to fire. For cables rated at 450/750 V there are two types, Type 1 and Type 2. Type 2 cables are required to meet a more severe test for resistance to flame propagation (EN 50266-2-4) than Type 1, and have particular suitability for installation in bunches (see also Annex C). The maximum permissible conductor temperature is 70 °C.</p>	<p><b>Scope:</b></p> <p>This Part 15 details the particular specifications for single-core non-sheathed cables for fixed wiring at rated voltages up to and including 450/750 V, insulated with halogen-free thermoplastic compound and having low emission of smoke and corrosive gases when exposed to fire. For cables rated at 450/750 V there are two types, Type 1 and Type 2. Type 2 cables are required to meet a more severe test for resistance to flame propagation (EN 50266-2-4) than Type 1, and have particular suitability for installation in bunches (see also Annex C). The maximum permissible conductor temperature is 70 °C.</p>
--	--

ICS 29.060.20

Võtmesõnad:

English version

**Cables of rated voltages up to and including 450/750 V  
and having thermoplastic insulation  
Part 15: Single core cables, insulated with halogen-free thermoplastic  
compound, for fixed wiring**

Conducteurs et câbles isolés avec des  
matériaux thermoplastiques de tension  
assignée au plus égale à 450/750 V  
Partie 15: Monoconducteurs pour  
installation fixe, isolés avec un mélange  
thermoplastique sans halogène

Starkstromleitungen mit thermoplastischer  
Isolierhülle mit Nennspannungen bis  
450/750 V  
Teil 15: Halogenfreie Aderleitungen mit  
thermoplastischen Werkstoffen für feste  
Verlegung

This Harmonization Document was approved by CENELEC on 2006-09-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the Central Secretariat or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Central Secretariat: rue de Stassart 35, B - 1050 Brussels**

## Foreword

This Harmonization Document was prepared by the Technical Committee CENELEC TC 20, Electric cables, from Vilamoura Notification BT(ES/NOT)5 and introduces a range of single core cables equivalent to those in HD 21.3 but with halogen-free thermoplastic insulation. The text of the draft was submitted to the formal vote and was approved by CENELEC as HD 21.15 S1 on 2006-09-01 without any modification.

The following dates were fixed:

- latest date by which the existence of the HD has to be announced at national level (doa) 2007-03-01
- latest date by which the HD has to be implemented at national level by publication of a harmonized national standard or by endorsement (dop) 2007-09-01
- latest date by which the national standards conflicting with the HD have to be withdrawn (dow) 2008-09-01

HD 21 has the following parts:

HD 21.1 S4	General requirements
HD 21.2 S3	Test methods
HD 21.3 S3	Non-sheathed cables for fixed wiring
HD 21.4 S2	Sheathed cables for fixed wiring (Reprint)
HD 21.5 S3	Flexible cables (cords)
HD 21.6	(Spare)
HD 21.7 S2	Single core non-sheathed cables for internal wiring for a conductor temperature of 90 °C
HD 21.8 S2	Single core non-sheathed cables for decorative chains
HD 21.9 S2	Single core non-sheathed cables for installation at low temperatures
HD 21.10 S2	Extensible leads
HD 21.11 S1	Cables for luminaires
HD 21.12 S1	Heat-resistant flexible cables (cords)
HD 21.13 S1	Oil resistant PVC sheathed cables with two or more conductors
HD 21.14 S1	Flexible cables (cords), insulated and sheathed with halogen-free thermoplastic compounds
HD 21.15 S1	Single core cables, insulated with halogen-free thermoplastic compound, for fixed wiring

## Contents

1	Scope.....	4
2	Normative references .....	4
3	Terms and definitions .....	5
4	Single-core non-sheathed cable with rigid conductor for general purposes .....	5
4.1	Code designation .....	5
4.2	Rated voltage.....	5
4.3	Construction.....	5
4.4	Tests .....	6
4.5	Smoke emission of cable.....	6
4.6	Guide to use.....	6
5	Single-core non-sheathed cable with flexible conductor for general purposes.....	8
5.1	Code designation .....	8
5.2	Rated voltage.....	8
5.3	Construction.....	9
5.4	Tests .....	9
5.5	Smoke emission of cable.....	9
5.6	Guide to use.....	9
6	Single-core non-sheathed cable with rigid conductor for internal wiring .....	11
6.1	Code designation .....	11
6.2	Rated voltage.....	11
6.3	Construction.....	12
6.4	Tests .....	12
6.5	Smoke emission of cable.....	12
6.6	Guide to use.....	12
7	Single-core non-sheathed cable with flexible conductor for internal wiring .....	14
7.1	Code designation .....	14
7.2	Rated voltage.....	14
7.3	Construction.....	14
7.4	Tests .....	14
7.5	Smoke emission of cable.....	14
7.6	Guide to use.....	14
	Annex A (normative) Requirements for halogens .....	16
	Annex B (normative) Determination of halogens – Elemental test .....	18
	Annex C (informative) Proposed amendment to HD 516 S2 .....	20

## Tables

Table 1 - General data for Types H07Z1-U and H07Z1-R .....	7
Table 2 - Tests for Types H07Z1-U and H07Z1-R .....	8
Table 3 - General data for Type H07Z1-K .....	10
Table 4 - Tests for Type H07Z1-K .....	11
Table 5 - General data for Types H05Z1-U and H05Z1-R .....	13
Table 6 - Tests for Types H05Z1-U and H05Z1-R .....	13
Table 7 - General data for Type H05Z1-K .....	15
Table 8 - Tests for Type H05Z1-K .....	15
Table A.1 .....	16
Table A.2 .....	17

## 1 Scope

This Part 15 details the particular specifications for single-core non-sheathed cables for fixed wiring at rated voltages up to and including 450/750 V, insulated with halogen-free thermoplastic compound and having low emission of smoke and corrosive gases when exposed to fire. For cables rated at 450/750 V there are two types, Type 1 and Type 2.

Type 2 cables are required to meet a more severe test for resistance to flame propagation (EN 50266-2-4) than Type 1, and have particular suitability for installation in bunches (see also Annex C).

The maximum permissible conductor temperature is 70 °C.

All cables shall comply with the appropriate requirements given in Part 1 of HD 21 and with the particular requirements of this Part 15.

NOTE 1 The overall dimensions of cables in HD 21.15 S1 have been calculated in accordance with EN 60719.

NOTE 2 Low emission of smoke is checked in accordance with EN 61034-2. Low emission of corrosive gases is checked as part of the check for absence of halogens (see Annex A).

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 50266 Series	Common test methods for cables under fire conditions - Test for vertical flame spread of vertically-mounted bunched wires or cables
EN 50267-2-1	Common test methods for cables under fire conditions - Tests on gases evolved during combustion of materials from cables - Part 2-1: Procedures - Determination of the amount of halogen acid gas
EN 50267-2-2	Part 2-2: Procedures - Determination of degree of acidity of gases for materials by measuring pH and conductivity
EN 50356	Method for spark testing of cables
EN 50363-7	Insulating, sheathing and covering materials for low voltage energy cables - Part 7: Halogen-free, thermoplastic insulating compounds
EN 50395	Electrical test methods for low voltage energy cables
EN 50396	Non electrical test methods for low voltage energy cables
HD 21 Series	Cables of rated voltages up to and including 450/750 V and having thermoplastic insulation
HD 516	Guide to use of low voltage harmonized cables
EN 60228	Conductors of insulated cables (IEC 60228)

EN 60332-1-2	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame (IEC 60332-1-2)
EN 60684-2	Flexible insulating sleeving - Part 2: Methods of test (IEC 60684-2)
EN 60719	Calculation of the lower and upper limits for the average outer dimensions of cables with circular copper conductors and of rated voltage up to and including 450/750 V (IEC 60719)
EN 60811 Series	Insulating and sheathing materials of electric and optical cables - Common test methods (IEC 60811 Series)
EN 61034-2	Measurement of smoke density of cables burning under defined conditions - Part 2: Test procedure and requirements (IEC 61034-2)

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

#### 3.1

##### **Type 1 cable**

cable meeting the requirements for resistance to flame spread as given in EN 60332-1-2

#### 3.2

##### **Type 2 cable**

cable meeting the requirements for resistance to flame spread as given in EN 60332-1-2 and additionally as given in EN 50266-2-4

### 4 Single-core non-sheathed cable with rigid conductor for general purposes

#### 4.1 Code designation

H07Z1-U, for cables with solid conductors;

H07Z1-R, for cables with stranded rigid conductors.

#### 4.2 Rated voltage

450/750 V

NOTE 600/1 000 V, when this cable is used in fixed installations with mechanical protection, within switchgear and controlgear (see HD 516).

#### 4.3 Construction

##### 4.3.1 Conductor

Number of conductors: 1

The conductors shall comply with the requirements given in EN 60228:

- class 1 for solid conductors;
- class 2 for stranded conductors.

##### 4.3.2 Separator

A separator of suitable material may be applied around the conductor.